



**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8**

1595 Wynkoop Street
DENVER, COLORADO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region8>

August 11, 2021

1:16 PM

Received by
EPA Region VIII
Hearing Clerk

Ref: 8ENF-W-SD

SENT VIA EMAIL
DIGITAL READ RECEIPT REQUESTED

The Honorable Shelly R. Fyant, Chairwoman
Confederated Salish and Kootenai Tribes of the Flathead Reservation
shelly.fyant@cskt.org

Ms. Raquel Davis, Program Manager
Salish Kootenai Housing Authority
rjdavis@skha.org

Re: Emergency Administrative Order Addendum, Salish Kootenai Housing Authority
regarding Turtle Lake Public Water System, PWS ID #083090032
Docket # SDWA-08-2021-0025

Dear Chairwoman Fyant and Ms. Davis:

This is an Addendum to the Emergency Administrative Order (Order) for the Turtle Lake Public Waters System issued to the Salish Kootenai Housing Authority (Housing Authority) on June 14, 2021. The purpose of this letter is to approve the Housing Authority's June 17, 2021 schedule (Schedule) for coming into consistent compliance with the *E.coli* maximum contaminant level (MCL). The Schedule is hereby incorporated into the Order pursuant to paragraph 20. Each milestone and deadline specified below is an enforceable provision of the Order.

Milestone

Deadline

Installation of independent sampling site between WL01 and WL02 and their point of connection	Completed June 16, 2021
Retest WL01 and WL02 once sampling sites are installed to get true sampling test from each well.	Completed June 17, 2021
Shock wells WL01 and WL02 and distribution system	Completed June 17, 2021
Flush system and begin residual chlorine testing	Completed June 21, 2021
Continue with daily residual chlorine testing	Completed June 22, 2021

Begin 3-daily Total Coliform Testing	Completed June 30, 2021
Installation of temporary chlorination	Completed June 23, 2021

If you have any questions concerning this Addendum, please contact Steven Latino via email at latino.steven@epa.gov or by phone at (800) 227-8917, extension 6440, or (303) 312- 6440. Any legal questions from the Respondent's attorney should be directed to Abigail Dean, Senior Assistant Regional Counsel, via email at Dean.Abigail@epa.gov or by phone at (800) 227-8917, extension 6106, or (303) 312- 6106.

Sincerely,

Suzanne J. Bohan, Director
Enforcement and Compliance Assurance Division

cc: Wilhelmina ("Willie") Keenan, Environmental Director
Chauncey Means, Water Resources Administrator
Alisha McDanal, Water Quality Specialist
Raquel Davis, SKHA Program Manager
Bud Gillin, SKHA Operations Manager
Dan Lipscomb, Water Quality Staff
Evan Smith, Water Regulatory Specialist
Richard Racine, IHS
Jason Schneider, IHS
Missy Haniewicz, EPA Regional Hearing Clerk