



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2007 SEP 18 PM 2:04

HELEN J. FARING
HEARING CLERK

Ref: ENF-W

SEP 18 2007

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Ms. Sherry Daigle, Treasurer
South Park Village Subdivision
aka South Park Village Home Owners Association
P.O. Box 1727
Jackson, WY 83001

Re: Emergency Administrative Order/
Administrative Order Addendum
South Park Village Subdivision
Docket No. SDWA-08-2007-0065 and
SDWA-08-2007-0032
PWS ID #WY5600836

Dear Ms. Daigle:

This addendum to the Administrative Order (the Order) issued March 1, 2007 and the Emergency Administrative Order (Emergency Order) issued July 20, 2007 to the South Park Village Subdivision, incorporates the schedule for treatment and modification completion outlined in the August 15, 2007 e-mail from you, on behalf of the South Park Village Subdivision public water system (the System). This letter constitutes the written approval by EPA of the schedule set forth in this letter. As provided in Paragraph 3 of the "order" section of the March 1, 2007 Order and Paragraph D.1.h. (page 7) of the Emergency Order, the effect of today's approval is to incorporate the following schedule into both the Order and Emergency Order. Each deadline in this schedule will be enforceable as if it were part of the Orders themselves.

The following schedule lists the action to be taken, deadline date and completion date if applicable.

<u>Action</u>	<u>Deadline</u>	<u>Completion</u>
Submit to EPA detailed plans for bringing the System into compliance with the total coliform bacteria maximum contaminant level (MCL).	August 20, 2007	August 15, 2007
Submit to EPA monthly reports on the progress made towards bringing the System into compliance with the total coliform bacteria MCL.	1 st report due: September 15, 2007 and monthly thereafter until plan is completed	
Purchase a new pump for and install the slurry chlorination system as a replacement for the current pellet chlorination system.	October 31, 2007	
Collect one chlorine residual sample daily to insure proper operation of the chlorination system. Submit chlorine residual results within 10 days of the end of each month.	Ongoing	
Repair fence around wellhead to eliminate livestock from entering the area and causing potential damage.	October 31, 2007	
Ensure that all electrical wiring on the chlorinator is within conduit, sealed, and connected to the unit.	October 31, 2007	September 6, 2007
Notify EPA in writing of completion of plans and modifications.	Within one week of completion	

Please be advised that South Park Village Subdivision is required to comply with all provisions of the Administrative Order and the Emergency Administrative Order. Penalties for failing to comply are set forth in the Orders. Please contact Kimberly Pardue Welch, at (303) 312-6983 if you have any questions concerning this Addendum. If you are represented by an attorney, please ask your attorney to call Peggy Livingston at the above 800 number, extension 6858, or at (303) 312-6858.

Sincerely,



Diane L. Sipe, Director
Technical Enforcement Program
Office of Compliance, Enforcement,
and Environmental Justice



Michael T. Risner, Director
David J. Janik, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: Maria VanderLoop, Clearwater Operations LLC
WY DEQ (via email)
WY DOH (via email)

