



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2014 JUN 30 AM 8:46

FILED
EPA REGION VIII
HEARING CLERK

JUN 30 2014

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Big Valley and Crossed Arrows Improvement District
c/o Wayne McBroom, President
P.O. Box 33
Meeteetse, WY 82433

Re: Administrative Order Addendum, Big Valley and Crossed Arrows Improvement District,
PWS ID#5601193, Docket No. SDWA-08-2014-0010

Dear Mr. McBroom:

This letter is an addendum to the Administrative Order (Order) issued March 25, 2014, to the Big Valley and Crossed Arrows Improvement District. The purpose of this letter is to approve the plan and schedule from you to the EPA dated April 26 and supplemented on May 26, 2014, to address the continuing total coliform maximum contaminant level violations. The EPA understands that Dan Chamberlain, Wyoming Association of Rural Water Systems (WARWS), has been providing on-site technical assistance. The plan and schedule shown below are hereby incorporated into the Order per paragraph 7 (page 2) of the Order.

<u>Action</u>	<u>Completion Date</u>
Excavated around tanks to prepare for a new tank. No defects or leaks found.	June 2013 (completed)
Drained distribution lines and tanks, cleaned one tank, disinfected and flushed tank and system.	August 2013 (completed)
Drained and cleaned second tank, disinfected and flushed tank and system.	October 2013 (completed)
Excavated area around well house to fix line break, system disinfected and flushed.	June 6, 2014 (completed June 12, 2014)
Annually disinfect and flush distribution system.	On-going

Please contact Kathelene Brainich, Environmental Specialist, at (303) 312-6481 if you have any questions concerning this Addendum.

Sincerely,



Arturo Palomares, Director
Water Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: WY DEQ/DOH (via email)
Tina Artemis, EPA Regional Hearing Clerk