

**From:** [Carballal-Broome, Christina](#)  
**To:** [mostdiek@rdzeng.com](#); [jacksonhole@me.com](#)  
**Cc:** [StClair, Kyle \(he/him/his\)](#); [Kahn, Lisa \(she/her\)](#); [Harris, Jamie S. \(she/her\)](#); [Langenfeld, Matthew](#); [Shalkey, Jane](#); [Eakins, Shaula](#); [Haniewicz, Melissa \(Missy\)](#); [Detty, Joan](#); [Cantor, Tiffany](#); [Wells, Ellen](#); [Rathbone, Colleen \(she/her\)](#); [Tribbett, Katherine \(Kate\)](#); [justin.latham@wyo.gov](#); [ashley.stegeman@wyo.gov](#); [william.tillman@wyo.gov](#); [bradley.ellis@wyo.gov](#); [doug.evans@wyo.gov](#); [dennis.lewis@wyo.gov](#); [Brough, James](#); [Kim Parker](#); [Lorraine.werner@wy.usda.gov](#); [mark.baron@wyo.gov](#); [roykehs@laramiecounty.com](#); [rheald@cnchd.org](#); [sara.budge@wyo.gov](#); [geffres@sweet.wy.us](#); [stanley.miller@wyo.gov](#); [markp](#); [clay.vanhouten@wyo.gov](#); [Tourney, Seth](#)  
**Subject:** Closure of the May 28, 2021 - Rivermeadows Water District (WY5600786) Emergency Administrative Order; Docket Number SDWA-08-2021-0023  
**Date:** Friday, December 17, 2021 1:50:27 PM

---

The EPA has decided to close the Emergency Administrative Order (Order) regarding the public water system specified in the subject line. The EPA has determined that there are no remaining requirements of the Order. System improvements included installing a new chlorine pump; modifying the tank vent design; installing a stainless steel screen on the storage tank overflow outlet; drilling a drain in the storage tank to access the hatch drainage collection channel to convey stormwater to exterior wall; building a work platform in the storage tank hatch for concrete repairs and installing weather stripping on the tank hatchway doors to prevent exterior drainage into tank.

Please be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations), 40 C.F.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and/or penalties.

Thank you for resolving these issues. If you have any questions regarding this matter, please contact me.

*Christina Carballal*

SDWA Enforcement Unit | U.S. EPA – Region 8  
1595 Wynkoop Street | Denver, CO 80202 | 8ENF-W-SD  
Phone: 303.312.6046 | Email: [carballal-broome.christina@epa.gov](mailto:carballal-broome.christina@epa.gov)