



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2008 SEP -4 AM 10:03

Ref: ENF-W

SEP - 4 2008

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Mr. Kevin Vanzee, Board President
Flying X Ranch Mobile Home Park
799 Halleck Canyon Road
Wheatland, WY 82201

Re: Plan Approval /
Emergency Administrative Order Addendum
Docket No. SDWA-08-2008-0079
PWS ID #WY5601104

Dear Mr. Vanzee:

As you are aware, according to paragraph 16 of the Emergency Administrative Order (EAO) EPA issued to you on July 18, 2008, concerning the Flying X Ranch Mobile Home Park (system), you were required to submit a plan to EPA to ensure compliance with the total coliform maximum contaminant level (MCL) cited in the EAO. In emails dated August 3, 7, and 11, 2008, Ray Parker, Maintenance / Facilities Manager for the system, submitted a plan to EPA on your behalf. This letter constitutes EPA's written approval by EPA of that plan, pursuant to paragraph 17 of the EAO.

The EAO is hereby amended to require that you perform each action listed in the following table by the deadline given in the table. Any noncompliance with these requirements would be subject to the same penalties described in the EAO.

<u>Action</u>	<u>Deadline</u>
Use the existing chlorination equipment to pump hypochlorite into the system during the months of May through October of each year.	October 15, 2008 (Note: You have stated that you began doing this on July 17, 2008 and are continuing to do so.)
Change sampling point #5 (SP05) from a yard hydrant to a kitchen sink.	October 15, 2008
Use Hach Model CN-66 chlorine residual test kit to replace the swimming pool test kit.	October 15, 2008


Obtain additional equipment and back up hypochlorite pump to ensure effective chlorination.	October 15, 2008
Replace the water meter with a meter that has a sensor cable that will activate the hypochlorite pump when the water comes on.	October 15, 2008
Add additional material to the top of the tank with a layer of impervious material to prevent surface water from entering storage tank.	November 15, 2008

Please be advised that you must submit monthly progress reports to EPA beginning September 1, 2008, outlining your progress in completing these activities, as required in paragraph 18 of the EAO. You are still obligated to comply with the EAO as originally issued and as modified according to EPA's August 4, 2008, letter. You also remain obligated to comply with 40 C.F.R. part 141, including but not limited to the monthly total coliform sampling requirement in 40 C.F.R. §141.21 and the total coliform MCL in 40 C.F.R. §141.63.

Please contact Shawn McCaffrey at (303) 312-6515 if you have any questions concerning this letter. If you are represented by an attorney, please ask your attorney to call Peggy Livingston at the above 800 number, extension 6858, or at (303) 312-6858.

Sincerely,


Diane L. Sipe, Director
Technical Enforcement Program
Office of Compliance, Enforcement,
and Environmental Justice


David J. Janik, Acting Director
Matthew Cohn, Acting Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: WY DEQ (via email)
WY DOH (via email)
Tina Artemis, EPA Regional Hearing Clerk