



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2007 AUG 14 PM 2:40

EPA REGION VIII
HEARING CLERK

AUG 14 2007

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

South Park Village Subdivision
c/o Sherry Daigle, Treasurer
aka South Park Village Home Owners Association
P.O. Box 1727
Jackson, WY 83001

RE: Emergency Administrative
Order issued under Section 1431
SDWA to South Park Village
Subdivision
Docket No. SDWA-08-2007-0065
PWS ID #5600836


Dear Ms. Daigle:

On July 20, 2007, the U.S. Environmental Protection Agency (EPA) issued an Emergency Administrative Order (Order) under section 1431 of the Safe Drinking Water Act (the Act), 40 U.S.C. § 300i, to the South Park Village Subdivision (the System). This letter confirms the verbal notice provided to you by Kimberly Pardue Welch of EPA on July 27, 2007 for reduced monitoring and rescission of the public notification (boil order) and alternate water source requirements under the Order. Additionally, this letter serves as written notice that effective July 27, 2007, pursuant to the Order, daily bacteriological monitoring is no longer required and may be reduced to weekly monitoring. This notice is based on bacteriological monitoring conducted on July 22nd, July 23rd, July 24th, and July 25th, 2007 which were analyzed as total coliform negative. Weekly bacteriological monitoring shall be conducted until you are notified by EPA that sampling may be reduced to monthly. Additionally, you may discontinue the public notice required by the Order and may discontinue the provision of an alternative potable water supply. As an additional measure to ensure the protection of public health, on July 27, 2007, EPA requested the System take chlorine residual samples twice daily (once in the morning and again in the afternoon at the entry point to the distribution system). The System willingly complied with this request and submitted daily chlorine residual results for July 26th, July 27th, July 28th, and July 29th, 2007. South Park Village Subdivision is required to continue daily chlorine residual sampling until notified by EPA they may discontinue the sampling. Additionally, the System shall include daily chlorine

residual sampling as part of their compliance plan which is required as part of both enforcement orders. The system is required to comply with all other provisions of the Order. Penalties for failing to comply are set forth in the Order.

We appreciate your cooperation. If you have any questions regarding this matter, please contact Kimberly Pardue Welch at (303) 312-6983. If you are represented by an attorney or have legal questions, please ask your attorney to call Michelle Marcu, Enforcement Attorney, at (303) 312-6921.

Sincerely,



David J. Janik, Acting Director
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice



Diane Sipe, Director
Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice