



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2011 MAR 10 PM 12:08

FILED
EPA REGION VIII
HEARING CLERK

MAR 10 2011

Ref: 8ENF-W

CERTIFIED MAIL LETTER
RETURN RECEIPT REQUESTED

Teton Pass Properties LLC
Peter Moyer, Registered Agent
50 King Street
Suite 203
P.O. Box 3682
Jackson, WY 83001

Re: Administrative Order
Docket No. SDWA-08-2011-0017
Stagecoach Bar Public Water System
PWS ID# WY5600523

Dear Mr. Moyer:

According to paragraph 15 of the Administrative Order (Order) EPA issued on January 26, 2011, Teton Pass Properties LLC (Teton Pass) was required to submit a plan for bringing the Stagecoach Bar public water system into compliance with the total coliform maximum contaminant level (MCL) within 30 days after receipt of the Order. On February 2, 2011, EPA received from Wayne Johnson, manager of the Stagecoach Bar, a summary of events and description of system improvements that have occurred since Teton Pass exceeded the MCL for total coliform bacteria during September 2009 and October 2010. Following the October 2010 MCL exceedance, Mr. Johnson met with Mike Dart and Jeff Eason of the Teton County Health Department to develop a corrective action plan. Specifically, the pressure tank was replaced, the well and distribution lines were chlorinated, and a UV light and water filter were installed.

At this time, EPA approves of these system improvements and will not require Teton Pass to submit an additional compliance plan and schedule. However, should Teton Pass again exceed the MCL for total coliform while this Order is open, EPA may order further steps and/or seek penalties for compliance.

Please be advised that Teton Pass is required to comply with all other provisions of the Order. Penalties for failing to comply are set forth in the Order. Please contact Shawn McCaffrey at (303) 312-6515 if you have any questions. If you are represented by an attorney, please ask your attorney to call Dana Stotsky at the above 800 number, extension 6905, or at (303) 312-6905.

Sincerely,

A handwritten signature in black ink, appearing to read 'Darcy O'Connor', with a long horizontal flourish extending to the right.

Darcy O'Connor, Acting Director
Water Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: Wayne Johnson, Manager, Stagecoach Bar
Tina Artemis, EPA Regional Hearing Clerk
Wyoming DEQ/DOH (via email)