



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2008 NOV -4 PM 1:25

FILED
EPA REGION VIII
HEARING CLERK

NOV - 4 2008

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Jesse Dale Ruby, Registered Agent and Operator
J M Land & Developing Co.
Ridgeway Community Well
2901 Four J Road
Gillette, WY 82718

RE: Emergency Administrative Order
Under Section 1431 SDWA
Docket No. SDWA-08-2008-0096
PWS ID #5601602

Dear Mr. Ruby:

On August 27, 2008, the US Environmental Protection Agency (EPA) issued an Emergency Administrative Order (the Order) ordering you to take various measures at the Ridgeway Community Well in response to loss of pressure events.

This letter serves as written notice that, pursuant to the Order, weekly special purpose bacteriological and chlorine residual monitoring is no longer required and you may now return to monthly monitoring. This notice is based upon safe bacteriological samples taken September 23, 24, 25, 26, 29, and 30 and October 9 and 15 after installation of a new chlorinator at the water system. EPA also was notified that a beacon was installed on top of the water tank to provide an alert should the water level drop significantly, to assist you in preventing future loss of pressure events.

The remainder of the Order remains in effect.


If you have any questions you may contact Kathelene Brainich at 1-800-227-8917, extension 6481 or (303) 312-6481 or Lisa Kahn at extension 6896 or (303) 312-6896.

Sincerely,



Diane L. Sipe, Director

Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice



for

Matthew Cohn, Director
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: WY DEQ/DOH (via e-mail)
Duane Faucett, The Water Guy (via fax)
Tina Artemis, EPA Regional Hearing Clerk