



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, COLORADO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2014 OCT -8 AM 8:56

OCT 08 2014

EPA REGION VIII
HEARING CLERK

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Cindy F. Buckendorf, Registered Agent
Eden Saloon, Inc.
3629 N. US Hwy 191
Eden, WY 82932

Re: Administrative Order Violation #4, Eden Saloon Water System, PWS ID #WY5600111
Docket No. SDWA-08-2012-0023

Dear Ms. Buckendorf:

On May 10, 2012, the U.S. Environmental Protection Agency (EPA) issued an Administrative Order (Order) ordering Eden Saloon, Inc., (Eden), as owner and/or operator of the Eden Saloon public water system, to comply with the Safe Drinking Water Act, 42 U.S.C. Section 300f et seq., and its implementing regulations, the National Primary Drinking Water Regulations, 40 C.F.R. part 141.

Our records indicate that Eden is again in violation of the Order. Among other things, the Order included the following requirements (from items 20 and 26 on pages 3 and 4 of the Order) in which Eden is named as Respondent:

1. If any total coliform routine sample for the System is positive for total coliform, Respondent shall collect a set of four repeat samples within 24 hours of being notified of the positive result and collect at least five routine samples during the next month in which the System provides water to the public, following the procedures in 40 C.F.R. § 141.21.

The EPA has received only 3 of the 4 total coliform repeat samples required after a total coliform positive result in July 2014 from the System's water.

2. Respondent shall report any violation of coliform monitoring requirements in 40 C.F.R. part 141 to the EPA within 10 days after discovering the violation, as required by 40 C.F.R. § 141.21(g)(2).

Respondent did not report the total coliform repeat monitoring violation cited above to the EPA.


The EPA is considering additional enforcement action as a result of Eden's non-compliance with the Order. Violating an Administrative Order may lead to (1) a penalty of up to \$37,500 per day per violation of the Order, and/or (2) a court injunction ordering compliance.

If you have any questions you may contact Kathelene Brainich at 1-800-227-8917, extension 6481, or (303) 312-6481. If Eden is represented by an attorney who has questions, please ask the attorney to direct any legal questions to Marc Weiner, Enforcement Attorney, at 1-800-227-8917, extension 6913 or (303) 312-6913, or at the following address:

Marc Weiner, Enforcement Attorney
U.S. EPA, Region 8 (8ENF-L)
1595 Wynkoop Street
Denver, Colorado 80202-1129

We urge your prompt attention to this matter.

Sincerely,



Kimberly Pardue-Welch, Team Leader
Drinking Water Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: WY DEQ/DOH (via email)
Tina Artemis, EPA Regional Hearing Clerk

