



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 5
77 WEST JACKSON BOULEVARD
CHICAGO, IL 60604-3590

JUN - 8 2017

REPLY TO THE ATTENTION OF

CERTIFIED MAIL #7009 1680 0000 7647 2784
RETURN RECEIPT REQUESTED

USACE, Rock Island District
Clock Tower Building
ATTN: Shannon McCurdy
Post Office Box 2004
Rock Island, Illinois 61204-2004

RUST-05-2017-0008 *fw*

Re: Notice of Violation and Compliance Order/Settlement Agreement for the Thomas J. O'Brian Lock & Dam facility located at 134th & Calumet River, Chicago, Illinois.

Dear Ms. McCurdy:


On April 3, 2017, the U.S. Environmental Protection Agency, Underground Storage Tank (UST) Section issued a Notice of Violation and a Compliance Order/Settlement Agreement (Field Citation) concerning an UST violation (i.e., failure to provide adequate overfill prevention monitoring for tank) found at the Thomas J. O'Brian Lock & Dam facility located at 134th & Calumet River, Chicago, Illinois.

We have received your signed copy of the Settlement Agreement, dated May 25, 2017 and payment for a total of \$250 in penalties. We also received supporting documentation on recent tests/records for the tanks on May 31, 2017, addressing the UST violation.

The Settlement Agreement states that it is effective upon EPA's final approval. I have enclosed a signed and dated copy of the approved Settlement Agreement. The original Settlement Agreement will remain in the EPA's files. We also have accepted and processed your payment transaction (i.e., credit card) as part of the settlement process.

If you have any further questions, please feel free to contact Arturo Cisneros, of my staff, at 312/886-7447.

Sincerely,


Gary J. Victorine, Chief
RCRA Branch

cc: Fred Schneller, Illinois OSFM

U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA) REGION 5
77 West Jackson Boulevard (LR-17J), Chicago, Illinois 60604-3590
UNDERGROUND STORAGE TANK (UST) FIELD CITATION FORM FOR EXPEDITED SETTLEMENT NO. R5-UST-17-030-AC

PART I: INSPECTION SUMMARY

Part II: SETTLEMENT AGREEMENT /COMPLIANCE ORDER

On: 04/03/2017 Time: 10:00 AM

At: Thomas O'Brian Lock & Dam
Address: 134th & Calumet River
Chicago, IL 60633

Robert Balamut
(Name of Site Representative if not the Owner or Operator)

Name and address of the UST Owner

Name: U.S. Army Corps of Engineer
Address: P.O. Box 2004
Rock Island, IL 61204-2004

A duly designated officer, employee, or representative of the EPA or a duly designated officer or employee of the State or Tribe inspected this facility. EPA has reviewed the inspection report and other relevant materials and has identified the following violation(s) of the UST regulations promulgated or approved by EPA under Subtitle I of the Resource Conservation and Recovery Act (RCRA) (42 U.S.C. § 6991 et seq).

1. Violation: Installation of inadequate overfill prevention equipment in a new tank

Cite: 40 CFR 280.20(c)(1)(ii) Proposed Penalty: \$250

2. Violation:

Cite: 40 CFR Proposed Penalty:

3. Violation:

Cite: 40 CFR Proposed Penalty:

4. Violation:

Cite: 40 CFR Proposed Penalty:

TOTAL PROPOSED PENALTY: \$250

EPA finds the Owner or Operator in violation of the above referenced UST regulations.

[Signature]
(Signature of EPA Inspector)

4-3-17
(Date)

A. Settlement Agreement: The Owner or Operator by signing this Settlement Agreement (or by having an authorized representative sign it) agrees to settle the violations identified in Part I, subject to the following terms and conditions:

The Owner or Operator certifies, subject to civil and criminal penalties for making a false submission to the U. S. Government, that he or she has corrected the violations, submitted true and accurate documentation of their correction, and submitted payment to the U.S. Treasury for the amount of \$250 in payment of the full proposed penalty amount, as described in Part I of this Form.

The Owner or Operator agrees to comply with the terms of the Compliance Order in Part II.B. Without admitting liability for the violations cited in Part I, the Owner or Operator signing below waives any objections to EPA's jurisdiction with respect to the Compliance Order and this Settlement Agreement, and consents to EPA's final approval of this Settlement Agreement without further notice. The Owner or Operator waives the opportunity for a public hearing pursuant to RCRA section 9006.

Once EPA signs the Settlement Agreement, EPA will take no further enforcement action against the Owner or Operator for the civil violations described in Part I, provided the violations have been timely corrected and the penalty has been paid. EPA does not waive its right to enforce against the Owner or Operator for any other violations not described in Part I and violations of the UST requirements or other requirements listed in Part I that were not corrected in a timely manner.

This Settlement Agreement and Compliance Order will become effective once signed by EPA and is binding on EPA and the Owner or Operator upon signature by both parties. Final approval of the Settlement Agreement and Compliance Order is in the sole discretion of the Regional Administrator, Region 5, EPA, or his or her authorized delegate. Upon final approval, EPA shall mail a copy of this document to the Owner or Operator signing below.

SIGNATURE BY OWNER, OPERATOR, OR AUTHORIZED REPRESENTATIVE:

Name (Print): Craig S. Baumgartner
Title (Print): COL, Engineer, Commander
Signature: [Signature] Date: 25 May '17

B. Compliance Order: This Compliance Order is issued under the authority of RCRA section 9006 to resolve the civil violations identified in Part I. The Owner or Operator is ordered to correct the violations, submit true and accurate documentation that the violations were corrected, and pay the total penalty amount listed in Part I of this Form. This Compliance Order shall become final and enforceable only upon signature by an EPA official with the authority to sign this document.

Name (Print): Gary J. Victorine
Title (Print): Chief, RCRA Branch
Signature: [Signature] Date: 6/8/2017

Notes:

RUST -05-2017-0008

