



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 8

1595 Wynkoop Street  
DENVER, CO 80202-1129  
Phone 800-227-8917  
<http://www.epa.gov/region08>

2007 AUG 14 PM 2:40

AUG 14 2007

EPA REGION VIII  
HEARING CLERK

Ref: 8ENF-W

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

South Park Village Subdivision  
c/o Sherry Daigle, Treasurer  
aka South Park Village Home Owners Association  
P.O. Box 1727  
Jackson, WY 83001

RE: Emergency Administrative  
Order issued under Section 1431  
SDWA to South Park Village  
Subdivision  
Docket No. SDWA-08-2007-0065  
PWS ID #5600836

Dear Ms. Daigle:

On July 20, 2007, the U.S. Environmental Protection Agency (EPA) issued an Emergency Administrative Order (Order) under section 1431 of the Safe Drinking Water Act (the Act), 40 U.S.C. § 300i, to the South Park Village Subdivision (System). This letter confirms the verbal notice provided to you by Kimberly Pardue Welch of EPA on August 13, 2007, that weekly bacteriological monitoring is no longer required. Therefore pursuant to the Order, the System may resume monthly monitoring.


This decision is based on samples collected by the System on July 30, 2007, and August 6, 2007 that were analyzed as total coliform negative. South Park Village Subdivision must collect five routine samples in August 2007 as required by 40 C.F.R. 141.21(b)(5), which requires a public water system that has one or more total coliform positive samples to collect at least 5 routine samples during the next month the system provides water to the public. The system is required to comply with all other provisions of the Order. Penalties for failing to comply are set forth in the Order.

We appreciate your cooperation. If you have any questions regarding this matter, please contact Kimberly Pardue Welch at (303) 312-6983. If you are represented by an attorney or have legal questions, please ask your attorney to call Michelle Marcu, Enforcement Attorney, at (303) 312-6921.

Sincerely,

A handwritten signature in cursive script, appearing to read "Diane Sipe".

Diane Sipe, Director  
Technical Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice

A handwritten signature in cursive script, appearing to read "David J. Janik".

David J. Janik, Acting Director  
Legal Enforcement Program  
Office of Enforcement, Compliance  
and Environmental Justice