



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2007 AUG 20 PM 1:35

EPA REGION VIII
HEARING CLERK

AUG 20 2007

Ref: 8ENF-W

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Mr. Robert Day, Vice-President
Sleepy Hollow Homeowners Association, Inc.
aka Sleepy Hollow Subdivision
6304 Irving Blvd.
Gillette, WY 82718

Bret Wolz, Operator
Falcon Consulting Services
P.O. Box 3943
Gillette, WY 82717

RE: Emergency Administrative
Order issued under Section 1431
SDWA to Sleepy Hollow Subdivision
Docket No. SDWA-08-2007-0068
PWS ID #5600764


Dear Messrs. Day and Wolz:

On August 2, 2007, the U.S. Environmental Protection Agency (EPA) issued an Emergency Administrative Order (Order) under section 1431 of the Safe Drinking Water Act (the Act), 40 U.S.C. § 300i, to the Sleepy Hollow Homeowners Association, Inc. and Brett Wolz, owner and operator respectively of the Sleepy Hollow Subdivision public water system (the System). This letter confirms the verbal notice provided to you by Kimberly Pardue Welch of EPA on August 9, 2007 for reduced monitoring and rescission of the public notification (boil order) and alternate water source requirements under the Order. Additionally, this letter serves as written notice that effective August 9, 2007, pursuant to the Order, daily bacteriological monitoring is no longer required and may be reduced to weekly monitoring. This notice is based on bacteriological monitoring conducted on August 3rd, August 4th, August 5th, August 6th, and August 7th, 2007 which were analyzed as total coliform negative. Weekly bacteriological monitoring shall be conducted until you are notified by EPA that sampling may be reduced to monthly. Additionally, you may discontinue the public notice required by the Order and may discontinue the provision of an alternative potable water supply. As an additional measure to ensure the protection of public health, the System is required to continue


daily monitoring of the chlorine residual at two locations in the distribution system until notified by EPA to discontinue the sampling. The system is required to comply with all other provisions of the Order. Penalties for failing to comply are set forth in the Order.

We appreciate your cooperation. If you have any questions regarding this matter, please contact Kimberly Pardue Welch at (303) 312-6983. If you are represented by an attorney or have legal questions, please ask your attorney to call Marc Weiner, Enforcement Attorney, at (303) 312-6913.

Sincerely,



David J. Janik, Acting Director
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice



Diane Sipe, Director
Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

bcc: