



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 8

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2008 MAY 29 AM 9:57

EPA REGION VIII
HEARING CLERK

Ref: 8ENF-W

MAY 29 2008

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Honorable Mayor Bradshaw
Town of Lyman
P.O. Box 300
100 East Sage Street
Lyman, WY 82937

Gary Hutchinson, Public Works Director
Town of Lyman Water System
P.O. Box 300
Lyman, WY 82937

RE: Emergency Administrative
Order issued under Section 1431
SDWA to Town of Lyman
Docket No. SDWA-08-2008-0058
PWS ID #5600033

Dear Mayor Bradshaw and Mr. Hutchinson:

On May 21, 2008, the U.S. Environmental Protection Agency (EPA) issued an Emergency Administrative Order (Order) under section 1431 of the Safe Drinking Water Act (the Act), 40 U.S.C. § 300i, to the Town of Lyman, owner of the Town of Lyman water system (the System) which is a consecutive water system to the Bridger Valley Joint Powers Board public water system. This letter confirms the verbal notice provided to Dave Dasher, Treasurer of the Bridger Valley Joint Powers Board, by Kimberly Pardue Welch of EPA on May 25, 2008 for reduced monitoring and rescission of the public notification (boil order) and alternate water source requirements under the Order.

Additionally, this letter serves as written notice that effective May 25, 2008, pursuant to the Order, daily bacteriological and chlorine residual monitoring are no longer required and may be reduced to weekly monitoring (two samples each per week). This notice is based on bacteriological monitoring conducted on May 22, May 23, and May 24, 2008 which were analyzed as total coliform negative as well as chlorine residual and turbidity monitoring conducted on these same dates. Weekly bacteriological and chlorine residual monitoring shall be conducted until you are notified by EPA that sampling may be reduced to monthly. Additionally, you may discontinue the public notice required by

the Order and may discontinue the provision of an alternative potable water supply. The System is required to comply with all other provisions of the Order. Penalties for failing to comply are set forth in the Order.

We appreciate your cooperation. If you have any questions regarding this matter, please contact Kimberly Pardue Welch at (303) 312-6983. If you are represented by an attorney or have legal questions, please ask your attorney to call Amy Swanson, Enforcement Attorney, at (303) 312-6906.

Sincerely,



David J. Janik, Acting Director
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice



Diane Sipe, Director
Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice