

From: [Carballal-Broome, Christina](#)
To: [Eldon Hongo](#); [Eldon Hongo](#)
Cc: [Kahn, Lisa \(she/her\)](#); [StClair, Kyle \(he/him/his\)](#); [Cantor, Tiffany](#); [Langenfeld, Matthew](#); [Harris, Jamie S. \(she/her\)](#); [Shalkey, Jane](#); [Haniewicz, Melissa \(Missy\)](#); [Tribbett, Katherine \(Kate\)](#); [bholmes1942@yahoo.com](#); [Bearley, Mia](#); [ashley.stegeman@wyo.gov](#); [Bradley Ellis](#); [Clay Vanhouten](#); [dennis.lewis@wyo.gov](#); [Doug Evans](#); [Brough, James](#); [justin.latham@wyo.gov](#); [Kim Parker](#); [Lorraine Werner](#); [mark baron](#); [roy kroeger](#); [Ruth Heald](#); [sara.budge@wyo.gov](#); [sarah.geffre](#); [Stan Miller](#); [william.tillman@wyo.gov](#); [Cantor, Tiffany](#); [Detty, Joan](#); [Jodi Stensgaard](#); [Rich Cripe \(rcripe@wrld-ltd.com\)](#)
Subject: Closure of Emergency Administrative Order - Bunkhouse Bar and Grill (WY5601129) - Docket Number SDWA-08-2021-0026
Date: Thursday, October 21, 2021 2:35:15 PM

The EPA has decided to close the Emergency Administrative Order (Order) regarding the public water system specified in the subject line. The EPA has determined that there are no remaining requirements of the Order. System improvements included installing a new sanitary hydrant between the cistern and well, a new overflow and vent on the cistern with #24 mesh screen, a new 1400-gallon cistern, a new riser for cistern with shoe box lid, concrete splash pad for overflow, float, and a bypass around the new cistern.

Please be aware that you are still required to comply with the National Primary Drinking Water Regulations (drinking water regulations), 40 C.F.R. part 141. Violation of the drinking water regulations may result in a court-imposed injunction and/or penalties.

Thank you for resolving these issues. If you have any questions regarding this matter, please contact me.

Christina Carballal

SDWA Enforcement Unit | U.S. EPA – Region 8
1595 Wynkoop Street | Denver, CO 80202 | 8ENF-W-SD
Phone: 303.312.6046 | Email: carballal-broome.christina@epa.gov