

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

FILED

2010 JUL 25 PM 1:09

REGION 6

REGIONAL HEARING CLERK

EPA REGION VI

IN THE MATTER OF

**NGL Crude Terminals, LLC
NGL Houma Terminal
Terrebonne Parish, Louisiana**

Respondent.

**CWA SECTION 311 CLASS I
CONSENT AGREEMENT
AND FINAL ORDER
UNDER 40 CFR § 22.13(b)**

Docket No. **CWA-06-2018-4806**

LEGAL AUTHORITY

1. This Consent Agreement is proposed and entered into under the authority vested in the Administrator of the U.S. Environmental Protection Agency (“EPA”) by Section 311(b)(6)(B)(i) of the Clean Water Act (“Act”), 33 U.S.C. § 1321(b)(6)(B)(i), as amended by the Oil Pollution Act of 1990, and under the authority provided by 40 CFR §§ 22.13(b) and 22.18(b)(2). The Administrator has delegated these authorities to the Regional Administrator of EPA, Region 6, who has in turn delegated them to the Director of the Superfund Division of EPA, Region 6, who has, by his concurrence, re-delegated the authority to act as Complainant to the Branch Chief of the Emergency Management Branch (formerly identified as Associate Director, Prevention and Response Branch) in Region 6, Delegation No. R6-2-51, dated February 13, 2008 (“Complainant”).

CONSENT AGREEMENT

SPCC Stipulations

The parties, in their own capacity or by their attorneys or other authorized representatives, hereby stipulate:

2. Section 311(j)(1)(C) of the Act, 33 USC § 1321(j)(1)(C), provides that the President

shall issue regulations "establishing procedures, methods, and equipment and other requirements for equipment to prevent discharges of oil from onshore or offshore vessels and from onshore or offshore facilities, and to contain such discharges...."

3. Initially by Executive Order 11548 (July 20, 1970), 35 Fed. Reg. 11677 (July 22, 1970), and most recently by Section 2(b)(1) of Executive Order 12777 (October 18, 1991), 56 Fed. Reg. 54757 (October 22, 1991), the President delegated to EPA his Section 311(j)(1)(C) authority to issue the regulations referenced in the preceding Paragraph for non-transportation-related onshore facilities.

4. EPA promulgated the Spill Prevention Control & Countermeasure (SPCC) regulations pursuant to delegated statutory authorities, and pursuant to its authorities under the Clean Water Act, 33 USC § 1251 *et seq.*, which established certain procedures, methods and other requirements upon each owner and operator of a non-transportation-related onshore or off-shore facility, if such facility, due to its location, could reasonably be expected to discharge oil into or upon the navigable waters of the United States and their adjoining shorelines in such quantity as EPA has determined in 40 CFR § 110.3 may be harmful to the public health or welfare or the environment of the United States ("harmful quantity").

5. In promulgating 40 CFR § 110.3, which implements Section 311(b)(4) of the Act, 33 USC § 1321(b)(4), EPA has determined that discharges of harmful quantities include oil discharges that cause either (1) a violation of applicable water quality standards or (2) a film, sheen upon, or discoloration of the surface of the water or adjoining shorelines, or (3) a sludge or emulsion to be deposited beneath the surface of the water or upon adjoining shorelines.

6. Respondent is a firm conducting business in the State of Louisiana, with a place of business located at 2900 North Loop West, Suite 1250, Houston, TX 77092, and is a person within the meaning of Sections 311(a)(7) and 502(5) of the Act, 33 U.S.C. §§ 1321(a)(7) and 1362(5), and 40 CFR § 112.2.

7. Respondent is the owner within the meaning of Section 311(a)(6) of the Act, 33 USC § 1321(a)(6), and 40 CFR § 112.2 of a bulk storage facility, the NGL Houma Terminal, located in Terrebonne Parish, Louisiana (“the facility”). The approximate coordinates of the facility are 29.617153° N and -90.710472° W. Drainage from the facility travels to the Intracoastal Waterway.

8. The facility has an aggregate above-ground storage capacity greater than 1320 gallons of oil in containers each with a shell capacity of at least 55 gallons. Facility capacity is approximately 10,836,000 gallons.

9. The Intracoastal Waterway is a navigable water of the United States within the meaning of 40 CFR § 112.2.

10. Respondent is engaged in drilling, producing, gathering, storing, processing, refining, transferring, distributing, using or consuming oil or oil products located at the facility.

11. The facility is therefore a non-transportation-related onshore facility which, due to its location, could reasonably be expected to discharge oil to a navigable water of the United States or its adjoining shorelines in a harmful quantity (“an SPCC-regulated facility”).

12. Pursuant to Section 311(j)(1)(C) of the Act, E.O. 12777, and 40 CFR § 112.1 Respondent, as the owner of an SPCC-regulated facility, is subject to the SPCC regulations.

SPCC Allegations

13. Paragraph 6 through 12 above are re-stipulated as though fully set forth herein.

14. 40 CFR § 112.3 requires that the owner or operator of an SPCC-regulated facility must prepare a SPCC plan in writing, and implement that plan in accordance with 40 CFR § 112.7 and any other applicable section of 40 CFR Part 112.

15. On July 11, 2017, EPA inspected the facility and found the following deficiencies in the Respondent's SPCC plan for the facility as follows:

- a. Respondent failed to discuss in the plan appropriate containment and or diversionary structures or equipment to prevent a discharge such that the entire containment system is constructed to prevent escape of discharge from the containment system. Specifically, the plan failed to discuss containment for piping and related appurtenances and transfer areas as required at 40 CFR § 112.7(c).
- b. Respondent failed to implement inspections and tests in accordance with written procedures, maintain records of inspections or test signed by supervisor or inspector and to maintain records for three years as required at 40 CFR § 112.7(e).
- c. Respondent failed to adequately address in the plan drainage of contaminated rainwater from diked areas into storm drain or open watercourse. In addition, the facility failed to maintain records of drainage as required at 40 CFR § 112.8(c)(3).
- d. Respondent failed to discuss in the plan appropriate qualifications for personnel performing test and inspections in accordance with industry standards and the plan failed to discuss comparison records of aboveground container integrity testing are maintained as required at 40 CFR § 112.8(c)(6).
- e. Respondent failed to provide a description in the plan of at least one type of liquid level sensing each container is equipped with as required at 40 CFR § 112.8(c)(8).
- f. Respondent failed to inspect aboveground valves, piping, and

appurtenances such as flange joints, expansion joints, valve glands and bodies, catch pans, pipeline supports, locking of valves, and metal surfaces on a regular schedule to assess their general condition as required at 40 CFR § 112.8(d)(4).

16. Respondent's deficiencies in its SPCC plan for the facility violated 40 CFR § 112.3, and impacted its ability to prevent an oil spill.

Waiver of Rights

17. Respondent admits the jurisdictional allegations set forth above and neither admits nor denies the other specific violations alleged above. Respondent waives the right to a hearing under Section 311(b)(6)(B)(i) of the Act, 33 U.S.C. § 1321(b)(6)(B)(i), and to appeal any Final Order in this matter under Section 311(b)(6)(G)(i) of the Act, 33 U.S.C. § 1321(b)(6)(G)(i), and consents to the issuance of a Final Order without further adjudication.

Penalty

18. The Complainant proposes, and Respondent consents to, the assessment of a civil penalty of **\$20,235.00**.

Payment Terms

Based on the forgoing, the parties, in their own capacity or by their attorneys or authorized representatives, hereby agree that:

19. Within thirty (30) days of the effective date of the Final Order, the Respondent shall pay the amount of **\$20,235.00** by means of a cashier's or certified check, or by electronic funds transfer (EFT). The Respondent shall submit this Consent Agreement and Final Order, with original signature, along with documentation of the penalty payment to:

Oil Spill and Response Team Leader
U. S. Environmental Protection Agency
Region 6 (6SF-EO)
1445 Ross Avenue
Dallas, Texas 75202-2733

- If you are paying by check, pay the check to "Environmental Protection Agency," noting on the check "OSTLF-311" and docket number CWA-06-2018-4806. If you use the U.S. Postal Service, address the payment to:

U.S. Environmental Protection Agency, Fines & Penalties
P.O. Box 979077, St. Louis, MO 63197-9000

- If you use a private delivery service, address the payment to:

U.S. Bank
1005 Convention Plaza, Mail Station SL-MO-C2GL
St. Louis, MO 63101

- The Respondent shall submit copies of the check (or, in the case of an EFT transfer, copies of the EFT confirmation) to the following person:

Lorena Vaughn
Regional Hearing Clerk (6RC)
U.S. Environmental Protection Agency
Region 6
1445 Ross Avenue
Dallas, TX 75202-2733

20. Failure by the Respondent to pay the penalty assessed by the Final Order in full by its due date may subject Respondent to a civil action to collect the assessed penalty, plus interest, attorney's fees, costs and an additional quarterly nonpayment penalty pursuant to Section 311(b)(6)(H) of the Act, 33 USC §1321(b)(6)(H). In any such collection action, the validity, amount and appropriateness of the penalty agreed to herein shall not be subject to review.

General Provisions

21. The Final Order shall be binding upon Respondent and Respondent's officers, directors, agents, servants, employees, and successors or assigns.

22. The Final Order does not constitute a waiver, suspension or modification of the requirements of Section 311 of the Act, 33 USC §1321, or any regulations promulgated thereunder, and does not affect the right of the Administrator or the United States to pursue any applicable injunctive or other equitable relief or criminal sanctions for any violation of law. Payment of the penalty pursuant to this Consent Agreement resolves only Respondent's liability for federal civil penalties for the violations and facts stipulated to and alleged herein.

NGL Crude Terminals, LLC

Date: 7/17/2018


George Beiriger, Terminal Manager

U.S. ENVIRONMENTAL PROTECTION AGENCY

Date: 7/24/18


for Ronald D. Crossland
Branch Chief
Emergency Management Branch
Superfund Division

FINAL ORDER

Pursuant to Section 311(b)(6) of the Act, 33 USC §1321(b)(6) and the delegated authority of the undersigned, and in accordance with the “Consolidated Rules of Practice Governing the Administrative Assessment of Civil Penalties, Issuance of Compliance or Corrective Action Orders, and the Revocation, Termination or Suspension of Permits,” codified at 40 CFR Part 22, the forgoing Consent Agreement is hereby approved and incorporated by reference into this Final Order, and the Stipulations by the parties and Allegations by the Complainant are adopted as Findings in this Final Order.

The Respondent is ordered to comply with the terms of the Consent Agreement.

Date: 7/24/10

for Carl E. Edlund
Carl E. Edlund, P.E.
Director
Superfund Division

CERTIFICATE OF SERVICE

I certify that the original and one copy of the foregoing "Consent Agreement and Final Order," issued pursuant to 40 C.F.R. 22.13(b), was filed on 7-25, 2018, with the Regional Hearing Clerk, U.S. EPA Region 6, 1445 Ross Avenue, Dallas, TX 75202-2733; and that on the same date a copy of the same was sent to the following, in the manner specified below:

NAME: Mr. George Beiriger
ADDRESS: 2900 N. Loop West; Suite 1250
Houston, TX 77092

Frankie Markham

Frankie Markham
OPA Enforcement Administrative Assistant