

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY REGION 8

1595 Wynkoop Street DENVER, CO 80202-1129 Phone 800-227-8917 http://www.epa.gov/region08 2009 SEP 24 AM 8: 41

SEP 2 4 2009

FILED EPA REGION VIII HEARING CLERK

Ref: 8ENF-W

CERTIFIED MAIL LETTER RETURN RECEIPT REQUESTED

Tim and Deborah Bishop, Owners Medicine Bow Lodge Star Route 8A Saratoga, WY 82331

Re:

Emergency Administrative Order Addendum Docket No. SDWA-08-2009-0066 Medicine Bow Lodge Public Water System PWS ID #WY5600986

Dear Mr. and Mrs. Bishop:

Pursuant to paragraph 15 of the Emergency Administrative Order (EAO) issued July 21, 2009, to you as owners and/or operators of the Medicine Bow Lodge, this Addendum to the EAO incorporates the schedule for actions aimed at ensuring compliance with the total coliform maximum contaminant level (MCL), outlined in your fax of August 3, 2009 as revised by your fax of September 2, 2009. This letter constitutes the written approval by EPA of that schedule. Please be advised that you must continue to meet the total coliform rule MCL requirements. If the actions listed in this schedule do not bring the water system into compliance with the total coliform MCL, EPA may require additional actions.

The following schedule lists the actions to be taken as set forth in your August 3, 2009 plan, including revisions of September 2, 2009, and if applicable, the start and completion dates of the actions. EPA recognizes that many of the actions have already been completed and thanks you for your proactive efforts to ensure safe drinking water for guests of the Medicine Bow Lodge.

Action	Begin Date	Completion
Inspect the chlorine system on a weekly basis	August 3, 2009	Ongoing
Take and log chlorine residual samples weekly (sampling site: kitchen). Promptly notify EPA of results.	September 2, 2009	Ongoing
Begin taking TCR samples from women's bathroom in bath house.	August 3, 2009	Until EPA approves kitchen sample site.
Restrict use of bath house by Medicine Bow Lodge "wranglers."	August 3, 2009	Ongoing
Change total coliform sampling site from bath house to kitchen.	September 2, 2009	EPA approved site change September 8, 2009.
Assure proper total coliform sampling techniques, including cleaning/sanitizing faucet, allowing water to run at least five minutes, and removing faucet screen prior to sampling.	September 2, 2009	Ongoing

Please be advised that you are required to comply with all provisions of the EAO. Penalties for failing to comply are set forth in the Order. Please contact Mario Mérida at (303) 312-6297 if you have any questions concerning this Addendum. If you are represented by an attorney, your attorney may contact Peggy Livingston, Enforcement Attorney, at (303) 312-6858 for any legal matters.

Sincerely,

Diane L. Sipe, Director Technical Enforcement Program Office of Compliance, Enforcement, and Environmental Justice

David Rall

David Rochlin, Supervisory Attorney Legal Enforcement Program Office of Enforcement, Compliance and Environmental Justice

cc: WY DEQ (via email) WY DOH (via email) Mary Peterson, Forest Supervisor, Medicine Bow National Forest Tina Artemis, EPA Regional Hearing Clerk