

(Signature of Authorized Officer or Employee of EPA)

U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA), REGION 8

1595 WYNKOOP STREET DENVER, CO 80202-1129

underground storage tank (ust) field citation form for expedited settlement no. RCRA-08-2024-0009

STATE STATE OF STATE OF THE STA	TOTAL OF LOT LEGICLE OF LOT
PART I: INSPECTION SUMMARY	PART II: SETTLEMENT AGREEMENT/COMPLIANCE ORDER
on: April 30, 2024 10:55 a.m. MST	A. Settlement Agreement: The Owner or Operator by signing this Settlement Agreement (or by having an
(Date of Inspection) (a.m. or p.m.)	authorized representative sign it) agrees to settle the violations identified in Part I, subject to the following
Red Cloud Indian School 4070002	terms and conditions:
(Facility Name and Identification Number)	The Owner or Operator certifies, subject to civil and criminal penalties for making a false submission to the
Address: 100 Mission Drive	U. S. Government, that he or she has corrected the violations, submitted true and accurate documentation of their correction, and submitted payment to the U.S. Treasury for the amount of
Pine Ridge, South Dakota 57770	\$2445\$ in payment of the full proposed penalty amount, as described in Part I of this Form.
	The Owner or Operator agrees to comply with the terms of the Compliance Order in Part II.B. Without
Name of On-site Representative if not the Owner or Operator:	admitting liability for the violations cited in Part I, the Owner or Operator signing below waives any objections to EPA's jurisdiction with respect to the Compliance Order and this Settlement Agreement, and
Monica Macek	consents to EPA's final approval of this Settlement Agreement without further notice. The Owner or
Name and address of the UST Owner or Operator (circle which applies):	Operator waives the opportunity for a public hearing pursuant to RCRA section 9006.
Red Cloud Indian School, Inc. (Mahpiya Luta Owayawa)	Once EPA signs the Settlement Agreement, EPA will take no further enforcement action against the Owne
100 Mission Drive	or Operator for the civil violations described in Part I, provided the violations have been timely corrected and the penalty has been paid. EPA does not waive its right to enforce against the Owner or Operator for
Pine Ridge, South Dakota 57770	any other violations not described in Part I and violations of the UST requirements or other requirements listed in Part I that were not corrected in a timely manner.
	This Settlement Agreement and Compliance Order will become effective once signed by EPA and is
A duly designated officer, employee, or representative of the EPA or a duly designated officer or employee	binding on EPA and the Owner or Operator upon signature by both parties. Final approval of the
of the State or Tribe inspected this facility. EPA has reviewed the inspection report and other relevant materials and has identified the following violation(s) of the UST regulations promulgated or approved by	Settlement Agreement and Compliance Order is in the sole discretion of the Regional Administrator, Regio 8, EPA, or his or her authorized delegate. Upon final approval, EPA shall mail a copy of this document t
EPA under Subtitle I of the Resource Conservation and Recovery Act (RCRA) (42 U.S.C. § 6991 et	the Owner or Operator signing below.
Egilure to energte and maintain release	SIGNATURE BY OWNER, OPERATOR, OR AUTHORIZED REPRESENTATIVE:
Failure to operate and maintain release detection method and annually test components	Name (print): Monica Macek
	Title (print): Vice President of Facilities
Cite: 40 C.F.R. §280.40(a)(3) Proposed Penalty: \$ 815	
Failure to monitor tanks installed after April 11, 2016, at	Signature: Morning March Date: 7/16/2
2. Violation: least every 30 days in accordance with 280.43(g) (interstitial monitoring)	B. Compliance Order: This Compliance Order is issued under the authority of RCRA section 9006 to
	resolve the civil violations identified in Part I. The Owner or Operator is ordered to correct the violations, submit true and accurate documentation that the violations were corrected, and pay the total penalty
Cite: 40 C.F.R. §280.41(a)(2) Proposed Penalty: \$ 815	amount listed in Part I of this Form. This Compliance Order shall become final and enforceable only upo
3. Violation: Failure to conduct monthly and annual	signature by an EPA official with the authority to sign this document.
walkthrough inspections	SIGNATURE BY EPA APPROVING THE SETTLEMENT AGREEMENT AND COMPLIANCE ORDER:
40 C.F.R. §280.36(a) Proposed Penalty: \$ 815	Name (print):
Cite:Proposed Penalty: 5	Title (print):
4. Violation:	Signature: Date:
Cite: Proposed Penalty: \$	Notes:
5. Violation:	I FILED I
	8/6/2024
Cite: Proposed Penalty: \$	2:39 PM
PROPOSED PENALTY TOTAL: \$ 2445	U.S. EPA REGION 8
	HEARING CLERK
EPA finds the Owner or Operator in violation of the above referenced UST regulations.	HEARING CLERK
MARTA GRABOWSKI Digitally signed by MARTA GRABOWSKI Date: 2024.07.01 15:10:43 -06'00' Date:	