



**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8**

1595 Wynkoop Street
DENVER, CO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2008 JUL 15 AM 10:14

EPA REGION VIII
HEARING OFFICE

Ref: 8ENF-W

JUL 15 2008

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Patrick S. Pierzina, Registered Agent
SBHY, LLC
4302 Stucky Road
Bozeman, MT 59718

Re: Administrative Order
Silos Inn Public Water System
Docket No. SDWA-08-2008-0065
PWS ID # MT0002994

Dear Mr. Pierzina:

Enclosed is an Administrative Order (Order) issued by the Environmental Protection Agency (EPA) under the authority of the Safe Drinking Water Act (the Act), 42 U.S.C. section 300f *et seq.* Among other things, the Order describes how Silos Inn has violated the National Primary Drinking Water Regulations.

The Order is effective upon the date received. Please review the Order and within 10 days provide EPA with any information you believe EPA may not have. If Silos Inn complies with the Order for twelve months, EPA may close the Order without further action. Failure to comply with the Order may lead to substantial civil penalties and/or a Federal court injunction ordering compliance.

To submit information or request an informal conference with EPA, contact Kimberly Pardue Welch at the above address (with the mailcode 8ENF-W) or by phone at (800) 227-8917, extension 6983 or (303) 312-6983. For legal questions, the attorney assigned to this matter is

Jean Belille, who may be reached at the above address (with the mailcode 8ENF-L) or by phone at (800) 227-8917, extension 6556 or (303) 312-6556.

We urge your prompt attention to this matter.

Sincerely,



Diane L. Sipe, Director
Water Technical Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

Enclosures
Order
Public notice samples/templates

cc: .
Doug Freese, Silos Inn
John Arrigo, MT DEQ
Shelly Nolan, MT DEQ

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8

2008 JUL 15 AM 10:15

EPA REGION VIII
HEADING OFFICE

_____)	
IN THE MATTER OF)	
)	
SBHY, LLC)	
Silos Inn)	
Townsend, MT)	ADMINISTRATIVE ORDER
)	
Respondent)	Docket No. SDWA-08-2008-0065

1. This Order is issued under the authority vested in the Administrator of the United States Environmental Protection Agency (EPA) in the Public Health Service Act (as amended by and hereafter referred to as the "Safe Drinking Water Act" or the "Act"), 42 U.S.C. § 300f, as properly delegated to the undersigned officials.

2. SBHY, LLC (Respondent) is a corporation which owns and/or operates the Silos Inn Water System (the system) in Broadwater County, Montana which provides piped water to the public for human consumption. The system is supplied by a groundwater source consisting of one well and serves approximately 70 people per day through 1 service connection year round. The system is a "non-community" water system as defined in 40 C.F.R. § 141.2. Respondent is subject to the requirements of the Act and the National Primary Drinking Water Regulations (drinking water regulations), at 40 C.F.R. part 141. The Respondent received annual notification from the Montana Department of Environmental Quality (MDEQ or the State) regarding the system's monitoring requirements.

3. The MDEQ has primary enforcement authority for the Act in the State of Montana. On June 9, 2008, EPA issued a Notice of Violation to MDEQ regarding the violations at the system. MDEQ elected not to commence an enforcement action against the system for the violations within the thirty-day time frame set forth in section 1414(a) of the Act, 42 U.S.C. § 300g-3(a). EPA has provided a copy of this Order to MDEQ and has provided the State, through MDEQ, with an opportunity to confer with EPA regarding this Order pursuant to section 1414(g)(2) of the Act, 42 U.S.C. § 300g-3(g)(2). EPA is issuing this Order requiring the system to comply with the "applicable requirements" it violated. An "applicable requirement" includes requirements of an applicable approved State program, such as Montana's "Public Water Supply Requirements" at Administrative Rules of Montana (Mont. Admin. R.) 17.38.101 through 703. 42 U.S.C. § 300g-3(i).

VIOLATIONS

4. Respondent is required to monitor the system's water at least once per month to determine compliance with the maximum contaminant level (MCL) for total coliform bacteria. 40 C.F.R. § 141.21 and Mont. Admin. R. 17.38.215. Respondent failed to monitor the water for contamination of total coliform bacteria during October 2006, November 2006, December 2006, January 2007, March 2007, September 2007, November 2007, and February 2008 and therefore violated this requirement.

5. The law requires Respondent to notify the public of certain violations of the drinking water regulations, in the manner specified by the regulations. 40 C.F.R. § 141.201 *et seq.* Respondent failed to notify the public of the violations that occurred in January 2007 and March 2007 which are outlined in Paragraph 4 above, and therefore violated this requirement. Public notice for the September 2007, November 2007, and February 2008 failure to monitor total coliform violations are not yet overdue.

6. Respondent is required to report failure to comply with a coliform monitoring requirement to the State within ten days after the system learned of the violation. 40 C.F.R. § 141.21(g)(2). Respondent failed to report to the State the failure to monitor total coliform violations listed in paragraph 4 above and therefore violated this requirement.

7. Respondent is required to report any failure to comply with any of the drinking water regulations (except where a different reporting period is specified in paragraph 6 above) to the State within 48 hours. 40 C.F.R. § 141.31(b). Respondent failed to report the violations listed in paragraph 5 above to the State and therefore violated this requirement.

ORDER

Based on the above violations, Respondent is ordered to perform the following actions:

8. Upon receipt of this Order, Respondent shall monitor monthly for total coliform bacteria. Mont. Admin. R. 17.38.215(1)(b). Respondent shall report analytical results to EPA and the State within the first 10 days following the month in which sample results are received, as required by the drinking water regulations. 40 C.F.R. § 141.31(a). Any violation of the total coliform monitoring requirements shall be reported to EPA and the State within ten days after Respondent learns of it. 40 C.F.R. § 141.21(g)(2).

9. Within 30 days of the effective date of this Order, Respondent must provide public notice of the violation(s) specified in Paragraph 4 in this Order (except the October - December 2006 failure to monitor total coliform violations). 40 C.F.R. §§ 141.201, 141.202 and 141.205. Respondent shall submit a copy of the public notice to EPA and the State within ten days of completion of the public notice. 40 C.F.R. § 141.31(d). This notice shall be given by (1) posting the notice in conspicuous locations throughout the distribution system frequented by persons served by the system OR (2) by mail or direct delivery to each customer and service connection; AND (3) any other method reasonably calculated to reach other persons served by the system if they would not normally be reached by the notice required above, such as publication in a local newspaper or newsletter distributed to customers; use of E-mail to notify employees or students; or delivery of multiple copies in central locations. If the public notice is posted, the notice must remain in place for as long as the violation or situation persists, but for no less than seven days. The public water system must repeat the notice every three months as long as the violation or situation persists. Upon the effective date of this Order, Respondent shall comply with the public notification requirements following any future drinking water regulations violation. 40 C.F.R. § 141.201 et seq.

10. Respondent shall report any other violation of the drinking water regulations to EPA and the State within 48 hours of discovery.

11. Reporting requirements specified in this Order shall be provided by certified mail to:

Kimberly Pardue Welch
U. S. EPA Region 8 (8ENF-W)
1595 Wynkoop Street
Denver, CO 80202-1129

AND

Shelly Nolan
Montana Department of
Environmental Quality- PWSS
P.O. Box 200901
Helena, MT 59620-0901

GENERAL PROVISIONS

12. This Order does not constitute a waiver, suspension, or modification of any requirement of the Act or drinking water regulations. Issuance of this Order is not an election by EPA to forgo any civil or criminal action.

13. Violation of any part of this Order, the Act, or the drinking water regulations may subject Respondent to a civil penalty of up to \$32,500 (as adjusted for inflation) per day of violation, 42 U.S.C. § 300g-3(g)(3); 40 C.F.R. part 19.

7/10/08
Date

Matthew Cohn
David J. Janik, Director
Matthew Cohn, Supervisory Attorney
Legal Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

7/2/08
Date

Diane L. Sipe
Diane L. Sipe, Director
Technical Water Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice