



EZY CHEK SYSTEMS
 PRODUCT LINE TEST
 FINAL REPORT

Test Date: 6/27/2016

Name: Clean Fuels Associates

Address: 7364 Edgewood Rd.

City: Annapolis, MD 21403

Phone: (410) 757-7576

Technician Information:

Name: Matthew Eader

Cert. #: 236465

Applied Pressure: 50 PSI (g)

Test Location Information

Name: Pacific Pride Station

Address: 930 Port St.

City: Easton, MD. 21601

Phone: _____

Contact: Tim Miller

**Product line test
 Final Report**

Product Type	Line ID number	PASS	FAIL
Gasoline	L04(Tank #4)	X	
Mid Gas	L02(Tank #2)	X	
Diesel	L03A(Tank #3A)	X	
Diesel	L01(Tank #1)		
Gasoline	L03B(Tank #3B)		

Comments/ Recommendations: Silver bullet installed to test L02. Ball valves good on L04 and L03A. Pumps are in a Dry run and can not pull product to test L01 and L03B. Testing is pending.

Technician Signature: Matthew Eader Date: 6/27/2016