



EZY CHEK SYSTEMS  
 PRODUCT LINE TEST  
 FINAL REPORT

Test Date: 9/1/2016

Name: Clean Fuels Associates

Address: 7666A Baltimore-Annapolis Blvd.

City: Glen Burnie, MD. 21060

Phone: (410) 757-7576

**Technician Information:**

Name: Matthew Eader

Cert. #: 236465

Applied Pressure: 50 PSI (g)

**Test Location Information**

Name: Pacific Pride Station (MDE#1656)

Address: 930 Port St.

City: Easton, MD. 21601

Phone: \_\_\_\_\_

Contact: Tim Miller

**Product line test  
 Final Report**

Product Type	Line ID number	PASS	FAIL
Diesel	L01(Tank #1)	X	
Gasoline	L03B(Tank #3B)	X	

Comments/ Recommendations: Repairs were made to the STP since the last visit and testing  
could be completed. The ball valve was good on Gasoline and used for isolation.  
Used functional element to test the Diesel line.

Technician Signature: *Matthew Eader* Date: 9/1/2016

