



ESTABROOK'S EZY CHEK LEAK DETECTOR TEST RESULTS

DATE: 6/27/2016

TESTING Clean Fuels Associates
 ADDRESS 7364 Edgewood Rd.
Annapolis, MD 21403
 PHONE: (410) 757-7576

TEST SITE: Pacific Pride Station
 ADDRESS: 930 Port St. Easton, MD.
21601

TECH NAME & CERT #: Matthew Eader #236465

TEST REPORT INDICATES

TYPE OF LEAK DETECTOR TESTED

PUMP #	MAKE	MODEL	SERIAL #
1	Veeder-Root	FX1DV	Unreadable
2	Veeder-Root	FX1V	Unreadable
3			
4	Veeder-Root	FX1V	Unreadable
5			
6			
7			
8			

PUMP #	PRODUCT TYPE	METERING PRESSURE	FUNCTIONAL ELEMENT HOLDING PSI	RESILIENCY	TEST LEAK RATE ML/MIN	OPENING TIME	PASS FAIL
1					189 ml		
2	Mid Grade(Disp. 3)(Tank #2)	28	28	330 ML	189 ml	5 sec.	P
3A	Diesel(Disp. 7)(Tank #3A)	30	30	250 ML	189 ml	4 sec.	P
3B					189 ml		
4	Unleaded Regular(Disp. 1/2)(Tank #4)	30	30	450 ML	189 ml	0 sec.	F
					189 ml		
					189 ml		
					189 ml		

** Dry runs on Tank 1 and Tank 3B. Can not test lines or MLD. Need new MLD for Tank 4**