



**ESTABROOK'S EZY CHEK
LEAK DETECTOR
TEST RESULTS**

DATE: 9/1/2016

TESTING Clean Fuels Associates

ADDRESS 7666A Baltimore-Annapolis Blvd.
Glen Burnie, MD 21060

PHONE: (410) 757-7576

(MDE # 1656)

TEST SITE: Pacific Pride Station

ADDRESS: 930 Port St. Easton, MD.
21601

TECH NAME & CERT #: Matthew Eader #236465

TEST REPORT INDICATES

TYPE OF LEAK DETECTOR TESTED

PUMP #	MAKE	MODEL	SERIAL #
1	Veeder-Root	FX1DV	6104
2			
3A			
3B	VMI	99LD-2000	12011266
4			

PUMP #	PRODUCT TYPE	METERING PRESSURE	FUNCTIONAL ELEMENT HOLDING PSI	RESILIENCY	TEST LEAK RATE ML/MIN	OPENING TIME	PASS FAIL
1	Diesel(Disp. 4/5) (Tank #1)	30 psi	15 psi	80 ml	189 ml	2 sec.	P
2					189 ml		
3A					189 ml		
3B	Unleaded Regular(Disp. 6)(Tank #3B)	30 psi	25 psi	100 ml	189 ml	2.5 sec.	P
4					189 ml		
					189 ml		
					189 ml		
					189 ml		