



7001 SOUTH FREEWAY
FORT WORTH, TX 76134-4099
817.551.3300
www.MillerCoors.com

RECEIVED
MAR 31 2009


09 MAR 31 AM 6:02

Certified Mail Return Receipt Requested 7008 0500 0001 0263 9395

March 24, 2009

RE: Written Report Non-Reportable Anhydrous Ammonia Release 3/26/2009 – MillerCoors LLC

Document Processing Center (7407M)
(Attn: Section 8(e) Coordinator)
Office of Pollution Prevention And Toxics
U.S. Environmental Protection Agency
1200 Pennsylvania Ave, NW
Washington, D.C. 20460



To Whom It May Concern:

Enclosed is the written report for the non-reportable anhydrous ammonia release at MillersCoors LLC – Fort Worth, Texas brewery.

If you have any questions, please contact me at 817-551-3347 or via e-mail at gomez.mike@millercoors.com.

Sincerely,

Mike Gomez
Brewery Environmental Coordinator

Enclosure (1)



Contains No CBI

CONTAINS NO CBI

CONTAINS NO CBI

318 221

Non-Reportable Ammonia Release February 26, 2009

On February 26, 2009 at approximately 1:00 PM, the Fort Worth brewery experienced a non-reportable release of ammonia. The release was called into the National Response Center as an unknown quantity at approximately 1:23 PM. I spoke to Operator Arsenault and provided the preliminary information. Report Number **89-8555** was issued. I notified the operator that we believed the quantity was below 100 pounds but that we were still investigating the leak. I also informed the operator that we had not notified any other regulatory agency.

The ammonia gas release was due to a gasket leak in the liquid level column on # 3 Pasteurizer Chiller in the Packaging basement. The leak was corrected by closing the liquid ammonia inlet valve to the chiller and replacing the gasket. The duration of the leak was approximately 25 minutes. The release quantity was **16 pounds** which is below the Release Quantity of 100 pounds. The Packaging basement was ventilated through the south stairwell exhaust fan. There were no injuries or equipment damage and evacuation of the brewery was not required.

Weather Conditions

Temperature: 85°F

Clear skies

Wind: 6-7 mph SE

I received a call from Mr. Richard Harris of the Texas Department of State Health Services later that afternoon and provided the preliminary release information. I forwarded an e-mail to Mr. Harris on March 2, 2009 with the additional information and spoke to him concerning the non-reportable release. He said that based on the information, the file report was closed and no further action was required.