

217/782-2113

CONSTRUCTION PERMIT - PSD APPROVAL - NSPS SOURCE

PERMITTEE

Kendall New Century Development, L.L.C.
Attn: Jeffrey Keenan, Technical Manager
1400 Smith Street
Houston, Texas 77002

Application No: 99020032

I.D. No.: 093801AAN

Applicant's Designation: ELECTRIGEN

Date Received: February 3, 1999

Subject: Electric Generation Facility (8 SSCT/83 MW Each)

Date Issued: January 14, 2000

Location: Corneils Road Between Eldamain Road and Beecher Road, Plano, Bristol Township, Kendall County

Permit is hereby granted to the above-designated Permittee to CONSTRUCT emission source(s) and/or air pollution control equipment consisting of eight gas fired combustion turbines, two natural gas fired fuel heaters, and one emergency fire-water pump diesel fired engine as described in the above referenced application and summarized in Attachment A. This Permit is granted based upon and subject to the findings and special conditions which follow:

In conjunction with this permit, approval is given with respect to the Prevention of Significant Deterioration of Air Quality Regulations (PSD) to construct the above referenced project, in that the Illinois Environmental Protection Agency (Illinois EPA) finds that the application fulfills all applicable requirements of 40 CFR 52.21. This approval is issued pursuant to the Clean Air Act, as amended, 42 U.S.C. 7401 et. seq., the Federal regulations promulgated thereunder at 40 CFR 52.21 for Prevention of Significant Deterioration of Air Quality (PSD), and a Delegation of Authority agreement between the United States Environmental Protection Agency and the Illinois EPA for the administration of the PSD Program. This approval becomes effective in accordance with the provisions of 40 CFR 124.15 and may be appealed in accordance with the provisions of 40 CFR 124.19. This approval is also based upon and subject to the following findings and conditions which follow:

Findings

1. Kendall New Century Development, L.L.C. (KNCD) has requested a permit for a electric generation facility that would include 8 "simple cycle" gas turbines. The gas turbines would be fired on natural gas and have the ability to generate up to about 664 MW of electricity.
2. The project would be constructed on a parcel of land located approximately two miles northwest of Yorkville and 6 miles east of Plano, in Kendall County. The area is currently designated attainment for all criteria pollutants.

3. a. The proposed project has the potential to emit major amounts of Nitrogen Oxides (NO_x) and Carbon Monoxide (CO). Although not a major source for Sulfur Dioxide (SO₂) or Particulate Matter (PM), potential emissions of these two pollutants are above significant levels as shown in Attachment B. The project is therefore subject to PSD review for NO_x, CO, SO₂ and PM.
- b. The proposed project has annual emissions of hazardous air pollutants that will be less than 10 tons of any hazardous pollutant and less than 25 tons in aggregate for any combination of hazardous air pollutants, as indirectly addressed by limits on emissions of criteria pollutants. Therefore, the project is not subject to review under Section 112(g) of the Clean Air Act.
4. After reviewing the materials submitted by KNCD, the Illinois EPA has determined that the project will (i) comply with applicable Board emission standards (ii) comply with applicable federal emission standards and (iii) utilize Best Available Control Technology (BACT) on emissions of NO_x, CO, SO₂ and PM.
5. The gas turbines are affected units under the Acid Rain Deposition Control Program pursuant to Title IV of the Clean Air Act and are subject to certain control requirements and emissions monitoring requirements pursuant to 40 CFR Parts 72, 73 and 75. As affected units under the Acid Rain Program, KNCD must also obtain an Acid Rain Permit before commencing operation.
6. The air quality analysis submitted by KNCD and reviewed by the Illinois EPA shows that the proposed project will not cause violations of the ambient air quality standard for NO_x, CO, SO₂ and PM. The analysis shows that project will have an insignificant impact on the ambient air quality standards.
7. The Illinois EPA has determined that the proposed project complies with all applicable Illinois Air Pollution Board Regulations and the federal Prevention of Significant Deterioration of Air Quality Regulations (PSD), 40 CFR 52.21.
8. A copy of the application and the Illinois EPA's formal review of the application and a draft of this permit were placed in a location in the vicinity of the project, and the public was given notice and an opportunity to examine this material and to submit comments and to request a public hearing on this matter.

The Illinois EPA is issuing approval to construct the proposed project subject to the following special conditions and consistent with the specifications and data included in the application. Any departure from the conditions of this approval or terms expressed in the application would need to receive prior written authorization by Illinois EPA.

Conditions

1. Standard conditions for issuance of construction permits, attached hereto and incorporated herein by reference, shall apply to this project, unless superseded by the following special conditions.
- 2a. The turbines shall each be equipped, operated, and maintained with low NO_x combustors.
 - b.
 - i. Operation of the turbine units (8 units) shall not exceed a combined total of 26,400 hours per year. Operation of each individual turbine unit shall not exceed 4,400 hours in any single year and 3,300 hours averaged over any three consecutive years.
 - ii. If at any time, the operation of an individual turbine exceeds 3,300 hours in a year, the Permittee shall demonstrate that operation of such turbine was consistent with its use as a peaking turbine, by making a detailed submittal of information to the Illinois EPA within 2 months that includes the following:
 - A. The total hours that the turbine actually operated during such year and a summary of actual operating hours of the turbine for prior years;
 - B. A description of the circumstances that contributed to actual operation for more than 3,300 hours in a year, with supporting documentation, including:
 - I. The circumstances with respect to the public demand for power, e.g., unusually cold or hot weather;
 - II. The circumstances with respect to unavailability of other turbines at the facility, e.g., unanticipated or extended outage of turbines;
 - III. The circumstances with respect to electric utility need for power, e.g., unexpected outages of major generating units or damage to power transmission systems; and
 - IV. Other circumstances that the Permittee believes contributed to the operation of the turbine for more than 3,300 hours in a year.
 - C. Further information to demonstrate that the above circumstances are uncommon or unlikely to reoccur so as to result in actual operation of the turbine for more than 3,300 hours in a year.

- iii. Prior to operation of an individual turbine for more than 3,300 hours in a year in a manner that is inconsistent with its use as a peaking turbine, the Permittee shall obtain a revised permit allowing such operation pursuant to PSD, 40 CFR 52.21, which permit may establish additional requirements for turbine as are appropriate as Best Available Control Technology.
 - iv. For the purposes of this permit, peaking operation means operation when base load generating capacity is insufficient to meet electrical demand and operating reserve requirements, due to high demand, outage of base load generating units, restrictions or interruptions in the power grid, etc. It also includes operation of a unit for purposes of verifying unit availability for the above purposes. Compliance with this requirement shall be presumed for an individual turbine if it operates for no more than 3,300 hours per year.
- c.
- i. The emissions of NO_x from each turbine shall not exceed 0.060 lb/mmBtu heat input (Low Heating Value (LHV)) on an hourly average during normal operation hereby defined as periods other than startup, low load operation, malfunction and shutdown as addressed by Condition 4.
 - ii. The emission of NO_x from each turbine shall not exceed 0.048 lb/mmBtu heat input (LHV) on a monthly average for normal operation provided a turbine operates more than 250 hours in a month.
 - iii. The emission of NO_x from each turbine shall not exceed 0.0365 lb/mmBtu heat input (LHV) on an annual average for normal operation.
- These limits are equivalent to nominal NO_x emission rates of 15, 12, and 9 ppmv respectively at 15% O₂.
- d. The turbines shall be maintained and operated with good combustion practice to control emissions of CO and PM.
- 3a. The fuel heaters shall be equipped with low-NO_x burners designed to emit no more than 0.1 lb NO_x/million Btu heat input on an hourly average.
- b. The fuel heaters shall be maintained and operated with good combustion practice to control emissions of CO and PM.
- 4a. The gas turbines shall be operated in a manner consistent with good air pollution control practice to minimize emissions of NO_x during startup/low load operation, malfunction, and shutdown including the following:

- i. Operation in accordance with the manufactures written instructions or other written instructions developed by the Permittee; and
 - ii. Review of operating parameters of a gas turbine during startup, malfunction, and breakdown, or shutdown as necessary to make adjustments to reduce or eliminate excess emissions.
- b.
 - i. Upon malfunction of a combustion turbine(CT) that will result in NO_x emissions in excess of the limit in condition 2(c)(i)(0.060 lb/mmBtu, 1-hour average), the Permittee shall as soon as practicable cease excess emissions by repairing the affected CT or removing it from service.
 - ii. This requirement shall not apply to burner trips if the Permittee has maintained and operated a CT so that burner trips are not caused by poor maintenance or careless operation and in general are not reasonably preventable. (Burner trips are malfunction involving automatic switches of CT burners to diffusion mode from lean pre-mix operation, with accompanying drop in turbine output.)
 - c. For the purpose of these conditions, startup/low load operation means turbines operating below 70% load with the burners in diffusion mode (rather than lean pre-mix operation).

Conditions 2, 3, and 4 represent the application of the Best Available Control Technology as required by Section 165 of the Clean Air Act.

- 5a. The gas turbines are subject to the New Source Performance Standard (NSPS) for Stationary Gas Turbines, 40 CFR 60, Subpart A and GG. The Illinois EPA is administrating NSPS in Illinois on behalf of the United States EPA under a delegation agreement.
 - b. The NO_x emissions from each gas turbine shall not exceed the limit established by the NSPS, pursuant to 40 CFR 60.332 (a)(1).
 - c. The emission from each gas turbine shall not contain SO₂ in excess of 0.015 percent by volume at 15 % O₂ and on a dry basis or the gas turbine shall not burn any fuel which contains sulfur in excess of 0.8 percent by weight, pursuant to 40 CFR 60.333 (a) and (b).
 - d. At all times, the Permittee shall maintain and operate the gas turbines in a manner consistent with good air pollution control practice for minimizing emissions, pursuant to the NSPS, 40 CFR 60.11(d).
- 6. The emission of smoke or other particulate matter from a gas turbine or fuel heater shall not have an opacity greater than 30 percent, pursuant to 35 IAC 212.123(a), except as allowed by 35 IAC 201.149, 212.123(b) or 212.124.

7. The only fuels fired in the turbines shall be natural gas, as defined in 40 CFR 60.41c.
- 8a. Emissions from the turbines shall not exceed the limits in Table 1.
 - b. Emissions of NO_x from the fuel heaters, in total, shall not exceed 2.5 lb/hr and 4.0 tons/yr.
 - c. Emissions of NO_x from the fire-water pump engine, shall not exceed 6.6 lb/hr and 1.7 tons/yr.
- 9a. Under this permit, each gas turbine may be operated for a period of up to 180 days from initial startup to allow for equipment shakedown and emissions testing as required. This period may be extended by the Illinois EPA upon request of the Permittee if additional time is needed to complete startup or perform emission testing.
 - b. Upon successful completion of emission testing demonstrating compliance with applicable limitations, the Permittee may continue to operate the facility as allowed by Section 39.5 (5) of the Environmental Protection Act.
 - c. This condition supercedes Standard Condition 6.
- 10a. Within 60 days after operating a gas turbine at the greatest load at which it will normally be operated but not later than 180 days after its initial startup, the Permittee shall perform emissions tests of gas turbines as follows. These tests shall be used as the initial compliance tests to demonstrate compliance with the limits and conditions set in this permit. Emissions shall be measured by an approved testing service during conditions which are representative of maximum emissions (peak load) for NO_x, CO, PM, VOM, and opacity and also at the minimum normal operating load, and two intermediate load levels for NO_x and CO.
 - b. The following USEPA methods and procedures shall be used for testing of emissions, unless another USEPA method is approved or specified by the Illinois EPA. For each turbine, measurement of NO_x and SO₂ emissions shall be conducted and data collected in accordance with the test methods and procedures specified in 40 CFR 60.335.

Location of Sample Points	USEPA Method 1
Gas Flow and Velocity	USEPA Method 2
Flue Gas Weight	USEPA Method 3 or 3A
Moisture	USEPA Method 4
Particulate Matter	USEPA Method 5
Nitrogen Oxides	USEPA Method 20
Opacity	USEPA Method 9

Carbon Monoxide	USEPA Method 10
Volatile Organic Material	USEPA Method 18
PM ₁₀	USEPA Method 201 or 201A (40 CFR 51, Appendix M)

The Permittee may report all PM emissions measured by USEPA Method 5 as PM₁₀, including back half condensable particulate. If the Permittee reports USEPA Method 5 PM emissions as PM₁₀, testing using USEPA method 201 or 201A need not be preformed.

- c. At least 60 days prior to the actual date of testing, a written test plan shall be submitted to the Illinois EPA for review. This plan shall describe the specific procedures for testing and shall include as a minimum:
 - i. The person(s) who will be performing sampling and analysis and their experience with similar tests.
 - ii. The specific conditions under which testing shall be performed including a discussion of why these conditions will be representative of maximum emissions and the means by which the operating parameters for the gas turbine will be tracked and recorded.
 - iii. The specific determinations of emissions that are intended to be made, including sampling and monitoring locations. As part of this plan, the Permittee may set forth a strategy for performing emission testing of selected turbines provided that all turbines are fitted for testing; the identity of the engines to be tested is determined immediately before testing, by the Illinois EPA or otherwise randomly; and continuous emission monitoring of NO_x is present on all turbines. The Permittee may also propose a plan for testing across the normal operating range of the turbines.
 - iv. The test method(s), which will be used, with the specific analysis method, if the method can be used with different analysis methods.
- d. The Illinois EPA shall be notified prior to these tests to enable the Illinois EPA to observe these tests. Notification of the expected date of testing shall be submitted a minimum of 30 days prior to the expected date. Notification of the actual date and expected time of testing shall be submitted a minimum of 5 working days prior to the actual date of the test. The Illinois EPA may at its discretion accept notifications with shorter advance notice provided that the Illinois EPA will not accept such notifications if it interferes with the Illinois EPA's ability to observe testing.

- e. Three copies of the Final Reports for these tests shall be forwarded to the Compliance Section in Springfield within 30 days after the test results are compiled and finalized, in advance of the operating permit application if necessary. The Final Report from testing shall contain a minimum:
 - i. A summary of results;
 - ii. General information;
 - iii. Description of test method(s), including a description of sampling points, sampling train, analysis equipment, and test schedule;
 - iv. Detailed description of test conditions, including:
 - A. Fuel consumption (standard ft³);
 - B. Firing rate (million Btu/hr) based on lower heating value (LHV);
 - C. Turbine/Generator output rate (MW); and
 - D. Turbine burner settings, e.g., burner excess air and pressure settings.
 - v. Data and calculations, including copies of all raw data sheets and records of laboratory analysis, sample calculations, and data on equipment calibration.
- f. Submittals and notification with respect to emissions testing shall be made to the following:

Illinois Environmental Protection Agency
Division of Air Pollution Control - Regional Office
Eisenhower Tower
1701 First Avenue
Maywood, Illinois 60153
Telephone: 708/338-7900 Fax: 708/338-7930

Illinois Environmental Protection Agency
Emission Monitoring and Testing Unit
P. O. Box 19276
Springfield, Illinois 62794-9276

Illinois Environmental Protection Agency
Division of Air Pollution Control, Compliance Section (#40)
P. O. Box 19276
Springfield, Illinois 62794-9276
Telephone: 217/782-5811 Fax: 217/782-6348

- 11a. The Permittee shall install, operate, and maintain a Continuous Emissions Monitoring (CEM) system to measure emissions of NO_x from each gas turbine in accordance with the Federal Acid Rain Program which CEMs shall also be used to demonstrate compliance with the limitations of this permit.
 - b.
 - i. The procedures under 40 CFR 60.13 and 75.12 and 40 CFR 75, Appendix F shall be followed for the installation, evaluation, and operation these CEM systems.
 - ii. At least 30 days prior to initial startup of a gas turbine, the Permittee shall submit to the Illinois EPA for review and comments a detailed plan describing the configuration and operation of the NO_x CEM system(s). The plan shall also state whether the Permittee is installing a SO₂ CEM system (40 CFR 75.11) rather than sulfur analysis and fuel flow monitoring equipment in accordance with 40 CFR 75.11(e).
 - c. These CEMs shall be operational and collecting data in accordance with the provisions of the Acid Rain Program.
- 12a. The Permittee shall sample and analyze for sulfur content of the fuels being fired in the gas turbines in accordance with 40 CFR 60.334(b) unless the Permittee has a custom schedule approved by the Illinois EPA, for the determination of these values based on the design and operation of the source and the characteristics of the fuel supply, this sampling and analysis shall occur on a monthly basis for natural gas.
 - b. The Permittee shall also sample and analyze for the sulfur content of the fuel for the turbines in accordance with the Federal Acid Rain Program 40 CFR 75.11(e), unless it elects to install and operate CEMs for emission of SO₂ from the turbines.
13. The Permittee shall install, operate, and maintain monitors on each gas turbine to measure and record fuel consumption and maintain records.
- 14a. The Permittee shall maintain a file of the following items:
 - i. The heat content (LHV) of the fuel fired in the turbines (Btu/standard ft³); and
 - ii. The sulfur content of the fuel for the turbines in accordance with condition 12.
- b. The Permittee shall maintain the following daily records:
 - i. The quantity of natural gas consumed for each gas turbine (standard ft³);

- ii. Operating hours for each turbine; and
 - iii. Identification of each hour when a turbine is operated at less than 70% load or the ambient temperature is less than 45°F, other than during start up, malfunction, or shutdown as addressed below in Condition 14 (d).
- c. i. The Permittee shall keep inspection, maintenance, and repair logs with dates and nature of such activities for the following as may be related to emissions and emission control:
- A. Each turbine, including the burner system;
 - B. Each fuel heater; and
 - C. Fire water pump engine.
- ii. The logs for each turbine shall include data on burner settings and any detailed information on inspection of the burner system including values of parameters related to burner performance measured during such inspections.
- d. The Permittee shall maintain following records related to startup, malfunction and breakdown, and shutdown of each gas turbine:
- i. The time and date of startup, malfunction or breakdown and shutdown of a gas turbine, and confirmation that standard practices were followed; and
 - ii. Each incident when operation of a turbine continued during malfunction or breakdown with excess emissions, including the following information:
 - A. Date and duration of malfunction or breakdown;
 - B. A description of the malfunction or breakdown;
 - C. The reason continued operation was necessary, including supporting documentation; and
 - D. The corrective actions used to reduce the quantity of emissions and the duration of the incident.
- e. The Permittee shall keep the following records with regards to emissions:
- i. NO_x emissions from each gas turbine recorded hourly, monthly, and annual (in lb/mmBtu (LHV) and lb or ton) by combining the NO_x

concentration (in ppm) and diluent concentration (in percent O₂ or CO₂) measurements determined in accordance with condition 11;

- ii. Monthly emissions of CO, SO₂ and PM from the turbines (tons/month). Emissions of SO₂ shall be determined in accordance with condition 12. Emissions of CO and PM shall be calculated from fuel consumption data and factors developed from emission testing;
 - iii. Monthly emissions of NO_x, CO, SO₂, VOM, and PM from the fuel heater and fire-water pump engine(ton/month). Emissions shall be calculated based on fuel consumption data and/or applicable emission factors; and
 - iv. Annual plant emissions of CO, SO₂, and PM, based on monthly emission totals.
15. All records required by this permit shall be retained on site for a period of at least three years and shall be made available for inspection and copying by the Illinois EPA upon request.
- 16a. i. For each gas turbine, the Permittee shall fulfill applicable notification requirements of the NSPS, 40 CFR 60.7(a), including notifications for date of commencement of construction, and actual date of initial startup.
- ii. With the notification of commencement of construction, the Permittee shall describe the actions that were and will be taken that constitute commencement of construction.
- b. The Permittee shall submit semi-annual progress reports to the Illinois EPA while construction is underway, which the reports shall describe for each turbine for which construction has been commenced, the accomplishments in the previous six months and the schedule of activities for the next six months.
- c. The Permittee shall promptly notify the Illinois EPA if construction of a particular gas turbine, once commenced, is discontinued or interrupted for a period of 18 months.
- 17a. If there is an exceedance of the requirements of Condition 2 through 8 of this permit, the Permittee shall submit a report to the Illinois EPA's Compliance Section in Springfield, Illinois within 30 days after the exceedance. The report shall include a description of the exceedance, a copy of relevant records, and a description of the exceedance or violation and efforts to reduce emissions and future occurrences.

- b. In conjunction with the Annual Emission Report required by 35 IAC Part 254, the Permittee shall provide:

The hours of operation for each simple cycle gas turbine.

- c. The Permittee shall comply with applicable reporting requirements under the Acid Rain Program, with a single copy of such report sent to Illinois EPA, Division of Air Pollution Control, Compliance Section.
- 18a. Any required reports and notifications concerning equipment operation, emissions testing, or a monitoring system shall be sent to the Illinois EPA at the following address unless otherwise indicated:

Illinois Environmental Protection Agency
Division of Air Pollution Control, Compliance Section (#40)
P.O. Box 19276
Springfield, Illinois 62794-9276
Telephone: 217/782-5811 Fax: 217/782-6348

- b. A copy of all reports and notifications, as required above, except the Annual Emission Report required by 35 Ill. Adm. Code 254, shall also be sent to the Illinois EPA at the following address:

Illinois Environmental Protection Agency
Division of Air Pollution Control
1701 First Street
Maywood, Illinois 60153
Telephone: 708/338-7900 Fax: 708/338-7930

- 19a. Pursuant to 40 CFR 52.21(r)(2), this permit shall become invalid if construction is not commenced within 18 months after this permit becomes effective, if construction is discontinued for a period of 18 months or more, or if construction is not completed within a reasonable period of time. The 18 month period may be extended by the Illinois EPA upon a satisfactory showing that an extension is justified. This condition supersedes Standard Condition 1.
- b. This permit shall become invalid as applied to a particular turbine unit if construction of such unit does not commence within 18 months after this permit becomes effective, if construction is discontinued for a period of 18 months or more, or if construction of the combustion turbine is not completed within a reasonable period of time. The 18 month period may be extended by the Illinois EPA upon a satisfactory showing from the Permittee that an extension is justified.
 - c. For purposes of the above provisions, the definitions of "construction" and "commence" at 40 CFR 52.21 (b)(8) and (9) shall apply, which require that a source must enter into a binding agreement for on-site

construction or begin actual on-site construction. (Also see the definition of "begin actual construction," 40 CFR 52.21 (b)(11))

20. This Permit for the above referenced project does not relieve the Permittee of the responsibility to comply with all Local, State and Federal Regulations which are part of the applicable Illinois State Implementation Plan, as well as all other applicable Federal, State, and Local requirements.

If you have any questions concerning this, please contact Manish Patel at 217/782-2113.

Donald E. Sutton, P.E.
Manager, Permit Section
Division of Air Pollution Control

DES:MNP:jar

cc: Region 1
USEPA
CASM, Illinois EPA

Attachment A

Emission Units

Unit			Rated Heat	Rated	
<u>I.D.</u>	<u>Description</u>	<u>Number</u>	Input ¹	Electrical	<u>Control</u>
SCCT	Simple Cycle Gas		(mmBtu/Hr)	Output ¹	
1 - 8	Turbine	8	1000.5	83	Low NO _x Combustors
	Fuel Heaters	2	12.0	--	Low NO _x Burners
	Backup Diesel				
	Fire Pump Engine	1	--	--	None

¹ Nominal ratings are based on lower heating value and are per unit.

Attachment B

Project Emissions (Ton/Yr)

<u>Pollutant</u>	<u>Potential Emissions</u>
CO	714.2
NO _x	432.1
PM/PM ₁₀	164.2
SO ₂	72.3
VOM	26.1

Table 1

Emission Limits for Turbines

<u>Pollutant</u>	<u>(Lb/mmBtu¹ (LHV))</u>	<u>(Lb/Hr²)</u>	<u>(Ton/Mo³)</u>	<u>(Ton/Yr³)</u>
NO _x	0.060	60.0	142.9	426.4
CO	0.054	53.7	265.5	710.1
PM/PM ₁₀	0.0139	14.0	41.7	163.5
VOM	0.00198	1.9	16.4	24.4
SO ₂	0.00619	6.2	18.5	71.9

¹ Heat input based emission limits are per unit and reflects vendor/manufacture data and information provided in the permit application. Notwithstanding the above limits, if ambient temperature is 45°F or less, CO and VOM emission shall not exceed 0.089 and 0.00549 lb/mmBtu (LHV), respectively. These heat input based limits do not apply during startup/low load operation, malfunction or shutdown as addressed by Condition 4. If the applicable limits of CO and PM are not met by a turbine, it shall also be presumed to constitute failure to use good combustion practice as required by Condition 2(d), as well as an exceedance of Condition 8(a).

² Hourly emission limits based on modeling data and information provided in the permit application. Operating the turbines in warmer weather results in lower generator output with accompanying lower emissions. Notwithstanding the above, if ambient temperature is 45°F or less, CO and VOM emission shall not exceed 89.2 and 5.5 lb/hour, respectively, and for periods other than normal operation, emissions of NO_x shall not exceed 80.0 lb/hour. If the applicable limits of CO and PM are not met by a turbine, it shall also be presumed to constitute failure to use good combustion practice as required by Condition 2(d), as well as an exceedance of Condition 8(a).

³ Monthly and annual limits apply to the total of all turbines. The annual limits reflect 26,400 total turbine operating hours considering 3,300 hours of operation for each turbine.

Table 2

Project Emissions (Ton/Yr)

<u>Unit</u>	<u>NO_x</u>	<u>CO</u>	<u>PM</u>	<u>VOM</u>	<u>SO₂</u>
Turbines	426.4	710.1	163.5	24.4	71.9
Gas Fired Heaters	4.0	3.6	0.4	1.5	0.2
Backup Diesel Fire Pump Engine	1.7	0.5	0.3	0.1	0.3
Fugitive VOM				0.1	
Totals:	432.1	714.2	164.2	26.1	72.3