

Attention:

ExxonMobil Lockport Terminal  
Attn: James R. Hesser  
12909 High Road  
Lockport, Illinois 60441

State of Illinois

CLEAN AIR ACT PERMIT  
PROGRAM (CAAPP) PERMIT

Source:


ExxonMobil Lockport Terminal  
12909 High Road  
Lockport, Illinois 60441

I.D. No.: 197810AAL  
Permit No.: 95090243

Permitting Authority:

Illinois Environmental Protection Agency  
Bureau of Air, Permit Section  
217/785-1705





# ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

1021 NORTH GRAND AVENUE EAST, P.O. BOX 19506, SPRINGFIELD, ILLINOIS 62794-9506 - (217) 782-2113

PAT QUINN, GOVERNOR

LISA BONNETT, DIRECTOR

## CLEAN AIR ACT PERMIT PROGRAM (CAAPP) PERMIT

Type of Application: Renewal  
Purpose of Application: Renew Existing CAAPP Permit for 5 Years

ID No.: 197810AAL  
Permit No.: 95090243  
Statement of Basis No.: 95090243-1403

Date Application Received: February 06, 2007  
Date Issued: October 24, 2014

Expiration Date: October 24, 2019  
Renewal Submittal Date: 9 Months Prior to Expiration Date

Source Name: ExxonMobil Lockport Terminal  
Address: 12909 High Road  
City: Lockport  
County: Will  
ZIP Code: 60441

This permit is hereby granted to the above-designated source authorizing operation in accordance with this CAAPP permit, pursuant to the above referenced application. This source is subject to the conditions contained herein. For further information on the source see Section 1 and for further discussion on the effectiveness of this permit see Condition 2.3(g).

If you have any questions concerning this permit, please contact Rosario Johnstone at 217/785-1705.

Raymond E. Pilapil  
Acting Manager, Permit Section  
Division of Air Pollution Control

REP:MTR:RJ:jws

cc: IEPA, Permit Section  
IEPA, FOS, Region 1  
Lotus Notes Database



<u>Section</u>	<b>Table of Contents</b>	<u>Page</u>
<b>1</b>	<b>Source Information</b>	<b>3</b>
	1.1 Addresses	
	1.2 Contacts	
	1.3 Single Source	
<b>2</b>	<b>General Permit Requirements</b>	<b>4</b>
	2.1 Prohibitions	
	2.2 Emergency Provisions	
	2.3 General Provisions	
	2.4 Testing	
	2.5 Recordkeeping	
	2.6 Certification	
	2.7 Permit Shield	
	2.8 Title I Conditions	
	2.9 Reopening and Revising Permit	
	2.10 Emissions Trading Programs	
	2.11 Permit Renewal	
	2.12 Permanent Shutdown	
	2.13 Startup, Shutdown, and Malfunction	
<b>3</b>	<b>Source Requirements</b>	<b>12</b>
	3.1 Applicable Requirements	
	3.2 Applicable Plans and Programs	
	3.3 Title I Requirements	
	3.4 Synthetic Minor Limits	
	3.5 Reporting Requirements	
<b>4</b>	<b>Emission Unit Requirements</b>	<b>18</b>
	4.1 Existing Internal Floating Roof Storage Tanks for Volatile Petroleum Liquids (Non NSPS Tanks)	
	4.2 Existing Internal Floating Roof Storage Tanks in Non-Gasoline Service	
	4.3 Internal Floating Roof Storage Tanks (NSPS Tanks) in Non Gasoline Service	
	4.4 Truck Loading Rack	
<b>5</b>	<b>Additional Title I Requirements</b>	<b>42</b>
	5.1 Construction Permits	
<b>6</b>	<b>Insignificant Activities Requirements</b>	<b>43</b>
	6.1 Insignificant Activities Subject to Specific Regulations	
	6.2 Insignificant Activities in 35 IAC 201.210(a)	
	6.3 Insignificant Activities in 35 IAC 201.210(b)	
	6.4 Applicable Requirements	
	6.5 Compliance Method	
	6.6 Notification Requirements for Insignificant Activities	
<b>7</b>	<b>Other Requirements</b>	<b>46</b>
	7.1 Testing	
	7.2 Emissions Reduction Market System (ERMS) Requirements	
	7.3 40 CFR 63 Subpart A Requirements (NESHAP)	
	7.4 Compliance Assurance Monitoring (CAM) Requirements	
<b>8</b>	<b>State Only Requirements</b>	<b>64</b>
	8.1 Permitted Emissions for Fees	
<b>Attachment 1</b>	<b>List of Emission Units at This Source</b>	<b>65</b>
<b>Attachment 2</b>	<b>Acronyms and Abbreviations</b>	<b>66</b>
<b>Attachment 3</b>	<b>Contact and Reporting Addresses</b>	<b>68</b>
<b>Attachment 4</b>	<b>Example Certification by a Responsible Official</b>	<b>69</b>

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

## Section 1 - Source Information

## 1. Addresses

<u>Source</u>	<u>Owner</u>
ExxonMobil Lockport Terminal 12909 High Road Lockport, Illinois 60441	ExxonMobil Lockport Terminal 3225 Gallows Road Lockport, Illinois 60441
<u>Operator</u>	<u>Permittee</u>
ExxonMobil Lockport Terminal 12909 High Road Lockport, Illinois 60441	The Owner and Operator of the source as identified in this table.

## 2. Contacts

Certified Officials

The source shall submit an Administrative Permit Amendment for any change in the Certified Officials, pursuant to Section 39.5(13) of the Act.

	<i>Name</i>	<i>Title</i>
<i>Responsible Official</i>	Darren W. Woods	Vice President ExxonMobil Oil Corporation
<i>Delegated Authority</i>	Charles S. Fennel	Area Manager-US East

Other Contacts

	<i>Name</i>	<i>Phone No.</i>	<i>Email</i>
<i>Source Contact</i>	James R. Hesser	630 243-2371	jim.r.hesser@exxonmobil.com
<i>Technical Contact</i>	Christina C. Stamatakis	832 624-4235	christina.c.stamatakis@exxonmobil.com
<i>Correspondence</i>	James R. Hesser	630 243-2371	jim.r.hesser@exxonmobil.com
<i>Billing</i>	James R. Hesser	630 243-2371	jim.r.hesser@exxonmobil.com

## 3. Single Source

The source identified in Condition 1.1 above shall be defined to include all the following additional source(s):

<i>I.D. No.</i>	<i>Permit No.</i>	<i>Single Source Name and Address</i>
N/A	N/A	N/A

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

## Section 2 - General Permit Requirements

### 1. Prohibitions

- a. It shall be unlawful for any person to violate any terms or conditions of this permit issued under Section 39.5 of the Act, to operate the CAAPP source except in compliance with this permit issued by the IEPA under Section 39.5 of the Act or to violate any other applicable requirements. All terms and conditions of this permit issued under Section 39.5 of the Act are enforceable by USEPA and citizens under the Clean Air Act, except those, if any, that are specifically designated as not being federally enforceable in this permit pursuant to Section 39.5(7)(m) of the Act. [Section 39.5(6)(a) of the Act]
- b. After the applicable CAAPP permit or renewal application submittal date, as specified in Section 39.5(5) of the Act, the source shall not operate this CAAPP source without a CAAPP permit unless the complete CAAPP permit or renewal application for such source has been timely submitted to the IEPA. [Section 39.5(6)(b) of the Act]
- c. No Owner or Operator of the CAAPP source shall cause or threaten or allow the continued operation of an emission source during malfunction or breakdown of the emission source or related air pollution control equipment if such operation would cause a violation of the standards or limitations applicable to the source, unless this CAAPP permit granted to the source provides for such operation consistent with the Act and applicable Illinois Pollution Control Board regulations. [Section 39.5(6)(c) of the Act]
- d. Pursuant to Section 39.5(7)(g) of the Act, emissions from the source are not allowed to exceed any allowances that the source lawfully holds under Title IV of the Clean Air Act or the regulations promulgated thereunder, consistent with Section 39.5(17) of the Act and applicable requirements, if any.

### 2. Emergency Provisions

Pursuant to Section 39.5(7)(k) of the Act, the Owner or Operator of the CAAPP source may provide an affirmative defense of emergency to an action brought for noncompliance with technology-based emission limitations under this CAAPP permit if the following conditions are met through properly signed, contemporaneous operating logs, or other relevant evidence:

- a.
  - i. An emergency occurred and the source can identify the cause(s) of the emergency.
  - ii. The source was at the time being properly operated.
  - iii. The source submitted notice of the emergency to the IEPA within 2 working days of the time when emission limitations were exceeded due to the emergency. This notice must contain a detailed description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.
  - iv. During the period of the emergency the source took all reasonable steps to minimize levels of emissions that exceeded the emission limitations, standards, or requirements in this permit.
- b. For purposes of Section 39.5(7)(k) of the Act, "emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, such as an act of God, that requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under this permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventive maintenance, careless or improper operation, or operation error.
- c. In any enforcement proceeding, the source seeking to establish the occurrence of an emergency has the burden of proof. This provision is in addition to any emergency or

ExxonMobil Lockport Terminal  
 I.D. No.: 197810AAL  
 Permit No.: 95090243

Date Received: 02/06/2007  
 Date Issued: 10/24/2014

upset provision contained in any applicable requirement. This provision does not relieve the source of any reporting obligations under existing federal or state laws or regulations.

### **3. General Provisions**

#### **a. Duty to Comply**

The source must comply with all terms and conditions of this permit. Any permit noncompliance constitutes a violation of the CAA and the Act, and is grounds for any or all of the following: enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. [Section 39.5(7)(o)(i) of the Act]

#### **b. Need to Halt or Reduce Activity is not a Defense**

It shall not be a defense for the source in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. [Section 39.5(7)(o)(ii) of the Act]

#### **c. Duty to Maintain Equipment**

The source shall maintain all equipment covered under this permit in such a manner that the performance or operation of such equipment shall not cause a violation of applicable requirements. [Section 39.5(7)(a) of the Act]

#### **d. Disposal Operations**

The source shall be operated in such a manner that the disposal of air contaminants collected by the equipment operations, or activities shall not cause a violation of the Act or regulations promulgated there under. [Section 39.5(7)(a) of the Act]

#### **e. Duty to Pay Fees**

- i. The source must pay fees to the IEPA consistent with the fee schedule approved pursuant to Section 39.5(18) of the Act, and submit any information relevant thereto. [Section 39.5(7)(o)(vi) of the Act]
- ii. The IEPA shall assess annual fees based on the allowable emissions of all regulated air pollutants, except for those regulated air pollutants excluded in Section 39.5(18)(f) of the Act and insignificant activities in Section 6, at the source during the term of this permit. The amount of such fee shall be based on the information supplied by the applicant in its complete CAAPP permit application. [Section 39.5(18)(a)(ii)(A) of the Act]
- iii. The check should be payable to "Treasurer, State of Illinois" and sent to: Fiscal Services Section, Illinois EPA, P.O. Box 19276, Springfield, IL, 62794-9276. Include on the check: ID #, Permit #, and "CAAPP Operating Permit Fees". [Section 39.5(18)(e) of the Act]

#### **f. Obligation to Allow IEPA Surveillance**

Pursuant to Sections 4(a), 39.5(7)(a), and 39.5(7)(p)(ii) of the Act, inspection and entry requirements that necessitate that, upon presentation of credentials and other documents as may be required by law and in accordance with constitutional limitations, the source shall allow the IEPA, or an authorized representative to perform the following:

- i. Enter upon the source's premises where the emission unit(s) are located or emissions-related activity is conducted, or where records must be kept under the conditions of this permit.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

- ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit.
- iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
- iv. Sample or monitor any substances or parameters at any location at reasonable times:
  - A. As authorized by the Clean Air Act or the Act, at reasonable times, for the purposes of assuring compliance with this CAAPP permit or applicable requirements; or
  - B. As otherwise authorized by the Act.
- v. Enter and utilize any photographic, recording, testing, monitoring, or other equipment for the purposes of preserving, testing, monitoring, or recording any activity, discharge or emission at the source authorized by this permit.

**g. Effect of Permit**

- i. Pursuant to Section 39.5(7)(j)(iv) of the Act, nothing in this CAAPP permit shall alter or affect the following:
  - A. The provisions of Section 303 (emergency powers) of the CAA, including USEPA's authority under that Section.
  - B. The liability of the Owner or Operator of the source for any violation of applicable requirements prior to or at the time of permit issuance.
  - C. The applicable requirements of the acid rain program consistent with Section 408(a) of the Clean Air Act.
  - D. The ability of USEPA to obtain information from the source pursuant to Section 114 (inspections, monitoring, and entry) of the Clean Air Act.
- ii. Notwithstanding the conditions of this permit specifying compliance practices for applicable requirements, pursuant to Sections 39.5(7)(j) and (p) of the Act, any person (including the Permittee) may also use other credible evidence to establish compliance or noncompliance with applicable requirements. [35 IAC 201.122 and Section 39.5(7)(a) of the Act]

**h. Severability Clause**

The provisions of this permit are severable. In the event of a challenge to any portion of this permit, other portions of this permit may continue to be in effect. Should any portion of this permit be determined to be illegal or unenforceable, the validity of the other provisions shall not be affected and the rights and obligations of the source shall be construed and enforced as if this permit did not contain the particular provisions held to be invalid and the applicable requirements underlying these provisions shall remain in force. [Section 39.5(7)(i) of the Act]

**4. Testing**

- a. Tests conducted to measure composition of materials, efficiency of pollution control devices, emissions from process or control equipment, or other parameters shall be conducted using standard test methods if applicable test methods are not specified by the applicable regulations or otherwise identified in the conditions of this permit. Documentation of the test date, conditions, methodologies, calculations, and test results shall be retained pursuant to the recordkeeping procedures of this permit. Reports of

ExxonMobil Lockport Terminal  
 I.D. No.: 197810AAL  
 Permit No.: 95090243

Date Received: 02/06/2007  
 Date Issued: 10/24/2014

any tests conducted as required by this permit or as the result of a request by the IEPA shall be submitted as specified in Condition 7.1 of this permit. [35 IAC Part 201 Subpart J and Section 39.5(7)(a) of the Act]

- b. Pursuant to Section 4(b) of the Act and 35 IAC 201.282, every emission source or air pollution control equipment shall be subject to the following testing requirements for the purpose of determining the nature and quantities of specified air contaminant emissions and for the purpose of determining ground level and ambient air concentrations of such air contaminants:
- i. **Testing by Owner or Operator:** The IEPA may require the Owner or Operator of the emission source or air pollution control equipment to conduct such tests in accordance with procedures adopted by the IEPA, at such reasonable times as may be specified by the IEPA and at the expense of the Owner or Operator of the emission source or air pollution control equipment. All such tests shall be made by or under the direction of a person qualified by training and/or experience in the field of air pollution testing. The IEPA shall have the right to observe all aspects of such tests.
  - ii. **Testing by the IEPA:** The IEPA shall have the right to conduct such tests at any time at its own expense. Upon request of the IEPA, the Owner or Operator of the emission source or air pollution control equipment shall provide, without charge to the IEPA, necessary holes in stacks or ducts and other safe and proper testing facilities, including scaffolding, but excluding instruments and sensing devices, as may be necessary.

## **5. Recordkeeping**

### **a. Control Equipment Maintenance Records**

Pursuant to Section 39.5(7)(b) of the Act, a maintenance record shall be kept on the premises for each item of air pollution control equipment. At a minimum, this record shall show the dates maintenance was performed and the nature of preventative maintenance activities.

### **b. Retention of Records**

- i. Records of all monitoring data and support information shall be retained for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records, original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. [Section 39.5(7)(e)(ii) of the Act]
- ii. Pursuant to Section 39.5(7)(a) of the Act, other records required by this permit including any logs, plans, procedures, or instructions required to be kept by this permit shall be retained for a period of at least 5 years from the date of entry unless a different period is specified by a particular permit provision.

### **c. Availability of Records**

- i. Pursuant to Section 39.5(7)(a) of the Act, the Permittee shall retrieve and provide paper copies, or as electronic media, any records retained in an electronic format (e.g., computer) in response to an IEPA or USEPA request during the course of a source inspection.
- ii. Pursuant to Section 39.5(7)(a) of the Act, upon written request by the IEPA for copies of records or reports required to be kept by this permit, the Permittee shall promptly submit a copy of such material to the IEPA. For this purpose, material shall be submitted to the IEPA within 30 days unless additional time is provided by the IEPA or the Permittee believes that the volume and nature of

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

requested material would make this overly burdensome, in which case, the Permittee shall respond within 30 days with the explanation and a schedule for submittal of the requested material. (See also Condition 2.9(d))

## 6. Certification

### a. Compliance Certification

- i. Pursuant to Section 39.5(7)(p)(v)(C) of the Act, the source shall submit annual compliance certifications by May 1 unless a different date is specified by an applicable requirement or by a particular permit condition. The annual compliance certifications shall include the following:
  - A. The identification of each term or condition of this permit that is the basis of the certification.
  - B. The compliance status.
  - C. Whether compliance was continuous or intermittent.
  - D. The method(s) used for determining the compliance status of the source, both currently and over the reporting period consistent with the conditions of this permit.
- ii. Pursuant to Section 39.5(7)(p)(v)(D) of the Act, all compliance certifications shall be submitted to USEPA Region 5 in Chicago as well as to the IEPA Compliance Section. Addresses are included in Attachment 3.
- iii. Pursuant to Section 39.5(7)(p)(i) of the Act, all compliance reports required to be submitted shall include a certification in accordance with Condition 2.6(b).

### b. Certification by a Responsible Official

Any document (including reports) required to be submitted by this permit shall contain a certification by the responsible official of the source that meets the requirements of Section 39.5(5) of the Act and applicable regulations. [Section 39.5(7)(p)(i) of the Act]. An example Certification by a Responsible Official is included in Attachment 4 of this permit.

## 7. Permit Shield

- a. Pursuant to Section 39.5(7)(j) of the Act, except as provided in Condition 2.7(b) below, the source has requested and has been granted a permit shield. This permit shield provides that compliance with the conditions of this permit shall be deemed compliance with applicable requirements which were applicable as of the date the proposed permit for this source was issued, provided that either the applicable requirements are specifically identified within this permit, or the IEPA, in acting on this permit application, has determined that other requirements specifically identified are not applicable to this source and this determination (or a concise summary thereof) is included in this permit. This permit shield does not extend to applicable requirements which are promulgated after 09/04/2014 (date USEPA notice started), unless this permit has been modified to reflect such new requirements.
- b. Pursuant to Section 39.5(7)(j) of the Act, this permit and the terms and conditions herein do not affect the Permittee's past and/or continuing obligation with respect to statutory or regulatory requirements governing major source construction or modification under Title I of the CAA. Further, neither the issuance of this permit nor any of the terms or conditions of the permit shall alter or affect the liability of the Permittee for any violation of applicable requirements prior to or at the time of permit issuance.

ExxonMobil Lockport Terminal  
 I.D. No.: 197810AAL  
 Permit No.: 95090243

Date Received: 02/06/2007  
 Date Issued: 10/24/2014

- c. Pursuant to Section 39.5(7)(a) of the Act, the issuance of this permit by the IEPA does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any currently pending or future legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the IEPA or the USEPA may have against the applicant including, but not limited to, any enforcement action authorized pursuant to the provision of applicable federal and state law.

#### 8. Title I Conditions

Pursuant to Sections 39(a), 39(f), and 39.5(7)(a) of the Act, as generally identified below, this CAAPP permit may contain certain conditions that relate to requirements arising from the construction or modification of emission units at this source. These requirements derive from permitting programs authorized under Title I of the Clean Air Act (CAA) and regulations thereunder, and Title X of the Illinois Environmental Protection Act (Act) and regulations implementing the same. Such requirements, including the New Source Review programs for both major (i.e., PSD and nonattainment areas) and minor sources, are implemented by the IEPA.

- a. This permit may contain conditions that reflect requirements originally established in construction permits previously issued for this source. These conditions include requirements from preconstruction permits issued pursuant to regulations approved or promulgated by USEPA under Title I of the CAA, as well as requirements contained within construction permits issued pursuant to state law authority under Title X of the Act. Accordingly, all such conditions are incorporated into this CAAPP permit by virtue of being either an "applicable Clean Air Act requirement" or an "applicable requirement" in accordance with Section 39.5 of the Act. These conditions are identifiable herein by a designation to their origin of authority.
- b. This permit may contain conditions that reflect necessary revisions to requirements established for this source in preconstruction permits previously issued under the authority of Title I of the CAA. These conditions are specifically designated herein as "TIR".
- i. Revisions to original Title I permit conditions are incorporated into this permit through the combined legal authority of Title I of the CAA and Title X of the Act. Public participation requirements and appeal rights shall be governed by Section 39.5 of the Act.
- ii. Revised Title I permit conditions shall remain in effect through this CAAPP permit, and are therefore enforceable under the same, so long as such conditions do not expire as a result of a failure to timely submit a complete renewal application or are not removed at the applicant's request.
- c. This permit may contain conditions that reflect new requirements for this source that would ordinarily derive from a preconstruction permit established under the authority of Title I of the CAA. These conditions are specifically designated herein as "TIN".
- i. The incorporation of new Title I requirements into this CAAPP permit is authorized through the combined legal authority of Title I of the CAA and Title X of the Act. Public participation requirements and appeal rights shall be governed by Section 39.5 of the Act.
- ii. Any Title I conditions that are newly incorporated shall remain in effect through this CAAPP permit, and are therefore enforceable under the same, so long as such conditions do not expire as a result of a failure to timely submit a complete renewal application or are not removed at the applicant's request.

ExxonMobil Lockport Terminal  
 I.D. No.: 197810AAL  
 Permit No.: 95090243

Date Received: 02/06/2007  
 Date Issued: 10/24/2014

**9. Reopening and Revising Permit****a. Permit Actions**

This permit may be modified, revoked, reopened and reissued, or terminated for cause in accordance with applicable provisions of Section 39.5 of the Act. The filing of a request by the source for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. [Section 39.5(7)(o)(iii) of the Act]

**b. Reopening and Revision**

Pursuant to Section 39.5(15)(a) of the Act, this permit must be reopened and revised if any of the following occur:

- i. Additional requirements become applicable to the equipment covered by this permit and three or more years remain before expiration of this permit;
- ii. Additional requirements become applicable to the source for acid deposition under the acid rain program;
- iii. The IEPA or USEPA determines that this permit contains a material mistake or that an inaccurate statement was made in establishing the emission standards or limitations, or other terms or conditions of this permit; or
- iv. The IEPA or USEPA determines that this permit must be revised or revoked to ensure compliance with the applicable requirements.

**c. Inaccurate Application**

Pursuant to Sections 39.5(5)(e) and (i) of the Act, the IEPA has issued this permit based upon the information submitted by the source in the permit application referenced on page 1 of this permit. Any misinformation, false statement or misrepresentation in the application shall be grounds for revocation or reopening of this CAAPP under Section 39.5(15) of the Act.

**d. Duty to Provide Information**

The source shall furnish to the IEPA, within a reasonable time specified by the IEPA any information that the IEPA may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. Upon request, the source shall also furnish to the IEPA copies of records required to be kept by this permit. [Section 39.5(7)(o)(v) of the Act]

**10. Emissions Trading Programs**

No permit revision shall be required for increases in emissions allowed under any USEPA approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for elsewhere in this permit and that are authorized by the applicable requirement. [Section 39.5(7)(o)(vii) of the Act]

**11. Permit Renewal**

- a. Upon the expiration of this permit, if the source is operated, it shall be deemed to be operating without a permit unless a timely and complete CAAPP application has been submitted for renewal of this permit. However, if a timely and complete application to renew this CAAPP permit has been submitted, the terms and all conditions of the most recent issued CAAPP permit will remain in effect until the issuance of a renewal permit. [Sections 39.5(5)(l) and (o) of the Act]

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

- b. For purposes of permit renewal, a timely application is one that is submitted no less than 9 months prior to the date of permit expiration. [Section 39.5(5)(n) of the Act]

**12. Permanent Shutdown**

Pursuant to Section 39.5(7)(a) of the Act, this permit only covers emission units and control equipment while physically present at the source location(s). Unless this permit specifically provides for equipment relocation, this permit is void for the operation or activity of any item of equipment on the date it is removed from the permitted location(s) or permanently shut down. This permit expires if all equipment is removed from the permitted location(s), notwithstanding the expiration date specified on this permit.

**13. Startup, Shutdown, and Malfunction**

Pursuant to Section 39.5(7)(a) of the Act, in the event of an action to enforce the terms or conditions of this permit, this permit does not prohibit a Permittee from invoking any affirmative defense that is provided by the applicable law or rule.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

## Section 3 - Source Requirements

**1. Applicable Requirements**

Pursuant to Sections 39.5(7)(a), 39.5(7)(b), and 39.5(7)(d) of the Act, the Permittee shall comply with the following applicable requirements. These requirements are applicable to all emission units (including insignificant activities unless specified otherwise in this Section) at the source.

**a. Fugitive Particulate Matter**

- i. Pursuant to 35 IAC 212.301 and 35 IAC 212.314, no person shall cause or allow the emission of fugitive particulate matter from any process, including any material handling or storage activity, that is visible by an observer looking generally toward the zenith at a point beyond the property line of the source unless the wind speed is greater than 25 mph.
- ii. Compliance Method (Fugitive Particulate Matter)

Upon request by the IEPA, the Permittee shall conduct observations at the property line of the source for visible emissions of fugitive particulate matter from the source to address compliance with 35 IAC 212.301. For this purpose, daily observations shall be conducted for a week for particular area(s) of concern at the source, as specified in the request, observations shall begin either within one day or three days of receipt of a written request from the IEPA, depending, respectively, upon whether observations will be conducted by employees of the Permittee or a third-party observer hired by the Permittee to conduct observations on its behalf. The Permittee shall keep records for these observations, including identity of the observer, the date and time of observations, the location(s) from which observations were made, and duration of any fugitive emissions event(s).

**b. Emissions Reduction Market System (ERMS)**

Pursuant to 35 IAC Part 205, this source is considered a "participating source" for purposes of the ERMS. The allotment of ATUs to this source is 113 ATUs per seasonal allotment period.

**c. Ozone Depleting Substances**

Pursuant to 40 CFR 82.150(b), the Permittee shall comply with the standards for recycling and emissions reduction of ozone depleting substances pursuant to 40 CFR Part 82, Subpart F, except as provided for motor vehicle air conditioners in Subpart B of 40 CFR Part 82:

- i. Pursuant to 40 CFR 82.156, persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices.
- ii. Pursuant to 40 CFR 82.158, equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment.
- iii. Pursuant to 40 CFR 82.161, persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program.
- iv. Pursuant to 40 CFR 82 Subpart B, any person performing service on a motor vehicle for consideration when this service involves the refrigerant in the motor vehicle air conditioner shall comply with 40 CFR 82 Subpart B, Servicing of Motor Vehicle Air Conditioners.

- v. Pursuant to 40 CFR 82.166, all persons shall comply with the reporting and recordkeeping requirements of 40 CFR 82.166.

**d. Asbestos Demolition and Renovation**

- i. Asbestos Fees. Pursuant to Section 9.13(a) of the Act, for any site for which the Owner or Operator must file an original 10-day notice of intent to renovate or demolish pursuant to Condition 3.1(d)(ii) below and 40 CFR 61.145(b), the owner or operator shall pay to the IEPA with the filing of each 10-day notice a fee of \$150.
- ii. Pursuant to 40 CFR 61 Subpart M, Standard of Asbestos, prior to any demolition or renovation at this facility, the Permittee shall fulfill notification requirements of 40 CFR 61.145(b).
- iii. Pursuant to 40 CFR 61.145(c), during demolition or renovation, the Permittee shall comply with the procedures for asbestos emission control established by 40 CFR 61.145(c).

**e. Future Emission Standards**

Pursuant to Section 39.5(15)(a) of the Act, this source shall comply with any new or revised applicable future standards of 40 CFR 60, 61, 62, or 63; or 35 IAC Subtitle B after the date issued of this permit. The Permittee shall, in accordance with the applicable regulation(s), comply with the applicable requirements by the date(s) specified and shall certify compliance with the applicable requirements of such regulation(s) as part of the annual compliance certification, as required by Condition 2.6(a). This permit may also have to be revised or reopened to address such new regulations in accordance to Condition 2.9.

**2. Applicable Plans and Programs**

Pursuant to Sections 39.5(7)(a), 39.5(7)(b), and 39.5(7)(d) of the Act, the Permittee shall comply with the following applicable requirements. These requirements are applicable to all emission units (including insignificant activities unless specified otherwise in this Section) at the source.

**a. Fugitive PM Operating Program**

Should this source become subject to 35 IAC 212.302, the Permittee shall prepare and operate under a Fugitive PM Operating Program consistent with 35 IAC 212.310 and submitted to the IEPA for its review. The Fugitive PM Operating Program shall be designed to significantly reduce fugitive particulate matter emissions, pursuant to 35 IAC 212.309(a). Any future Fugitive PM Operating Program made by the Permittee during the permit term is automatically incorporated by reference provided the Fugitive PM Operating Program is not expressly disapproved, in writing, by the IEPA within 30 days of receipt of the Fugitive PM Operating Program. In the event that the IEPA notifies the Permittee of a deficiency with any Fugitive PM Operating Program, the Permittee shall be required to revise and resubmit the Fugitive PM Operating Program within 30 days of receipt of notification to address the deficiency pursuant to Section 39.5(7)(a) of the Act.

**b. PM<sub>10</sub> Contingency Measure Plan**

Should this source become subject to 35 IAC 212.700, then the Permittee shall prepare and operate under a PM<sub>10</sub> Contingency Measure Plan reflecting the PM<sub>10</sub> emission reductions as set forth in 35 IAC 212.701 and 212.703. The Permittee shall, within 90 days after the date this source becomes subject to 35 IAC 212.700, submit a request to modify this CAAPP permit in order to include a new, appropriate PM<sub>10</sub> Contingency Measure Plan.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

c. Episode Action Plan

Should this source become subject to 35 IAC 244.142, the Permittee shall prepare, submit, and operate under an Episode Action Plan for reducing the levels of emissions during yellow alerts, red alerts, and emergencies, consistent with safe operating procedures and submitted to the IEPA for its review. The Episode Action Plan shall contain the information specified in 35 IAC 244.144. The Permittee shall immediately implement the appropriate steps described in this Episode Action Plan should an air pollution alert or emergency be declared. Any future Episode Action Plan made by the Permittee during the permit term is automatically incorporated by reference provided the Episode Action Plan is not expressly disapproved, in writing, by the IEPA within 30 days of receipt of the Episode Action Plan. In the event that the IEPA notifies the Permittee of a deficiency with any Episode Action Plan, the Permittee shall be required to revise and resubmit the Episode Action Plan within 30 days of receipt of notification to address the deficiency pursuant to 39.5(7)(a) of the Illinois Environmental Protection Act.

d. Risk Management Plan (RMP)

Should this stationary source, as defined in 40 CFR 68.3, become subject to the federal regulations for Chemical Accident Prevention in 40 CFR Part 68, then the Permittee shall submit a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR 68.10(a); or submit a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan, as part of the annual compliance certification required by Condition 2.6(a). This condition is imposed in this permit pursuant to 40 CFR 68.215(a)(2)(i) and (ii).

<b>3. Equipment Leaks (40 CFR 63 Subpart BBBBBB)</b>
--

- a. Pursuant to 40 CFR 63.11089, the Permittee shall perform the following equipment leak inspections of all equipment (each valve, pump, pressure relief device, sampling connection system, open-ended valve or line, and flange or other connector in the gasoline liquid and vapor collection systems as defined in 40 CFR 63.11100):
- i. The Permittee shall perform a monthly leak inspection of all equipment in gasoline service, as defined above and in 40 CFR 63.11100. For this inspection, detection methods incorporating sight, sound, and smell are acceptable.
  - ii. A log book shall be used and shall be signed by the Permittee at the completion of each inspection. A section of the log book shall contain a list, summary description, or diagram(s) showing the location of all equipment in gasoline service at the facility.
  - iii. Each detection of a liquid or vapor leak shall be recorded in the log book. When a leak is detected, an initial attempt at repair shall be made as soon as practicable, but no later than 5 calendar days after the leak is detected. Repair or replacement of leaking equipment shall be completed within 15 calendar days after detection of each leak, except as provided below.
  - iv. Delay of repair of leaking equipment will be allowed if the repair is not feasible within 15 days. The owner or operator shall provide in the semiannual report the reason(s) why the repair was not feasible and the date each repair was completed.
- b. Pursuant to 40 CFR 63.11094(d), the Permittee subject to the equipment leak provisions of 40 CFR 63.11089 shall prepare and maintain a record describing the types, identification numbers, and locations to all equipment in gasoline service. If instrument program under 40 CFR 11089 is implemented, the record shall contain a full description of the program.
- c. Pursuant to 40 CFR 63.11094(e), the Permittee subject to the equipment leak inspections under 40 CFR 63.11089 shall record in the log book for each leak that is detected the following information:

ExxonMobil Lockport Terminal  
 I.D. No.: 197810AAL  
 Permit No.: 95090243

Date Received: 02/06/2007  
 Date Issued: 10/24/2014

- i. The equipment type and identification number.
- ii. The nature of the leak (i.e., vapor or liquid) and the method of detection (i.e., sight, sound, or smell).
- iii. The date the leak was detected and the date of each attempt to repair the leak.
- iv. Repair methods applied in each attempt to repair the leak.
- v. "Repair delayed" and the reason for the delay if the leak is not repaired within 15 calendar days after discovery of the leak.
- vi. The expected date of successful repair of the leak if the leak is not repaired within 15 days.
- vii. The date of successful repair of the leak.

**4. Pump and Compressor Requirements (35 IAC 218.142)**

- a. Pursuant to 35 IAC 218.142, the Permittee shall not cause or allow the discharge of more than 32.8 ml (2 cu in) of VOL with vapor pressure of 17.24 kPa (2.5 psia) or greater at 294.3°K (70°F) into the atmosphere from any pump or compressor in any 15 minute period at standard conditions.
- b. Pursuant to Section 39.5(7)(a) of the Act, compliance with the standard in 35 IAC 218.142 shall be achieved through implementation of the following procedures:
  - i. Inspections and repairs of the liquid leaks, as identified in 40 CFR 63.11089 and described in Condition 3.3 above.
  - ii. If a liquid leak(s) of VOL was discovered and identified, the Permittee shall use all available means to start localizing or collecting a leak and measuring an amount of VOL being discharged on the hourly basis before a leak is repaired.
  - iii. If the measured VOL leaks exceed the amount identified in 35 IAC 218.142, the Permittee shall report this event in accordance with Condition 3.7(a).
- c. Pursuant to Section 39.5(7)(a) of the Act, the Permittee shall keep records with supporting calculations of the discharge of VOL emissions (ml) to determine compliance with the applicable limitation in Condition 3.4(a) above.

**5. Title I Requirements**

- a. i. **Volatile Organic Material Requirements (VOM)**
  - A. Pursuant to Construction Permit #12110021, VOM emissions from storage of material, by category of service, shall not exceed the following limits: [T1].

Service	VOM Emissions	
	Tons/Month	Tons/Year
Gasoline	1.0	6.1
Distillate Oil	0.4	2.2
Other (Ethanol and Additive)	---	1.1

- B. Pursuant to Construction Permit #12110021, VOM emissions from leaking components (valves, pumps, flanges, etc.) associated with storage tanks shall not exceed 1.4 tons/year. [T1]

ExxonMobil Lockport Terminal  
 I.D. No.: 197810AAL  
 Permit No.: 95090243

Date Received: 02/06/2007  
 Date Issued: 10/24/2014

- C. Pursuant to Construction Permit #12110021, VOM emissions attributable to tank cleaning events and when the floating roof(s) rest on their legs resulting in landing losses shall not exceed 13.2 ton/year for all the internal floating roof tanks located at the source

ii. Compliance Method (VOM Requirements)

Monitoring

- A. Pursuant to Section 39.5(7)(a) of the Act, compliance with annual limits shall be determined on a monthly basis from the sum of the data for the current month plus the preceding 11 months (running 12 month total). [T1]

Recordkeeping

- B. Pursuant to Section 39.5(7)(b) of the Act, the Permittee shall maintain records as follows:
  - I. VOM emissions from each emission unit with supporting documentation (tons /month, tons/year) for each material.

**6. Synthetic Minor Limits**

As of the date of issuance of this permit, there are no source-wide synthetic minor limits that need to be included in this Condition.

**7. Reporting Requirements**

The Permittee shall submit the following information pursuant to Section 39.5(7)(f) of the Act. Addresses are included in Attachment 3.

a. Prompt Reporting

- i. A. Pursuant to Section 39.5(7)(f)(ii) of the Act, the Permittee shall promptly notify the IEPA, Air Compliance Section, within 30 days of deviations from applicable requirements as follows:
  - I. Requirements in Conditions 3.1(a)(i), 3.1(b), 3.1(c), 3.1(d), and 3.1(e).
  - II. Requirements in Conditions 3.2(a), 3.2(b), 3.2(c), and 3.2(d).
  - III. Requirements in Conditions 3.3(a), 3.3(b) and 3.3(c).
- B. All such deviations shall be summarized and reported as part of the Semiannual Monitoring Report required by Condition 3.7(b).
- ii. The Permittee shall notify the IEPA, Air Compliance Section, of all other deviations as part of the Semiannual Monitoring Report required by Condition 3.7(b).
- iii. The deviation reports shall contain at a minimum the following information:
  - A. Date and time of the deviation.
  - B. Emission unit(s) and/or operation involved.
  - C. The duration of the event.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

- D. Probable cause of the deviation.
- E. Corrective actions or preventative measures taken.

iv. All deviation reports required in this Permit shall be identified, summarized, and reported as part of the Semiannual Monitoring Report required by Condition 3.5(b).

**b. Semiannual Reporting**

i. Pursuant to Section 39.5(7)(f)(i) of the Act, the Permittee shall submit Semiannual Monitoring Reports to the IEPA, Air Compliance Section, summarizing required monitoring as part of the Compliance Methods in this Permit submitted every six months as follows, unless more frequent reporting is required in other parts of this permit.

<u>Monitoring Period</u>	<u>Report Due Date</u>
January through June	July 31
July through December	January 31

ii. The Semiannual Monitoring Report must be certified by a Responsible Official consistent with Condition 2.6(b).

**c. Annual Emissions Reporting**

Pursuant to 35 IAC Part 254, the Source shall submit an Annual Emission Report to the Air Quality Planning Section, due by May 1 of the year following the calendar year in which the emissions took place. All records and calculations upon which the verified and reported data are based must be retained by the source.

**d. Federal Reporting for Equipment Leaks (40 CFR 63 Subpart BBBBBB)**

Pursuant to 40 CFR 63.11089(g), the Permittee shall provide to the Illinois EPA, the semiannual compliance report specified in 40 CFR 63.11089(d) and 40 CFR 63.11095(b) for equipment leak inspections and shall include the number of equipment leaks not repaired within 15 days after detection. The semiannual compliance report could be submitted together with a Semiannual Monitoring Report on the dates identified above.

## Section 4 - Emission Unit Requirements

### 4.1 Existing Internal Floating Roof Storage Tanks for Gasoline/Gasoline Blend Stocks) (Non NSPS Tanks)

<b>1. Emission Units and Operations</b>
---

Emission Units	Pollutants Being Regulated	Original Construction Date	Modification/ Reconstruction Date	Air Pollution Control Devices or Measures	Monitoring Devices
151,461 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 901)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
53,595 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 902)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
96,739 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 903)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
80,324 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 904)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
42,421 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 905)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
121,001 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 906)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
80,518 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 907)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
67,080 Gallons Internal Floating Roof with Geodesic Dome Cover (TK 908)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
4,776 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 909)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

Note: For the emission units in Condition 4.1.1 above, the applicable requirements in non-gasoline mode of operation are addressed in Permit Section 4.2.

**2. Applicable Requirements**

For the emission units in Condition 4.1.1 above, the Permittee shall comply with the following applicable requirements pursuant to Sections 39.5(7)(a), 39.5(7)(b), and 39.5(7)(d) of the Act.

a. i. Work Practices and Control Requirements

A. Requirements of 35 IAC Part 218 Subpart B:

- I. Pursuant to 35 IAC 218.120(a), each tank shall be equipped with an internal floating roof that meets the specifications contained in 35 IAC 218.120(a)(1)(A) through (H).
- II. Pursuant to 35 IAC 218.121(b)(1), each tank shall be equipped with a floating roof which rests on the surface of the volatile petroleum liquid (VPL) and is equipped with a closure seal or seals between the roof edge and the tank wall. VPL stored in each floating roof tank shall not have a vapor pressure of 86.19 kPa (12.5 psia) or greater at 294.3°K (70°F). The Permittee shall not cause or allow the emission of VOMs into the atmosphere from any gauging or sampling devices attached to each tank, except during sampling or maintenance operations.
- III. Pursuant to 35 IAC 218.122(b), each tank shall be equipped with a permanent submerged loading pipe.
- IV. Pursuant to 35 IAC 218.123(b), no volatile petroleum liquid is allowed to be stored in the tanks, unless each tank is equipped and operated as follows:
  - 1. The tank is equipped with an internal floating roof as specified in 35 IAC 218.121(b);
  - 2. There are no visible holes, tears or other defects in the seal or any seal fabric or material of any floating roof;
  - 3. All openings of any floating roof deck, except stub drains, are equipped with covers, lids or seals such that:
    - (a) The cover, lid or seal is in the closed position at all times except when petroleum liquid is transferred to or from the tank;
    - (b) Automatic bleeder vents are closed at all times except when the roof is floated off or landed on the roof leg supports; and
    - (c) Rim vents, if provided, are set to open when the roof is being floated off the roof leg supports or at the manufacturer's recommended setting.

B. Requirements of 40 CFR 63 Subpart BBBBBB:

- I. Pursuant to 40 CFR 63.11081(a), the tanks are subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) Subpart BBBBBB for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

Section 4 - Emission Unit Requirements  
4.1 - Existing Internal Floating Roof Storage Tanks in Gasoline Service

1. Pursuant to 40 CFR 63.11098, the Permittee shall meet the applicable general provisions of 40 CFR 63 Subpart A.
  2. Pursuant to 40 CFR 63.11085(a), the Permittee shall, at all times, operate and maintain each storage tank, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions.
- II. Pursuant to 40 CFR 63.11087(a) and Table 1 of 40 CFR 63 Subpart BBBBBB, the Permittee shall:
1. Equip and operate each internal floating roof of a gasoline storage tank according to the applicable requirements in 40 CFR 60.112b(a)(1), except for the secondary seal requirements under 40 CFR 60.112b(a)(1)(ii)(B) and 40 CFR 60.112b(a)(1)(iv) through (ix). [Option 2b in Table 1]
- ii. Compliance Method (Work Practice and Control Requirements)

Monitoring

- A. Pursuant to 40 CFR 63.11087(c) and 40 CFR 63.11092(e)(1), the Permittee shall perform the following visual inspections of the different internal floating roof system designs according to the requirements of 40 CFR 60.113b(a), based on complying with Option 2(b) in Table 1 of 40 CFR 63 Subpart BBBBBB:
- B. 35 IAC 218.123(b):
- I. Pursuant to 35 IAC 218.123(b)(4), the Permittee shall conduct routine inspections of floating roof seals through roof hatches once every six months.
  - II. Pursuant to 35 IAC 218.123(b)(5), a complete inspection of the cover and seal of any floating roof tank is made whenever the tank is emptied for reasons other than the transfer of petroleum liquid during the normal operation of the tank, or whenever repairs are made as a result of any semi-annual inspection or incidence of roof damage or defect.

Recordkeeping

- C. Pursuant to 40 CFR 63.11094(a), the Permittee shall keep the following records as specified in 40 CFR 63.1065 if the storage tanks are complying with Option 2(b) in Table 1 of 40 CFR 63 Subpart BBBBBB as identified above:
- I. Tank dimensions and capacity.
  - II. Inspection results with the following data:
    1. Identification of the storage tank that was inspected;
    2. The date of inspection;
    3. A description of all inspection failures;
    4. A description of all repairs and the dates they were made;
    5. The date the storage vessel was removed from service, if applicable.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

- D. Pursuant to 35 IAC 218.123(b)(6), the Permittee shall keep the records of each inspection conducted under 35 IAC 218.123(b)(4) and (b)(5).
- E. Pursuant to Section 39.5(7)(b) of the Act, the Permittee shall maintain records of the presence of the submerged loading pipe.
- F. Pursuant to 40 CFR 60.115b, the owner or operator of each storage vessel shall keep records and furnish reports as required by 40 CFR 60.115b(a).
- G. Pursuant to 40 CFR 60.116b, the Permittee shall maintain records of the Monitoring of Operations as required by 40 CFR 60.116b(a) through (f).

### 3. Non-Applicability Determinations

- a. The tanks are not subject to the New Source Performance Standards (NSPS) for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels), 40 CFR Part 60 Subpart K, K<sub>a</sub>, K<sub>b</sub>, because the tanks were not constructed, reconstructed, or modified after July 23, 1984. Note: the tanks are subject to certain requirements of 40 CFR Part 60 Subpart K<sub>b</sub> when 40 CFR Part 63 Subpart BBBBBB contains an optional compliance reference to the certain provisions of Subpart K<sub>b</sub> or 40 CFR 63 Subpart WW. The Permittee is using 40 CFR Subpart K<sub>b</sub> option.
- b. The tanks are not subject to the National Emission Standards for Hazardous Air Pollutants for Gasoline Distribution Facilities (Bulk Gasoline Terminals and Pipeline Breakout Stations), 40 CFR Part 63 Subpart R, because the tanks are not located at a source that is a major source of hazardous air pollutants.
- c. The tanks are not subject to 35 IAC 218.120(a)(4) requiring installation of a vapor control system, because each tank is equipped with internal floating roof.
- d. The storage tank is not subject to 35 IAC 218.301 because the gasoline storage tank does not use organic material as defined in 35 IAC 211.4250(b).
- e. The tanks are not subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources, because the tanks use passive control measures, such as seals, lids, or roofs, that are not considered control devices.

### 4. Operational Flexibility/Anticipated Operating Scenarios

For other types of petroleum or organic liquid stored in these tanks, see permit section 4.2

### 5. Reporting Requirements

The Permittee shall submit the following information pursuant to Section 39.5(7)(f) of the Act. Addresses are included in Attachment 3.

#### a. Prompt Reporting

- i. A. Pursuant to Section 39.5(7)(f)(ii) of the Act, the Permittee shall promptly notify the IEPA, Air Compliance Section, within 30 days of deviations from applicable requirements as follows unless a different period is specified by a particular permit provision, i.e., NSPS or NESHAP requirement:
  - I. Requirements in Conditions 4.1.2(a)(i).
- B. All such deviations shall be summarized and reported as part of the Semiannual Monitoring Report required by Condition 3.7(b).

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

- ii. The Permittee shall notify the IEPA, Air Compliance Section, of all other deviations as part of the Semiannual Monitoring Reports required by Condition 3.7(b).
- iii. The deviation reports shall contain at a minimum the following information:
  - A. Date and time of the deviation.
  - B. Emission unit(s) and/or operation involved.
  - C. The duration of the event.
  - D. Probable cause of the deviation.
  - E. Corrective actions or preventative measures taken.

**b. Federal Reporting**

- i. Pursuant to 40 CFR 63.11087, the Permittee must keep records and submit reports as specified in 40 CFR 63.11094 and 40 CFR 63.11095(a)(1). The Permittee shall include in a semiannual compliance report the following information:
  - A. For storage tanks complying with option 2(d) in Table 1 of 40 CFR 63 Subpart BBBBBB, the information specified in 40 CFR 63.1066.
- ii. Pursuant to 40 CFR 63.11085(b), 40 CFR 63.11087(e), 40 CFR 63.11089(g), and 40 CFR 63.11095(d), the Permittee shall submit a semiannual report including the number, duration, and a brief description of each type of malfunction which occurred during the reporting period and which caused or may have caused any applicable emission limitation to be exceeded. The report shall also include a description of actions taken by the Permittee during a malfunction of the source to minimize emissions in accordance with 40 CFR 63.11085(a), including actions taken to correct a malfunction. The report may be submitted as a part of the semiannual compliance report required by Condition 3.7(b).

**c. Federal Reporting**

- i. Pursuant to 40 CFR 60.115b(a)(3), the Permittee shall submit a report identifying any deficiencies or shortcomings identified in the Annual Inspection to Illinois EPA within 30 days of inspection. This report shall identify the storage tank, the nature of the defects, and the date the storage vessel was emptied or the nature of and the date the repair was made.
- ii. Pursuant to 40 CFR 60.113b(a)(5), the Permittee shall provide notification at least 30 days prior to refilling a tank for which an Out-of-Service inspection is required to afford the Illinois EPA with an opportunity to have an observer present.

If the inspection is not planned and the owner or operator of the tank could not have known about refilling the tank 30 days in advance, a shorter notification may be accepted as provided for in 40 CFR 60.113b(a)(5).
- iii. Pursuant to 40 CFR 60.115b(a)(4), the Permittee shall submit a report identifying any deficiencies or shortcomings identified in the Out-of-Service Inspection within 30 days of the inspection. This report shall identify the storage tank on which the inspection was performed and shall contain the date the tank was inspected and the observed condition of each component of the control equipment (seals, internal floating roof, and fittings).

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

4.2 Existing Internal Floating Roof Storage Tanks in Non-Gasoline Service

1. Emission Units and Operations

Emission Units	Pollutants Being Regulated	Original Construction Date	Modification/ Reconstruction Date	Air Pollution Control Devices or Measures	Monitoring Devices
151,461 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 901)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
53,595 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 902)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
96,739 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 903)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
80,324 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 904)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
42,421 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 905)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
121,001 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 906)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
80,518 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 907)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
67,080 Gallons Internal Floating Roof with Geodesic Dome Cover (TK 908)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None
4,776 Barrels Internal Floating Roof with Geodesic Dome Cover (TK 909)	VOM, HAP	1972	N/A	Internal floating roof, metallic shoe primary seal, Rim-Mounted secondary seal, and a permanent submerged loading pipe.	None

Note: For the emission units in Condition 4.2.1 above, the applicable requirements in gasoline mode of operation are addressed in Permit Section 4.1.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

**2. Applicable Requirements**

For the emission units in Condition 4.2.1 above, the Permittee shall comply with the following applicable requirements pursuant to Sections 39.5(7)(a), 39.5(7)(b), and 39.5(7)(d) of the Act.

a. i. Work Practices and Control Requirements

A. Requirements of 35 IAC Part 218 Subpart B:

I. Pursuant to 35 IAC 218.121(b)(1), each VPL tank shall be equipped with a floating roof which rests on the surface of the volatile petroleum liquid (VPL) and is equipped with a closure seal or seals between the roof edge and the tank wall. VPL stored in each floating roof tank shall not have a vapor pressure of 86.19 kPa (12.5 psia) or greater at 294.3°K (70°F). The Permittee shall not cause or allow the emission of VOMs into the atmosphere from any gauging or sampling devices attached to each tank, except during sampling or maintenance operations.

II. Pursuant to 35 IAC 218.122(b), each tank shall be equipped with a permanent submerged loading pipe.

B. Pursuant to Section 39.5(7)(a) of the Act, the tanks shall not store VOL more than 0.5 maximum true vapor pressure.

ii. Compliance Method (Work Practices and Control Requirements)

Recordkeeping

A. Pursuant to Section 39.5(7)(b) of the Act, the Permittee shall keep the following records: material stored, tank dimensions and capacity in each tank.

B. Pursuant to Section 39.5(7)(b) of the Act, the Permittee shall maintain records of the presence of the submerged loading pipe.

**3. Non-Applicability Determinations**

- a. The tanks are not subject to the New Source Performance Standards (NSPS) for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels), 40 CFR Part 60 Subpart K, Ka, Kb, because the tanks were not constructed, reconstructed, or modified after July 23, 1984.
- b. The tanks are not subject to the National Emission Standards for Hazardous Air Pollution (NESHAP) for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities, 40 CFR Part 63 Subpart BBBBBB, because the tanks do not store gasoline pursuant to 40 CFR 63.11082. For gasoline storage operations see Permit Section 4.1.
- c. The gasoline storage tank is not subject to 35 IAC 218.301 because the gasoline storage tank does not use organic material as defined in 35 IAC 211.4250(b).
- d. The tanks are not subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources, because the tanks use passive control measures, such as seals, lids, or roofs, that are not considered control devices.

**4. Operational Flexibility/Anticipated Operating Scenarios**

For gasoline stored in these tanks, see permit section 4.1.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

**5. Reporting Requirements**

The Permittee shall submit the following information pursuant to Section 39.5(7)(f) of the Act. Addresses are included in Attachment 3.

**a. Prompt Reporting**

- i. A. Pursuant to Section 39.5(7)(f)(ii) of the Act, the Permittee shall promptly notify the IEPA, Air Compliance Section, within 30 days of deviations from applicable requirements as follows unless a different period is specified by a particular permit provision, i.e., NSPS or NESHAP requirement:
  - I. Requirements in Condition 4.2.2(a)(i).
- B. All such deviations shall be summarized and reported as part of the Semiannual Monitoring Report required by Condition 3.7(b).
- ii. The Permittee shall notify the IEPA, Air Compliance Section, of all other deviations as part of the Semiannual Monitoring Reports required by Condition 3.7(b).
- iii. The deviation reports shall contain at a minimum the following information:
  - A. Date and time of the deviation.
  - B. Emission unit(s) and/or operation involved.
  - C. The duration of the event.
  - D. Probable cause of the deviation.
  - E. Corrective actions or preventative measures taken.

4.3 Internal Floating Roof Storage Tanks (NSPS Tanks) in Non Gasoline Service

**1. Emission Units and Operations**

<i>Emission Units</i>	<i>Pollutants Being Regulated</i>	<i>Original Construction Date</i>	<i>Modification/ Reconstruction Date</i>	<i>Air Pollution Control Devices or Measures</i>	<i>Monitoring Devices</i>
4,912 Barrels Gallons Internal Floating Roof (Tank 910)	VOM, HAP	1997	N/A	Internal floating roof, metallic shoe primary seal, wiper secondary seal, and a permanent submerged loading pipe.	None
17,078 Barrels Gallons Internal Floating Roof (Tank 915)	VOM, HAP	2013	N/A	Internal floating roof, metallic shoe primary seal, wiper secondary seal, and a permanent submerged loading pipe.	None

**2. Applicable Requirements**

For the emission units in Condition 4.3.1 above, the Permittee shall comply with the following applicable requirements pursuant to Sections 39.5(7) (a), 39.5(7) (b), and 39.5(7) (d) of the Act.

a. i. Work Practices and Control Requirements

A. Requirements of 40 CFR 60 Subpart Kb

Pursuant to 40 CFR 60.112b(a)(1)(i), each internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal floating roof shall be floating on the liquid surface at all times, except during initial fill and during those intervals when the storage tank is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible.

- I. Pursuant to 40 CFR 60.112b(a)(1)(ii), each internal floating roof shall be equipped with one of the following closure devices between the wall of the storage tank and the edge of the internal floating roof:
  - 1. A foam- or liquid-filled seal mounted in contact with the liquid (liquid-mounted seal).
  - 2. Two seals mounted one above the other so that each forms a continuous closure that completely covers the space between the wall of the storage vessel and the edge of the internal floating roof. The lower seal may be vapor-mounted, but both must be continuous.
  - 3. A mechanical shoe seal. A mechanical shoe seal is a metal sheet held vertically against the wall of the storage vessel by springs or weighted levers and is connected by braces to the floating roof. A flexible coated fabric (envelope) spans the annular space between the metal sheet and the floating roof.
- II. Pursuant to 40 CFR 60.112b(a)(1)(iii), each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and the rim space vents, shall provide a projection below the liquid surface.

Section 4 - Emission Unit Requirements  
4.3 - Internal Floating Roof Storage Tanks  
(NSPS Tanks) in Non Gasoline Service

- III. Pursuant to 40 CFR 60.112b(a)(1)(iv), each opening in the internal floating roof, except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains, shall be equipped with a cover or lid which is maintained in a closed position at all times (i.e., no visible gaps) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use.
- IV. Pursuant to 40 CFR 60.112b(a)(1)(v), automatic bleeder vents shall be equipped with a gasket and be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports.
- V. Pursuant to 40 CFR 60.112b(a)(1)(vi), rim space vents shall be equipped with a gasket and be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting.
- VI. Pursuant to 40 CFR 60.112b(a)(1)(vii), each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The sample well shall have a slit fabric cover that covers at least 90 percent of the opening.
- VII. Pursuant to 40 CFR 60.112b(a)(1)(viii), each penetration of the internal floating roof that allows for the passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover.
- VIII. Pursuant to 40 CFR 60.112b(a)(1)(ix), each penetration of the internal floating roof that allows for passage of a ladder shall have a gasketed sliding cover.
- IX. Pursuant to 40 CFR 60.113b(a)(2) and (a)(3)(ii), a tank that is in-service shall be repaired or emptied upon identification in an inspection that the floating roof is not resting on the surface of the VOL, there is liquid accumulated on the roof, the seal is detached, or there are holes or tears in the seal fabric. These actions shall be completed within 45 days of the inspection unless an extension is granted.
- X. Pursuant to 40 CFR 60.113b(a)(3)(ii) and (a)(4), a tank that is empty shall be repaired prior to refilling the tank upon identification in an inspection that the floating roof has defects, the primary seal has holes, tears or other openings in the seal or seal fabric, or the secondary seal has holes, tears or other openings in the seal or seal fabric, or the gaskets no longer close off.

B. Requirements of 35 IAC Part 218 Subpart B:

- I. Pursuant to 35 IAC 218.120(a), the tanks in VOL service shall be equipped with internal floating roof that meets the specifications contained in 35 IAC 218.120(a)(1)(A) through (H).
- II. Pursuant to 35 IAC 218.121(b)(1), the tanks in VPL service shall be equipped with a floating roof which rests on the surface of the volatile petroleum liquid (VPL) and is equipped with a closure seal or seals between the roof edge and the tank wall. VPL stored in each floating roof tank shall not have a vapor pressure of 86.19 kPa (12.5 psia) or greater at 294.3°K (70°F). The Permittee shall not cause or allow the emission of VOMs into the atmosphere from any gauging or

sampling devices attached to each tank, except during sampling or maintenance operations.

III. Pursuant to 35 IAC 218.122(b), each tank shall be equipped with a permanent submerged loading pipe.

ii. Compliance Method (Work Practices and Control Requirements)

Monitoring

A. Monitoring of True Vapor Pressure 40 CFR 60.116b(e)

I. Pursuant to 40 CFR 60.116b(e)(1), for vessels operated at ambient temperatures, the maximum true vapor pressure can be calculated based upon the maximum local monthly average ambient temperature as reported by the National Weather Service.

B. Inspections of VOL Operations [40 CFR 60.113b(a)]

I. The Permittee shall perform the following:

1. 40 CFR 60.113b(a)(1):

Visually inspect the internal floating roof, the primary seal, and the secondary seal (if one is in service), prior to filling the storage tank with volatile organic liquid. All holes, tears, openings, or defects of the roof components shall be repaired before filling the storage tank.

2. 40 CFR 60.113b(a)(2):

For storage tanks equipped with a liquid-mounted or mechanical shoe primary seal, visually inspect the internal floating roof and the primary seal or the secondary seal at least once every 12 months after initial fill.

3. 40 CFR 60.113b(a)(3):

For storage tanks equipped with a double-seal system, visual inspections shall be conducted at least every 5 years or every 12 months after initial fill.

4. 40 CFR 60.113b(a)(4):

Visually inspect the internal floating roof, the primary seal, the secondary seal (if one is in service), gaskets, slotted membranes and sleeve seals (if any) each time the storage vessel is emptied and degassed. If the internal floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, or the gaskets no longer close off the liquid surfaces from the atmosphere, or the slotted membrane has more than 10 percent open area, the owner or operator shall repair the items as necessary so that none of the conditions specified in this paragraph exist before refilling the storage vessel with VOL. In no event shall inspections conducted in accordance with this provision occur at intervals greater than 10 years in the case of vessels conducting the annual visual inspection as specified in 40 CFR 60.113b(a)(2) and (a)(3)(ii) and at intervals no

greater than 5 years in the case of vessels specified in 40 CFR 60.113b(a) (3) (i).

- C. 35 IAC 218.123(b):
- I. Pursuant to 35 IAC 218.123(b) (4), the Permittee shall conduct routine inspections of the floating roof seals of each VPL tank through roof hatches once every six months.
  - II. Pursuant to 35 IAC 218.123(b) (5), a complete inspection of the cover and seal of any floating roof VPL tank is made whenever the tank is emptied for reasons other than the transfer of petroleum liquid during the normal operation of the tank, or whenever repairs are made as a result of any semi-annual inspection or incidence of roof damage or defect.
  - III. Pursuant to 35 IAC 218.127(a) (2), the Permittee shall conduct the routine inspections of the floating roof seals conducted through roof hatches once every 12 months and comply with the requirements specified in 35 IAC 218.127(a) (2) through (4).

Recordkeeping

- D. I. Pursuant to 40 CFR 60.115b, the owner or operator of each storage vessel shall keep records and furnish reports as required by 40 CFR 60.115b(a).
- II. Pursuant to 40 CFR 60.116b, the Permittee shall maintain records of the Monitoring of Operations as required by 40 CFR 60.116b(a) through (f).
- E. Pursuant to Section 39.5(7) (b), the Permittee shall keep the following records:
- I. Tank dimensions and capacity.
  - II. Inspection results with the following data:
    - 1. Identification of the storage tank that was inspected;
    - 2. The date of inspection;
    - 3. A description of all inspection failures;
    - 4. A description of all repairs and the dates they were made;
    - 5. The date the storage vessel was removed from service, if applicable.
- F. Pursuant to 35 IAC 218.123(b) (6), the Permittee shall keep the records of each VPL tank inspection conducted under 35 IAC 218.123(b) (4) and (b) (5).
- G. Pursuant to 35 IAC 218.129(a) (2), the Permittee shall keep records of each VOL tank inspection conducted under 35 IAC 218.127(a) (2), (a) (3) and (a) (4).

**3. Non-Applicability Determinations**

- a. The tanks are not subject to the National Emission Standards for Hazardous Air Pollution (NESHAP) for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities, 40 CFR Part 63 Subpart BBBBBB, because the tanks do not store gasoline pursuant to 40 CFR 63.11082.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

- b. The tanks are not subject to 35 IAC 218.123(b) because the tanks are subject to New Source Performance Standards for storage vessels of petroleum liquid (40 CFR 60 Subpart Kb) pursuant to 35 IAC 218.123(a) (5).
- c. The tanks are not subject to 35 IAC 218.301 because the gasoline storage tank does not use organic material as defined in 35 IAC 211.4250(b).
- d. The tanks are not subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources, because the tanks use passive control measures, such as seals, lids, or roofs, that are not considered control devices.

#### 4. Operational Flexibility/Anticipated Operating Scenarios

The Permittee is authorized to make the following physical or operational change with respect to a tank without prior notification to the Illinois EPA or revision of this permit. This condition does not affect the Permittee's obligation to properly obtain a construction permit in a timely manner for any activity constituting construction or modification of the source, as defined in 35 IAC 201.102.

- a. Changes in the material stored with a vapor pressure less than 3.5 kPa (0.5 psia) at 70°F, e.g., distillate fuel oils or blend stocks, diesel fuel, and jet kerosene, in the storage tanks identified in this section. In such instances, the unit specific conditions in Section 4.3 of this permit, applicable to such tank based on the storage of VOL or VPL, shall not apply.
  - i. If any storage tank identified in this section changes to storage of materials with a vapor pressure of less than 3.5 kPa (0.5 psia) at 70°F, the Permittee shall maintain a record identifying the specific tank, the liquid stored in the tank, the date such tank switched to the storage of this liquid, and if applicable, the date such tank returned to storage of VOL or VPL.
  - ii. Upon resuming storage of VOL or VPL, the applicable unit specific conditions of Section 4.3 of this permit shall again apply. Pursuant to 40 CFR 60.113b(a)(4), prior to returning such a tank to storage of VOL (or VPL), the Permittee shall conduct appropriate inspection(s) of the tank.
- b. Change the service between the tanks in Section 4.3 of the permit. Pursuant to Condition 4.3(a)(ii)(B)(I), maintain records of the material stored in each tank so that the applicable unit specific conditions of Section 4.3 of this permit (for VOL or VPL storage) can be determined.

#### 5. Reporting Requirements

The Permittee shall submit the following information pursuant to Section 39.5(7)(f) of the Act. Addresses are included in Attachment 3.

##### a. Prompt Reporting

- i. A. Pursuant to Section 39.5(7)(f)(ii) of the Act, the Permittee shall promptly notify the IEPA, Air Compliance Section, within 30 days of deviations from applicable requirements as follows unless a different period is specified by a particular permit provision, i.e., NSPS or NESHAP requirement:
  - I. Requirements in Condition 4.3.2(a)(i)
- B. All such deviations shall be summarized and reported as part of the Semiannual Monitoring Report required by Condition 3.7(b).

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

ii. The Permittee shall notify the IEPA, Air Compliance Section, of all other deviations as part of the Semiannual Monitoring Reports required by Condition 3.7(b).

iii. The deviation reports shall contain at a minimum the following information:

- A. Date and time of the deviation.
- B. Emission unit(s) and/or operation involved.
- C. The duration of the event.
- D. Probable cause of the deviation.
- E. Corrective actions or preventative measures taken.

**b. State Reporting**

- i. A. Pursuant to 35 IAC 218.127(a) (5), the Permittee shall promptly notify the IEPA, Air Compliance Section, in writing at least 30 days prior to the filling or refilling of each storage vessel for which an inspection is required by 35 IAC 218.127 (a) (1) and (a) (4) to afford the IEPA the opportunity to have an observer present. If the inspection required by subsection 35 IAC 218.127(a) (4) is not planned and the Permittee could not have known about the inspection 30 days in advance of refilling the tank, the Permittee shall notify the Agency at least 7 days prior to the refilling of the storage vessel. Notification shall be made by telephone immediately followed by written documentation demonstrating why the inspection was unplanned. Alternatively, this notification including the written documentation may be made in writing and sent by express mail so that it is received by the IEPA at least 7 days prior to the refilling.
- B. Pursuant to 35 IAC 218.129(a) (3), and (a) (4), the Permittee shall promptly notify the IEPA, Air Compliance Section, in writing if any of the conditions described in 35 IAC 218.127(a) (2) are detected during the annual visual inspection required by Section 218.127(a) (2), report to the IEPA within 30 days after the inspection the identity of the storage vessel, the nature of the defects, and the date the storage vessel was emptied or the nature of and date the repair was made; and
- C. after each inspection required by 35 IAC 218.127(a) (3) where holes or tears in the seal or seal fabric, or defects in the internal floating roof, or other control equipment defects listed in 35 IAC 218.127(a) (3) (B) are discovered, report to the IEPA within 30 days after the inspection the identity of the storage vessel and the reason it did not meet the specifications of 35 IAC 218.120(a) (1) or (2) or 35 IAC 218.127(a), and list each repair made.

**c. Federal Reporting**

- i. Pursuant to 40 CFR 60.115b(a) (3), if any of the conditions described in 40 CFR 60.113b(a) (2) are detected during the annual visual inspection required by 40 CFR 60.113b(a) (2), a report shall be furnished to the Administrator within 30 days of the inspection. Each report shall identify the storage vessel, the nature of the defects, and the date the storage vessel was emptied or the nature of and date the repair was made.
- ii. Pursuant to 40 CFR 60.113b(a) (5), the Permittee shall provide notification at least 30 days prior to refilling an tank for which an Out-of-Service inspection is required to afford the Illinois EPA with an opportunity to have an observer present.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

Section 4 - Emission Unit Requirements  
4.3 - Internal Floating Roof Storage Tanks  
(NSPS Tanks) in Non Gasoline Service

If the inspection is not planned and the owner or operator of the tank could not have known about refilling the tank 30 days in advance, a shorter notification may be accepted as provided for in 40 CFR 60.113b(a) (5).

- iii. Pursuant to 40 CFR 60.115b(a) (4), after each inspection required by 40 CFR 60.113b(a) (3) that finds holes or tears in the seal or seal fabric, or defects in the internal floating roof, or other control equipment defects listed in 40 CFR 60.113b(a) (3) (ii), a report shall be furnished to the IEPA within 30 days of the inspection. The report shall identify the storage vessel and the reason it did not meet the specifications of 40 CFR 61.112b(a) (1) or 40 CFR 60.113b(a) (3) and list each repair made.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

4.4 Truck Loading Rack

**1. Emission Units and Operations**

Emission Units	Pollutants Being Regulated	Original Construction Date	Modification/ Reconstruction Date	Air Pollution Control Devices or Measures	Monitoring Devices
Tank Truck Loading/ Unloading Rack Bay Loading Rack	VOM, HAP	07/1995	N/A	Vapor Combustion Unit (VCU) Portable VCU	Monitor device for Combustion Temperature

**2. Applicable Requirements**

For the emission units in Condition 4.4.1 above, the Permittee shall comply with the following applicable requirements pursuant to Sections 39.5(7)(a), 39.5(7)(b), and 39.5(7)(d) of the Act.

a. i. Volatile Organic Material Requirements (VOM)

- A. Pursuant to 40 CFR 63.11088(a) and Table 2 of Subpart BBBBBB, the Permittee shall reduce emissions of total organic compounds (TOC) to less than or equal to 80 mg/l of gasoline loaded into gasoline cargo tanks at the loading rack.
- B. Pursuant to 40 CFR 60.502(b), the emissions to the atmosphere from the vapor collection system due to the loading of liquid product into gasoline tank trucks are not to exceed 35 milligrams of total organic compounds per liter of gasoline loaded, except as noted in 40 CFR 60.502(c).
- C. Pursuant to 35 IAC 218.582(a)(1), no person shall cause or allow the transfer of gasoline into any delivery vessel from any bulk gasoline terminal unless the bulk gasoline terminal is equipped with a vapor control system that limits emission of VOM to 80 mg/l (0.00067 lbs/gal) of gasoline loaded.
- D. Pursuant to Construction permit #03060042 VOM emission from the VCU shall not exceed 10 mg/liter of gasoline loaded. [T1]
- E. Pursuant to Construction permit #12110021 VOM Emissions from the loading rack shall not exceed the following limits: [T1]

<u>Service</u>	<u>VOM Emissions</u>	
	<u>(Tons/Month)</u>	<u>(Tons/Year)</u>
Gasoline Loading	2.9	28.8
Distillate Loading	0.5	5.0

- F. Pursuant to Construction Permit #12110021 VOM emissions associated with fugitive losses associated with gasoline loading when the VAL system is not operational, shall not exceed 2.4 tons/year.

ii. Compliance Method (VOM Requirements)

Monitoring

- A. Pursuant to Section 39.5(7)(b), compliance with annual limits shall be determined on a monthly basis from the sum of the data for the current month plus the preceding 11 months (running 12 month total).
- B. Pursuant to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources, the loading rack is subject to 40 CFR Part 64. The

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

Permittee shall comply with the monitoring requirements of the CAM Plan described in Condition 7.4 and Table 7.4.1, pursuant to 40 CFR Part 64 as submitted in the Permittee's CAM plan application. At all times, the Owner or Operator shall maintain the monitoring, including but not limited to, maintaining necessary parts for routine repairs of the monitoring equipment, pursuant to 40 CFR 64.7(a) and (b).

- C. See also Condition 4.4.2(d) for the work practices requirements.
- D. Pursuant to 40 CFR 63.8(c)(4), the CPMS shall be in continuous operation and shall meet minimum frequency of operation requirements and shall complete a minimum of one cycle of operation for each successive 15-minute period. The Permittee shall comply with all the applicable general requirements in 40 CFR 63.8.

Testing

- E. Pursuant to Section 39.5(7)(c) of the Act and 40 CFR 63.11092(a), the Permittee shall conduct a test of the primary VCU by using methods 2A, 2B, 25B, and 21 within 18 months after of issuance of this permit and every 5 years thereafter separately with and without the Vacuum Assisted Loading (VAL). The Permittee shall comply with all the applicable testing requirements of 40 CFR 60.503, and Section 7.1.
- F. Pursuant to 40 CFR 63.11092(f), the annual certification test for gasoline cargo tanks shall be performed in accordance with requirements of 40 CFR 63.11092(f)(1) and (f)(2).

Recordkeeping

- G. Pursuant to Section 39.5(7)(b) of the Act, the Permittee shall maintain records of VOM emissions with supporting calculations (mg/liter, tons/month and tons/year).
- H. Pursuant to 40 CFR 63.11094(b), the Permittee shall keep records of the test results for each gasoline cargo tank loading at the facility as specified in 40 CFR 63.11094(b)(1) through (3).
- I. Pursuant to Construction Permit #12110021, the Permittee shall keep records of the identification of each period of time when the loading rack continued to load gasoline when the VAL system was not operating or not operating properly, with date, time duration, gasoline loading volume, and the reason why the system was not operating or not operating properly.
- J. Pursuant to Construction Permit #12110021, the Permittee shall keep records of aggregate duration (hours/month and hours/year) of operation when the VAL system is not operating or not operating properly.

b. i. Nitrogen Oxide Requirements (NO<sub>x</sub>)

- A. Pursuant to Construction Permit #12110021, NO<sub>x</sub> emissions from the vapor combustion unit associated with the affected loading rack shall not exceed 1.4 tons/month, and 13.1 tons/year. [T1]

ii. Compliance Method (NO<sub>x</sub> Requirements)

Monitoring

- A. Pursuant to Section 39.5(7)(b), compliance with annual limits shall be determined on a monthly basis from the sum of the data for the current month plus the preceding 11 months (running 12 month total).

Recordkeeping

B. Pursuant to Section 39.5(7)(b) of the Act, the Permittee shall maintain records of NO<sub>x</sub> emissions with supporting calculations (tons/month and tons/year).

c. i. Carbon Monoxide Requirements (CO)

A. Pursuant to Construction Permit #12110021, CO emissions from the vapor combustion unit associated with the affected loading rack shall not exceed 3.0 tons/month, and 29.8 tons/year. [T1]

ii. Compliance Method (CO Requirements)

Monitoring

A. Pursuant to Section 39.5(7)(b), compliance with annual limits shall be determined on a monthly basis from the sum of the data for the current month plus the preceding 11 months (running 12 month total).

Recordkeeping

C. Pursuant to Section 39.5(7)(b) of the Act, the Permittee shall maintain records of CO emissions with supporting calculations (tons/month and tons/year).

d. i. Work Practice and Control Requirements - 40 CFR 63 Subpart BBBBBB: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities

A. Pursuant to 40 CFR 63.11088(a) and Table 2 of Subpart BBBBBB, the Permittee shall comply with the following requirements:

1. A gasoline loading rack(s) at a bulk gasoline terminal with a gasoline throughput of 250,000 gallons per day, or greater	(a) Equip your loading rack(s) with a vapor collection system designed to collect the TOC vapors displaced from cargo tanks during product loading; and
	(b) Reduce emissions of TOC to less than or equal to 80 mg/l of gasoline loaded into gasoline cargo tanks at the loading rack; and
	(c) Design and operate the vapor collection system to prevent any TOC vapors collected at one loading rack from passing to another loading rack; and
	(d) Limit the loading of gasoline into gasoline cargo tanks that are vapor tight using the procedures specified in 40 CFR 60.502(e) through (j).

B. Pursuant to 40 CFR 63.11092(b)(1), (3) and (4), gasoline loading shall start until the VCU combustion temperature attains a value of 450°F. A combustion temperature of 450°F, 15-minute average shall be maintained during gasoline loading.

ii. Compliance Method (Work Practice Requirements)

Monitoring

A. Pursuant to 40 CFR 63.11092(b)(1)(iii)(A), the Permittee shall operate a Continuous Parameter Monitoring System (CPMS) by monitoring the temperature

sensor (gauge) and operated in firebox in a position before any substantial heat exchange occurs.

- B. Pursuant to Section 39.5(7)(d), the Permittee may use a portable VCU unit as a backup for the primary VCU for up to a total of 15 days per year. The portable VCU unit is subject to all control requirements applicable to the primary VCU as described in Section 4.4. If the portable VCU operates at the terminal more than 15 days per year, the Permittee shall inform the IEPA's Compliance Section and Regional Field Operations office within 3 business days. Additionally, if a company-owned portable VCU operates at the terminal more than 15 days per year, the Permittee shall conduct a test on the company-owned portable VCU unit in accordance with Condition 4.4.2(a)(ii)(D) within 60 days of such notification. For rental portable VCUs operated more than 15 days per year, emission data information from the manufacturer may be used in lieu of test results.
- C. Pursuant to 40 CFR 63.11092(d), each owner or operator of a bulk gasoline terminal shall comply with the requirements in 40 CFR 63.11092(d)(1) through (4):
- I. Operate the vapor processing system in a manner not to exceed or not to go below, as appropriate, the operating parameter value for the parameters described in paragraph 40 CFR 63.11092 (b)(1).
  - II. Operation of the vapor processing system in a manner exceeding or going below the operating parameter value, as appropriate, shall constitute a violation of the emission standard in 40 CFR 63.11088(a).

#### Testing

For Testing Requirements see Condition 4.4.2(a)(ii).

#### Recordkeeping

- D. Pursuant to 40 CFR 63.11094(f), the Permittee shall keep the records as specified on to 40 CFR 63.11094(f)(1) through (f)(5):
- I. Keep an up-to-date, readily accessible record of the continuous monitoring data required under 40 CFR 63.11092(b) or 40 CFR 63.11092(e). This record shall indicate the time intervals during which loadings of gasoline cargo tanks have occurred or, alternatively, shall record the operating parameter data only during such loadings. The date and time of day shall also be indicated at reasonable intervals on this record.
  - II. Record and report simultaneously with the Notification of Compliance Status required under 40 CFR 63.11093(b):
    - 1. All data and calculations, engineering assessments, and manufacturer's recommendations used in determining the operating parameter value under 40 CFR 63.11092(b) or 40 CFR 63.11092(e);
  - III. If the Permittee requests approval to use a vapor processing system or monitor an operating parameter other than those specified in 40 CFR 63.11092(b), the Permittee shall submit a description of planned reporting and recordkeeping procedures.
- E. Pursuant to 40 CFR 63.11094(g), shall keep the following records:

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

- I. Records of the occurrence and duration of each malfunction of operation of the loading racks or VCU and monitoring equipment.
- II. Records of actions taken during periods of malfunction to minimize emissions in accordance with 40 CFR 63.11085(a), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.

e. i. Work Practice and Control Requirements - 40 CFR 60 Subpart XX Standards of Performance for Bulk Gasoline Terminals

- A. Pursuant to 40 CFR 60.502(d), each vapor collection system shall be designed to prevent any total organic compounds vapors collected at one loading rack from passing to another loading rack.
- B. Pursuant to 40 CFR 60.502(e), loadings of liquid product into gasoline tank trucks shall be limited to vapor-tight gasoline tank trucks using the procedures 40 CFR 60.502(e)(1) through (e)(6).
- C. Pursuant to 40 CFR 60.502(f), the Permittee shall act to assure that loadings of gasoline tank trucks at the affected facility are made only into tanks equipped with vapor collection equipment that is compatible with the terminal's vapor collection system.
- D. Pursuant to 40 CFR 60.502(g), the Permittee shall act to assure that the terminal's and the tank truck's vapor collection systems are connected during each loading of a gasoline tank truck.
- E. Pursuant to 40 CFR 60.502(h), the vapor collection and liquid loading equipment shall be designed and operated to prevent gauge pressure in the delivery tank from exceeding 4,500 pascals (450 mm of water) during product loading. This level is not to be exceeded when measured by the procedures specified in 40 CFR 60.503(d).
- F. Pursuant to 40 CFR 60.502(i), no pressure-vacuum vent in the bulk gasoline terminal's vapor collection system shall begin to open at a system pressure less than 4,500 pascals (450 mm of water).

ii. Compliance Method (Work Practice Requirements)

Testing

- A. Pursuant to 40 CFR 60.503(a), the Permittee shall conduct performance tests required in 40 CFR 60.8, by utilizing test methods and procedures in Appendix A or other methods and procedures as specified in 40 CFR 60.8, except as provided in 40 CFR 60.8(b). The three-run requirement of 40 CFR 60.8(f) does not apply.
- B. Pursuant to 40 CFR 60.503(b), immediately prior to the performance test required to determine compliance with 40 CFR 60.502(b), (c), and (h), the Permittee shall use Method 21 to monitor for leakage of vapor all potential sources in the terminal's vapor collection system equipment while a gasoline tank truck is being loaded. The Permittee shall repair all leaks with readings of 10,000 ppm (as methane) or greater before conducting the performance test.
- C. Pursuant to 40 CFR 60.503(c), the Permittee shall determine compliance with the standards in 40 CFR 60.502(b) and (c) as specified in 40 CFR 60.503(c)(1) through (c)(7).

- D. Pursuant to 40 CFR 60.503(d), the Permittee shall determine compliance with the standard in 40 CFR 60.502(h) as specified in 40 CFR 60.503(d)(1) through (d)(2).
- E. The Permittee shall comply with all the applicable testing requirements of Section 7.1.
  - I. For the frequencies of testing requirements in Condition 4.4.2(e)(ii)(A), (B), and (C), see testing requirements of Condition 4.4.2(a)(ii).

Monitoring

- F. Pursuant to 40 CFR 60.502(j), each calendar month, the vapor collection system, the vapor processing system, and each loading rack handling gasoline shall be inspected during the loading of gasoline tank trucks for total organic compounds liquid or vapor leaks. For purposes of this paragraph, detection methods incorporating sight, sound, or smell are acceptable. Each detection of a leak shall be recorded and the source of the leak repaired within 15 calendar days after it is detected.

Recordkeeping

- G. For tank truck(s), the Permittee shall keep records specified in 40 CFR 60.505(a), (b) and (e).

f. i. Work Practice and Control Requirements - 35 IAC 218.582 and Construction Permit #1211021

- A. Pursuant to 35 IAC 218.582(a)(2), the vapor control system is operating and all vapors displaced in the loading of gasoline to the delivery vessel are vented only to the vapor control system.
- B. Pursuant to 35 IAC 218.582(a)(3), there shall be no liquid drainage from the loading device of a loading rack when it is not in use.
- C. Pursuant to 35 IAC 218.582(a)(4), all loading and vapor return lines shall be equipped with fittings which are vapor tight.
- D. Pursuant to 35 IAC 218.582(a)(5), the delivery vessel displays the appropriate sticker pursuant to the requirements of 35 IAC 218.584(b) or (d); or, if the terminal is driver-loaded, the terminal owner or operator shall be deemed to be in compliance with this 35 IAC 218.582 when terminal access authorization is limited to those owners and/or operators of delivery vessels who have provided a current certification as required by 35 IAC 218.584(c)(3).
- E. Pursuant to 35 IAC 218.582(b)(2), 218.582(b)(1)(A) and (C), the Permittee shall provide a pressure tap or equivalent on the vapor collection system associated with an affected loading rack. The vapor collection system and the gasoline loading equipment shall be operated in such a manner that it prevents avoidable leaks of liquid during loading or unloading operations and prevents the gauge pressure from exceeding 18 inches of water and the vacuum from exceeding 6 inches of water and to be measured as close as possible to the vapor hose connection.
- F. Pursuant to Construction Permit #12110021, the Vacuum Assisted Loading (VAL) System shall:

- a. The VAL system shall be designed to maintain a minimum vacuum (negative pressure) of 1.5 inches water column, 15 minute average, while loading gasoline into tanker trucks.
- b. Beginning one year (365 days) after initial startup of the VAL system, except during scheduled maintenance or extended outage of this system, if the above minimum vacuum is not present while loading tanker trucks with gasoline, the VAL system shall automatically shutdown the gasoline loading operation. The VAL system shall be operated whenever gasoline is loaded, except as noted in permit condition 4.4.2(g) (i) (B).

ii. Compliance Method (Work Practice and Control Requirements)

Monitoring

- A. Pursuant to 35 IAC 218.582(a), no person shall cause or allow the transfer of gasoline into a delivery vessel from an affected loading rack unless the delivery vessel displays the appropriate sticker pursuant to 35 IAC 218.584(b) or (d) or the delivery vessel has provided a current certification as required by 35 IAC 218.584(c) (3), and the delivery vessel meets the following requirements: [35 IAC 218.582(a) (5) and 218.584(a)]
  - I. Includes a vapor space connection that is equipped with fitting(s) which are vapor tight;
  - II. Has its hatches closed at all times during loading or unloading operations, unless a top loading vapor recovery system is used;
  - III. Does not internally exceed a gauge pressure of 18 inches of water or a vacuum of 6 inches of water;
  - IV. Is designed and maintained to be vapor tight at all times during normal operations;
  - V. Is not refilled in Illinois at other than:
    - 1. Bulk gasoline terminals that comply with the requirements of 35 IAC 218.582; or
    - 2. Bulk gasoline plants that comply with the requirements of 35 IAC 218.581(b); and
  - VI. Are tested annually in accordance with Method 27, 40 CFR 60, Appendix A. Each vessel must be repaired and retested within 15 business days after discovery of the leak by the owner, operator, or the Illinois EPA, when it fails to sustain:
    - 1. A pressure drop of no more than three inches of water in five minutes; and
    - 2. A vacuum drop of no more than three inches of water in five minutes.
- B. Pursuant to Construction Permit #12110021, the Permittee shall install, operate and maintain a continuous monitoring system for the level of vacuum (measured in inches of water) being achieved by the VAL System. The VAL system shall be operated whenever gasoline is loaded, except as noted in permit condition 4.4.2(g) (i) (B).

Recordkeeping

- C. Pursuant to Section 39.5(7)(b) of the Act, the Permittee shall maintain records of the requirements specified on 35 IAC 218.582(a)(5) and 218.584(a). The Permittee shall comply with all the applicable testing requirements of Section 7.1.
- D. Pursuant to Construction Permit #12110021, the Permittee shall maintain records of Identification of each period of time when the loading rack continued to load gasoline when the VAL system was not operating or not operating properly, with date, time duration, gasoline loading volume, and the reason why the system was not operating or not operating properly.

g. i. Operational and Production Requirements

- A. Pursuant to Construction Permit #12110021, gasoline loading through the loading rack shall not exceed 69,000,000 gallons/month and 689,900,000 gallons/year. Operation of the rack for distillate oil shall not exceed a throughput of 70,500,000 gallons/month and 705,200,000 gallons/year. Operation on Ethanol 10,400,000 gall/month and 103,500,000 gallons/year.
- B. Pursuant to Construction Permit #12110021, gasoline shall only be loaded through the loading rack when the VAL system is operational, except loading is allowed during maintenance or malfunction of the VAL system, provided that the maintenance or malfunction period shall not exceed 900 hours/year.

ii. Compliance Method (Operational and Production Requirements)

Monitoring

- A. Pursuant to Section 39.5(7)(b) of the Act, compliance with the annual limit shall be determined each month plus the preceding 11 months (running 12 months total). Compliance with the monthly limit shall be determined on a daily basis and 30 day rolling for each month for each mode of operation.

Recordkeeping

- B. Pursuant to Construction Permit #12110021, the Permittee shall keep the monthly and annual records of each material loadout processed by the loading rack (gallons/month and gallons/year). [T1]
- C. Pursuant to Construction Permit #12110021, the Permittee shall keep the aggregate duration (hours/month and hours/year) of operation when the VAL system is not operating or not operating properly. [T1]
- D. Pursuant to Construction permit #1309004, the Permittee shall keep the following records:
  - I. Identification of particular portable VCU, i.e., name, model number, serial number, VOM performance specification.
  - II. The Permittee shall maintain records of the date and time, when an affected VCU was in operation.
  - III. The Permittee shall maintain a record of the test report(s) for testing performed in accordance with Section 7.1. [T1]

**3. Non-Applicability Determinations**

- a. The loading rack is not subject to 35 IAC 218.122(a), because these emission units are equipped with a device that is equally effective in controlling emissions and according to the provisions of 35 IAC 201, and further processed consistent with 35 IAC 218.108b.
- b. The loading rack is not subject to 35 IAC 218 Subpart TT, pursuant to 35 IAC 218.980(a), because these emission units are regulated by 35 IAC 218 Subpart Y.

**4. Other Requirements**

As of the date of issuance of this permit, there are no other requirements that need to be included in this Condition.

**5. Reporting Requirements**

The Permittee shall submit the following information pursuant to Section 39.5(7)(f) of the Act. Addresses are included in Attachment 3.

**a. Prompt Reporting**

- i. A. Pursuant to Section 39.5(7)(f)(ii) of the Act, the Permittee shall promptly notify the IEPA, Air Compliance Section, within 30 days of deviations from applicable requirements as follows unless a different period is specified by a particular permit provision, i.e., NSPS or NESHAP requirement:
  - I. Requirements in Conditions 4.4.2(a)(i), 4.4.2(b)(i), 4.4.2(c)(i), 4.4.2(d)(i), 4.4.2(e)(i), 4.4.2(f)(i) and 4.4.2(g)(i).
  - B. All such deviations shall be summarized and reported as part of the Semiannual Monitoring Report required by Condition 3.7(b).
- ii. The Permittee shall notify the IEPA, Air Compliance Section, of all other deviations as part of the Semiannual Monitoring Report required by Condition 3.7(b).
- iii. The deviation reports shall contain at a minimum the following information:
  - A. Date and time of the deviation.
  - B. Emission unit(s) and/or operation involved.
  - C. The duration of the event.
  - D. Probable cause of the deviation.
  - E. Corrective actions or preventative measures taken.
  - F. Pursuant to Construction Permit#:
    - I. The Permittee shall notify the Illinois EPA of deviations from the requirements of this permit within 30 days of such occurrence. Reports shall describe the deviation, the probable cause of such deviation, the corrective actions taken, and any preventative measures taken.
    - II. The Permittee shall notify the IEPA within 30 days of affected VCU installation with reason for installation.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

b. Federal Reporting

- i. Pursuant to 40 CFR 63.11088, the Permittee must keep records and submit reports as specified in 40 CFR 63.11094 and 40 CFR 63.11095 and 40 CFR 63.11095(a)(2), (b) and (c).
  - A. For storage tanks complying with option 2(d) in Table 1 of 40 CFR 63 Subpart BBBBBB, the information specified in 40 CFR 63.1066.
- ii. Pursuant to 40 CFR 63.11085(b), 40 CFR 63.11087(e), 40 CFR 63.11089(g), and 40 CFR 63.11095(d), the Permittee shall submit a semiannual report including the number, duration, and a brief description of each type of malfunction which occurred during the reporting period and which caused or may have caused any applicable emission limitation to be exceeded. The report shall also include a description of actions taken by the Permittee during a malfunction of the source to minimize emissions in accordance with 40 CFR 63.11085(a), including actions taken to correct a malfunction. The report may be submitted as a part of the semiannual compliance report.

**Section 5 - Additional Title I Requirements**

This Section is reserved for Title I requirements not specified in Sections 3 or 4. As of the date of issuance of this permit, there are no Title I requirements that need to be separately addressed in this Section.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

## Section 6 - Insignificant Activities Requirements

### 1. Insignificant Activities Subject to Specific Regulations

This condition is reserved for insignificant activities, as defined in 35 IAC 201.210 and 201.211, which are subject to specific standards promulgated pursuant Sections 111, 112, 165, or 173 of the Clean Air Act, see Sections 9.1(d) and 39.5(6)(a) of the Act. As of the date of issuance of this permit, there are no such insignificant activities present at the source.

### 2. Insignificant Activities in 35 IAC 201.210(a)

In addition to any insignificant activities identified in Condition 6.1, the following additional activities at the source constitute insignificant activities pursuant to 35 IAC 201.210 and 201.211:

Insignificant Activity	Number of Units	Insignificant Activity Category
Meter Proving Tank 1,500 and 200-gallon , portable vessel	2	35 IAC 201.210(a)(1) and 201.211
Tanks storing additives (Tank 0001, Tank 0002 and Tank 0003)	3	35 IAC 201.210(a)(1) and 201.211
Stormwater discharges	1	35 IAC 201.210(a)(2) or (a)(3)
5,499 Barrels Gallons Internal Floating Roof (Tank 913)	1	35 IAC 201.210(a)(2) or (a)(3)
Storage tanks < 10,000 gallon with annual throughput < 100,000 gallon (not storing gasoline or any material listed as a HAP). Tank 0005 and Tank 911	2	35 IAC 201.210(a)(10)

### 3. Insignificant Activities in 35 IAC 201.210(b)

Pursuant to 35 IAC 201.210, the source has identified insignificant activities as listed in 35 IAC 201.210(b)(1) through (28) as being present at the source. The source is not required to individually list the activities.

### 4. Applicable Requirements

Insignificant activities in Conditions 6.1 and 6.2 are subject to the following general regulatory limits notwithstanding status as insignificant activities. The Permittee shall comply with the following requirements, as applicable:

- a. Pursuant to 35 IAC 212.123(a), no person shall cause or allow the emission of smoke or other particulate matter, with an opacity greater than 30 percent, into the atmosphere from any emission unit other than those emission units subject to 35 IAC 212.122, except as provided in 35 IAC 212.123(b).
- b. Pursuant to 35 IAC 212.321 or 212.322 (see Conditions 7.2(a) and (b)), no person shall cause or allow the emission of particulate matter into the atmosphere in any one hour period from any process emission unit which, either alone or in combination with the emission of particulate matter from all other similar process emission units at a source or premises, exceed the allowable emission rates specified 35 IAC 212.321 or 212.322 and 35 IAC Part 266.
- c. Pursuant to 35 IAC 214.301, no person shall cause or allow the emission of sulfur dioxide into the atmosphere from any process emission source to exceed 2,000 ppm, except as provided in 35 IAC Part 214.
- d. Pursuant to 35 IAC 218.301, no person shall cause or allow the discharge of more than 8 lbs/hr of organic material into the atmosphere from any emission source, except as provided in 35 IAC 218.302, 218.303, 218.304 and the following exception: If no odor nuisance exists the limitation of 35 IAC 215 Subpart K shall apply only to photochemically reactive material.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

- e. Pursuant to 35 IAC 218.122(b), no person shall cause or allow the loading of any organic material into any stationary tank having a storage capacity of greater than 250 gal, unless such tank is equipped with a permanent submerged loading pipe, submerged fill, or an equivalent device approved by the IEPA according to 35 IAC Part 201 or unless such tank is a pressure tank as described in 35 IAC 215.121(a) or is fitted with a recovery system as described in 35 IAC 215.121(b)(2). Exception as provided in 35 IAC 218.122(c): If no odor nuisance exists the limitations of 35 IAC 215.122 shall only apply to the loading of volatile organic liquid with a vapor pressure of 2.5 psia or greater at 70°F.
- f. Pursuant to 35 IAC 218 Subpart TT, VOM emissions from insignificant activities required to be included in determining applicability of 35 IAC 218 Subpart TT, in conjunction with applicable emission units in Section 4 of this permit, shall not equal or exceed 25 tons/yr.

#### 5. Compliance Method

Pursuant to Section 39.5(7)(b) of the Act, the source shall maintain records of the following items for the insignificant activities in Conditions 6.1 and 6.2:

- a. List of all insignificant activities, including insignificant activities added as specified in Condition 6.6, the categories the insignificant activities fall under, and supporting calculations as needed for any insignificant activities listed in 35 IAC 201.210(a)(1) through (3).
- b. Potential to emit emission calculations before any air pollution control device for any insignificant activities listed in 35 IAC 201.210(a)(1) through (3).

#### 6. Notification Requirements for Insignificant Activities

The source shall notify the IEPA accordingly to the addition of insignificant activities:

##### a. Notification 7 Days in Advance

- i. Pursuant to 35 IAC 201.212(b), for the addition of an insignificant activity that would be categorized under 35 IAC 201.210(a)(1) and 201.211 and is not currently identified in Conditions 6.1 or 6.2, a notification to the IEPA Permit Section 7 days in advance of the addition of the insignificant activity is required. Addresses are included in Attachment 3. The notification shall include the following pursuant to 35 IAC 201.211(b):
  - A. A description of the emission unit including the function and expected operating schedule of the unit.
  - B. A description of any air pollution control equipment or control measures associated with the emission unit.
  - C. The emissions of regulated air pollutants in lb/hr and ton/yr.
  - D. The means by which emissions were determined or estimated.
  - E. The estimated number of such emission units at the source.
  - F. Other information upon which the applicant relies to support treatment of such emission unit as an insignificant activity.
- ii. Pursuant to 35 IAC 201.212(b), for the addition of an insignificant activity that would be categorized under 35 IAC 201.210(a)(2) through 201.210(a)(18) and is not currently identified in Conditions 6.1 or 6.2, a notification to the IEPA Permit Section 7 days in advance of the addition of the insignificant activity is required. Addresses are included in Attachment 3.

ExxonMobil Lockport Terminal  
 I.D. No.: 197810AAL  
 Permit No.: 95090243

Date Received: 02/06/2007  
 Date Issued: 10/24/2014

iii. Pursuant to Sections 39.5(12)(a)(i)(b) and 39.5(12)(b)(iii) of the Act, the permit shield described in Section 39.5(7)(j) of the Act (see Condition 2.7) shall not apply to any addition of an insignificant activity noted above.

**b. Notification Required at Renewal**

Pursuant to 35 IAC 201.212(a) and 35 IAC 201.146(kkk), for the addition of an insignificant activity that would be categorized under 35 IAC 201.210(a) and is currently identified in Conditions 6.1 or 6.2, a notification is not required until the renewal of this permit.

**c. Notification Not Required**

Pursuant to 35 IAC 201.212(c) and 35 IAC 201.146(kkk), for the addition of an insignificant activity that would be categorized under 35 IAC 201.210(b) as describe in Condition 6.3, a notification is not required.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

## Section 7 - Other Requirements

### 1. Testing

- a. Pursuant to Section 39.5(7) (a) of the Act, a written test protocol shall be submitted at least sixty (60) days prior to the actual date of testing, unless it is required otherwise in applicable state or federal statutes. The IEPA may at the discretion of the Compliance Section Manager (or designee) accept protocol less than 60 days prior to testing provided it does not interfere with the IEPA's ability to review and comment on the protocol and does not deviate from the applicable state or federal statutes. The protocol shall be submitted to the IEPA, Compliance Section and IEPA, Stack Test Specialist for its review. Addresses are included in Attachment 3. This protocol shall describe the specific procedures for testing, including as a minimum:
- i. The name and identification of the emission unit(s) being tested.
  - ii. Purpose of the test, i.e., permit condition requirement, IEPA or USEPA requesting test.
  - iii. The person(s) who will be performing sampling and analysis and their experience with similar tests.
  - iv. The specific conditions under which testing will be performed, including a discussion of why these conditions will be representative of maximum emissions and the means by which the operating parameters for the emission unit and any control equipment will be determined.
  - v. The specific determinations of emissions and operation which are intended to be made, including sampling and monitoring locations.
  - vi. The test method(s) that will be used, with the specific analysis method, if the method can be used with different analysis methods. Include if emission tests averaging of 35 IAC 283 will be used.
  - vii. Any minor changes in standard methodology proposed to accommodate the specific circumstances of testing, with detailed justification. This shall be included as a waiver of the test procedures. If a waiver has already been obtained by the IEPA or USEPA, then the waiver shall be submitted.
  - viii. Any proposed use of an alternative test method, with detailed justification. This shall be included as a waiver of the test procedures. If a waiver has already been obtained by the IEPA or USEPA, then the waiver shall be submitted.
  - ix. Sampling of materials, QA/QC procedures, inspections, etc.
- b. The IEPA, Compliance Section shall be notified prior to these tests to enable the IEPA to observe these tests pursuant to Section 39.5(7) (a) of the Act as follows:
- i. Notification of the expected date of testing shall be submitted in writing a minimum of thirty (30) days prior to the expected test date, unless it is required otherwise in applicable state or federal statutes.
  - ii. Notification of the actual date and expected time of testing shall be submitted in writing a minimum of five (5) working days prior to the actual date of the test. The IEPA may at its discretion of the Compliance Section Manager (or designee) accept notifications with shorter advance notice provided such notifications will not interfere with the IEPA's ability to observe testing.
- c. Copies of the Final Report(s) for these tests shall be submitted to the IEPA, Compliance Section within fourteen (14) days after the test results are compiled and finalized but

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

no later than ninety (90) days after completion of the test, unless it is required otherwise in applicable state or federal statutes or the IEPA may at the discretion of the Compliance Section Manager (or designee) an alternative date is agreed upon in advance pursuant to Section 39.5(7)(a) of the Act. The Final Report shall include as a minimum:

- i. General information including emission unit(s) tested.
  - ii. A summary of results.
  - iii. Discussion of conditions during each test run (malfunction/breakdown, startup/shutdown, abnormal processing, etc.).
  - iv. Description of test method(s), including description of sampling points, sampling train, analysis equipment, and test schedule.
  - v. Detailed description of test conditions, including:
    - A. Process information, i.e., mode(s) of operation, process rate, e.g. fuel or raw material consumption.
    - B. Control equipment information, i.e., equipment condition and operating parameters during testing.
    - C. A discussion of any preparatory actions taken, i.e., inspections, maintenance and repair.
  - vi. Data and calculations, including copies of all raw data sheets and records of laboratory analyses, sample calculations, and data on equipment calibration.
  - vii. An explanation of any discrepancies among individual tests or anomalous data.
  - viii. Results of the sampling of materials, QA/QC procedures, inspections, etc.
  - ix. Discussion of whether protocol was followed and description of any changes to the protocol if any occurred.
  - x. Demonstration of compliance showing whether test results are in compliance with applicable state or federal statutes.
- d. Copies of all test reports and other test related documentation shall be kept on site as required by Condition 2.5(b) pursuant to Section 39.5(7)(e)(ii) of the Act.

**2. Emissions Reduction Market System (ERMS) Requirements**

- a. Pursuant to 35 IAC Part 205, this source is considered a "participating source" for purposes of the ERMS.
- b. Obligation to Hold Allotment Trading Units (ATUs)
  - i. Pursuant to 35 IAC 205.150(c)(1) and 35 IAC 205.720, and as further addressed by Condition 7.2(g), as of December 31 of each year, this source shall hold ATUs in its account in an amount not less than the ATU equivalent of its VOM emissions during the preceding seasonal allotment period (May 1 - September 30), not including VOM emissions from the following, or the source shall be subject to "emissions excursion compensation", as described in Condition 7.2(d):
    - A. VOM emissions from insignificant emission units and activities as identified in Section 6 of this permit, in accordance with 35 IAC 205.220.
    - B. Excess VOM emissions associated with startup, malfunction, or breakdown of an emission unit as authorized in Section 4 of this permit, in accordance with 35 IAC 205.225.
    - C. Excess VOM emissions to the extent allowed by a Variance, Consent Order, or Compliance Schedule, in accordance with 35 IAC 205.320(e)(3).
    - D. Excess VOM emissions that are a consequence of an emergency as approved by the IEPA, pursuant to 35 IAC 205.750.
    - E. VOM emissions from certain new and modified emission units as addressed by Condition 7.2(g)(ii), if applicable, in accordance with 35 IAC 205.320(f).
  - ii. In accordance with 35 IAC 205.150(c)(2), notwithstanding the Condition 7.2(b)(i) above, if a source commences operation of a major modification, pursuant to 35 IAC Part 203, the source shall hold ATUs in an amount not less than 1.3 times its seasonal VOM emissions attributable to such major modification during the seasonal allotment period, determined in accordance with the construction permit for such major modification or applicable provisions in Section 4 of this permit.
- c. Market Transactions
  - i. As specified in 35 IAC 205.610(a), the source shall apply to the IEPA for and obtain authorization for a Transaction Account prior to conducting any market transactions.
  - ii. Pursuant to 35 IAC 205.610(b), the Permittee shall promptly submit to the IEPA any revisions to the information submitted for its Transaction Account.
  - iii. Pursuant to 35 IAC 205.620(a), the source shall have at least one account officer designated for its Transaction Account.
  - iv. Any transfer of ATUs to or from the source from another source or general participant must be authorized by a qualified Account Officer designated by the source and approved by the IEPA, in accordance with 35 IAC 205.620, and the transfer must be submitted to the IEPA for entry into the Transaction Account database.
- d. Emissions Excursion Compensation

Pursuant to 35 IAC 205.720, if the source fails to hold ATUs in accordance with Condition 7.2(b), it shall provide emissions excursion compensation in accordance with the following:

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

- i. Upon receipt of an Excursion Compensation Notice issued by the IEPA, the source shall purchase ATUs from the ACMA in the amount specified by the notice, as follows:
  - A. The purchase of ATUs shall be in an amount equivalent to 1.2 times the emissions excursion; or
  - B. If the source had an emissions excursion for the seasonal allotment period immediately before the period for the present emissions excursion, the source shall purchase ATUs in an amount equivalent to 1.5 times the emissions excursion.
- ii. If requested in accordance with paragraph 7.2(d)(iii) below or in the event that the ACMA balance is not adequate to cover the total emissions excursion amount, the IEPA will deduct ATUs equivalent to the specified amount or any remaining portion thereof from the ATUs to be issued to the source for the next seasonal allotment period.
- iii. Pursuant to 35 IAC 205.720(c), within 15 days after receipt of an Excursion Compensation Notice, the Owner or Operator may request that ATUs equivalent to the amount specified be deducted from the source's next seasonal allotment by the IEPA, rather than purchased from the ACMA.

e. Quantification of Seasonal VOM Emissions

- i. Pursuant to 35 IAC 205.315(b), the methods and procedures specified in Sections 3 and 4 of this permit for determining VOM emissions and compliance with VOM emission limitations shall be used for determining seasonal VOM emissions for purposes of the ERMS, with the following exceptions:

No exceptions

- ii. In accordance with 35 IAC 205.750, the Permittee shall report emergency conditions at the source to the IEPA if the Permittee intends to deduct VOM emissions in excess of the technology-based emission rates normally achieved that are attributable to the emergency from the source's seasonal VOM emissions for purposes of the ERMS. These reports shall include the information specified by 35 IAC 205.750(a), and shall be submitted in accordance with the following:
  - A. An initial emergency conditions report within two days after the time when such excess emissions occurred due to the emergency.
  - B. A final emergency conditions report, if needed to supplement the initial report, within 10 days after the conclusion of the emergency.

f. Annual Account Reporting

- i. Pursuant to 35 IAC 205.300, for each year in which the source is operational, the Permittee shall submit, as a component of its Annual Emissions Report, seasonal VOM emissions information to the IEPA for the seasonal allotment period. This report shall include the following information:
  - A. Actual seasonal emissions of VOM from the source.
  - B. A description of the methods and practices used to determine VOM emissions, as required by this permit, including any supporting documentation and calculations.
  - C. A detailed description of any monitoring methods that differ from the methods specified in this permit, as provided in 35 IAC 205.337.

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

- D. If a source has experienced an emergency, as provided in 35 IAC 205.750, the report shall reference the associated emergency conditions report that has been approved by the IEPA.
- E. If a source's baseline emissions have been adjusted due to a Variance, Consent Order, or CAAPP permit Compliance Schedule, as provided for in 35 IAC 205.320(e)(3), the report shall provide documentation quantifying the excess VOM emissions during the season that were allowed by the Variance, Consent Order, or Compliance Schedule, in accordance with 35 IAC 205.320(e)(3).
- F. If a source is operating a new or modified emission unit for which three years of operational data is not yet available, as specified in 35 IAC 205.320(f), the report shall specify seasonal VOM emissions attributable to the new emission unit or the modification of the emission unit.

ii. This report shall be submitted by November 30 of each year, for the preceding seasonal allotment period.

g. Allotment of ATUs to the Source

- i. A. The allotment of ATUs to this source is 113 ATUs per seasonal allotment period.
  - B. This allotment of ATUs reflects the IEPA's determination that the source's baseline emissions were 12.7523 tons per season.
    - I. This determination includes the use of 1995 and 1996 as baseline seasons.
  - C. The source's allotment reflects 88% of the baseline emissions (12% reduction), except for the VOM emissions from specific emission units excluded from such reduction, pursuant to 35 IAC 205.405, including units complying with MACT or using BAT, as identified in Condition 7.2(i) of this permit.
  - D. ATUs will be issued to the source's Transaction Account by the IEPA annually. These ATUs will be valid for the seasonal allotment period following issuance and, if not retired in this season, the next seasonal allotment period.
- ii. Contingent Allotments for New or Modified Emission Units
- None
- iii. Notwithstanding the above, part or all of the above ATUs will not be issued to the source in circumstances as set forth in 35 IAC Part 205, including:
- A. Transfer of ATUs by the source to another participant or the ACMA, in accordance with 35 IAC 205.630.
  - B. Deduction of ATUs as a consequence of emissions excursion compensation, in accordance with 35 IAC 205.720.
  - C. Transfer of ATUs to the ACMA, as a consequence of shutdown of the source, in accordance with 35 IAC 205.410.

h. Recordkeeping for ERMS

Pursuant to 35 IAC 205.700(a), the Permittee shall maintain copies of the following documents as its Compliance Master File for purposes of the ERMS:

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

- i. Seasonal component of the Annual Emissions Report.
- ii. Information on actual VOM emissions, as specified in detail in Sections 3 and 4 of this permit and Condition 7.2(e)(i).
- iii. Any transfer agreements for the purchase or sale of ATUs and other documentation associated with the transfer of ATUs.

i. Exclusions from Further Reductions

- i. A. Pursuant to 35 IAC 205.405(a), VOM emissions from the following emission units shall be excluded from the VOM emissions reductions requirements specified in 35 IAC 205.400(c) and (e) as long as such emission units continue to satisfy the following:
  - I. Emission units that comply with any NESHAP or MACT standard promulgated pursuant to the CAA.
  - II. Direct combustion emission units designed and used for comfort heating purposes, fuel combustion emission units, and internal combustion engines.
  - III. An emission unit for which a LAER demonstration has been approved by the IEPA on or after November 15, 1990.
- B. Pursuant to 35 IAC 205.405(a) and (c), the source has demonstrated in its ERMS application and the IEPA has determined that the following emission units qualify for exclusion from further reductions because they meet the criteria as indicated above:

None
- ii. A. Pursuant to 35 IAC 205.405(b), VOM emissions from emission units using BAT for controlling VOM emissions shall not be subject to the VOM emissions reductions requirement specified in 35 IAC 205.400(c) or (e) as long as such emission unit continues to use such BAT.
- B. Pursuant to 35 IAC 205.405(b) and (c), the source has demonstrated in its ERMS application and the IEPA has determined that the following emission units qualify for exclusion from further reductions because these emission units use BAT for controlling VOM emissions as indicated above:

None

**3. 40 CFR 63 Subpart A Requirements (NESHAP)**

**a. 40 CFR 63 Subpart A and Subpart BBBBBB - National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Distribution Bulk Terminals, Bulk Plants, and Pipeline Facilities**

Pursuant to 40 CFR 63 Subpart A and Subpart BBBBBB, Table 3, the Permittee shall comply with the following applicable General Provisions as indicated:

<i>General Provision Citation</i>	<i>General Provision Applicable?</i>	<i>Subject of Citation</i>	<i>Explanation (if required)</i>
40 CFR 63.1	Yes, specific requirements given in 40 CFR 63.11081.	Applicability	Initial applicability determination; applicability after standard established; permit requirements; extensions, notifications
40 CFR 63.1(c)(2)	Yes, 40 CFR 63.11081(b) of subpart BBBBBB exempts identified area sources from the obligation to obtain title V operating permits.	Title V permit	Requirements for obtaining a Title V permit from the applicable permitting authority
40 CFR 63.2	Yes, additional definitions in 40 CFR 63.11100.	Definitions	Definitions for Part 63 standards
40 CFR 63.3	Yes.	Units and Abbreviations	Units and abbreviations for Part 63 standards
40 CFR 63.4	Yes.	Prohibited Activities and Circumvention	Prohibited activities, circumvention, severability
40 CFR 63.5	Yes.	Construction/Reconstruction	Applicability; applications; approvals
40 CFR 63.6(a)	Yes.	Compliance with Standards/Operation & Maintenance Applicability	General Provisions apply unless compliance extension; General Provisions apply to area sources that become major
40 CFR 63.6(b)(1)-(4)	Yes.	Compliance Dates for New and Reconstructed Sources	Standards apply at effective date; 3 years after effective date; upon startup; 10 years after construction or reconstruction commences for CAA section 112(f)
40 CFR 63.6(b)(5)	Yes.	Notification	Must notify if commenced construction or reconstruction after proposal
40 CFR 63.6(b)(6)		[Reserved]	

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

<i>General Provision Citation</i>	<i>General Provision Applicable?</i>	<i>Subject of Citation</i>	<i>Explanation (if required)</i>
40 CFR 63.6(b)(7)	No.	Compliance Dates for New and Reconstructed Area Sources that Become Major	Area sources that become major must comply with major source standards immediately upon becoming major.
40 CFR 63.6(c)(1)-(2)	No, 40 CFR 63.11083 specifies the compliance dates.	Compliance Dates for Existing Sources	Comply according to date in this subpart, which must be no later than 3 years after effective date; for CAA section 112(f) standards, comply within 90 days of effective date unless compliance extension
40 CFR 63.6(c)(3)-(4)		[Reserved]	
40 CFR 63.6(c)(5)	No.	Compliance Dates for Existing Area Sources that Become Major	Area sources that become major must comply with major source standards by date indicated in this subpart or by equivalent time period (e.g., 3 years)
40 CFR 63.6(d)		[Reserved]	
40 CFR 63.6(e)(1)(i)	No. See 40 CFR 63.11085 for general duty requirement.	General duty to minimize emissions	Operate to minimize emissions at all times; information Administrator will use to determine if operation and maintenance requirements were met
40 CFR 63.6(e)(1)(ii)	No.	Requirement to correct malfunctions as soon as possible	Owner or operator must correct malfunctions as soon as possible
40 CFR 63.6(e)(2)		[Reserved]	
40 CFR 63.6(e)(3)	No.	Startup, Shutdown, and Malfunction (SSM) plan	Requirement for SSM plan; content of SSM plan; actions during SSM
40 CFR 63.6(f)(1)	No.	Compliance Except During SSM	You must comply with emission standards at all times except during SSM
40 CFR 63.6(f)(2)-(3)	Yes.	Methods for Determining Compliance	Compliance based on performance test, operation and maintenance plans, records, inspection
40 CFR 63.6(g)(1)-(3)	Yes.	Alternative Standard	Procedures for getting an alternative standard
40 CFR 63.6(h)(1)	No.	Compliance with Opacity/VE Standards	You must comply with opacity/VE standards at all times except during SSM
40 CFR 63.6(h)(2)(i)	No.	Determining Compliance with Opacity/VE Standards	If standard does not State test method, use EPA Method 9 for opacity in Appendix A of Part 60 of this chapter and EPA Method 22 for VE in Appendix A of part 60 of this chapter

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

General Provision General Provision  
Citation Applicable?

Citation	Applicable?	Subject of Citation	Explanation (if required)
40 CFR 63.6(h)(2)(ii)		[Reserved]	
40 CFR 63.6(h)(2)(iii)	No.	Using Previous Tests to Demonstrate Compliance with Opacity/VE Standards	Criteria for when previous opacity/VE testing can be used to show compliance with this subpart
40 CFR 63.6(h)(3)		[Reserved]	
40 CFR 63.6(h)(4)	No.	Notification of Opacity/VE Observation Date	Must notify Administrator of anticipated date of observation
40 CFR 63.6(h)(5)(i), (iii)-(v)	No.	Conducting Opacity/VE Observations	Dates and schedule for conducting opacity/VE observations
40 CFR 63.6(h)(5)(ii)	No.	Opacity Test Duration and Averaging Times	Must have at least 3 hours of observation with 30 6-minute averages
40 CFR 63.6(h)(6)	No.	Records of Conditions During Opacity/VE Observations	Must keep records available and allow Administrator to inspect
40 CFR 63.6(h)(7)(i)	No.	Report Continuous Opacity Monitoring System (COMS) Monitoring Data from Performance Test	Must submit COMS data with other performance test data
40 CFR 63.6(h)(7)(ii)	No.	Using COMS Instead of EPA Method 9	Can submit COMS data instead of EPA Method 9 results even if rule requires EPA Method 9 in Appendix A of Part 60 of this chapter, but must notify Administrator before performance test
40 CFR 63.6(h)(7)(iii)	No.	Averaging Time for COMS During Performance Test	To determine compliance, must reduce COMS data to 6-minute averages
40 CFR 63.6(h)(7)(iv)	No.	COMS Requirements	Owner/operator must demonstrate that COMS performance evaluations are conducted according to 40 CFR 63.8(e); COMS are properly maintained and operated according to 40 CFR 63.8(c) and data quality as 40 CFR 63.8(d)
40 CFR 63.6(h)(7)(v)	No.	Determining Compliance with Opacity/VE Standards	COMS is probable but not conclusive evidence of compliance with opacity standard, even if EPA Method 9 observation shows otherwise. Requirements for COMS to be probable evidence-proper maintenance, meeting Performance Specification 1 in Appendix B of Part 60 of this chapter, and data have not been altered

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

General Provision Citation	General Provision Applicable?	Subject of Citation	Explanation (if required)
40 CFR 63.6(h)(8)	No.	Determining Compliance with Opacity/VE Standards	Administrator will use all COMS, EPA Method 9 (in Appendix A of Part 60 of this chapter), and EPA Method 22 (in Appendix A of Part 60 of this chapter) results, as well as information about operation and maintenance to determine compliance
40 CFR 63.6(h)(9)	No.	Adjusted Opacity Standard	Procedures for Administrator to adjust an opacity standard
40 CFR 63.6(i)(1)-(14)	Yes.	Compliance Extension	Procedures and criteria for Administrator to grant compliance extension
40 CFR 63.6(j)	Yes.	Presidential Compliance Exemption	President may exempt any source from requirement to comply with this subpart
40 CFR 63.7(a)(2)	Yes.	Performance Test Dates	Dates for conducting initial performance testing; must conduct 180 days after compliance date
40 CFR 63.7(a)(3)	Yes.	Section 114 Authority	Administrator may require a performance test under CAA Section 114 at any time
40 CFR 63.7(b)(1)	Yes.	Notification of Performance Test	Must notify Administrator 60 days before the test
40 CFR 63.7(b)(2)	Yes.	Notification of Re-scheduling	If have to reschedule performance test, must notify Administrator of rescheduled date as soon as practicable and without delay
40 CFR 63.7(c)	Yes.	Quality Assurance (QA)/Test Plan	Requirement to submit site-specific test plan 60 days before the test or on date Administrator agrees with; test plan approval procedures; performance audit requirements; internal and external QA procedures for testing
40 CFR 63.7(d)	Yes.	Testing Facilities	Requirements for testing facilities
63.7(e)(1)	No, 40 CFR 63.11092(g) specifies conditions for conducting performance tests.	Conditions for Conducting Performance Tests	Performance test must be conducted under representative conditions
40 CFR 63.7(e)(2)	Yes.	Conditions for Conducting Performance Tests	Must conduct according to this subpart and EPA test methods unless Administrator approves alternative

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

General Provision General Provision

Citation	Applicable?	Subject of Citation	Explanation (if required)
40 CFR 63.7(e)(3)	Yes, except for testing conducted under 40 CFR 63.11092(a).	Test Run Duration	Must have three test runs of at least 1 hour each; compliance is based on arithmetic mean of three runs; conditions when data from an additional test run can be used
40 CFR 63.7(f)	Yes.	Alternative Test Method	Procedures by which Administrator can grant approval to use an intermediate or major change, or alternative to a test method
40 CFR 63.7(g)	Yes.	Performance Test Data Analysis	Must include raw data in performance test report; must submit performance test data 60 days after end of test with the notification of compliance status; keep data for 5 years
40 CFR 63.7(h)	Yes.	Waiver of Tests	Procedures for Administrator to waive performance test
40 CFR 63.8(a)(1)	Yes.	Applicability of Monitoring Requirements	Subject to all monitoring requirements in standard
40 CFR 63.8(a)(2)	Yes.	Performance Specifications	Performance specifications in Appendix B of 40 CFR Part 60 apply
40 CFR 63.8(a)(3)		[Reserved]	
40 CFR 63.8(a)(4)	Yes.	Monitoring of Flares	Monitoring requirements for flares in 40 CFR 63.11 apply
40 CFR 63.8(b)(1)	Yes.	Monitoring	Must conduct monitoring according to standard unless Administrator approves alternative
40 CFR 63.8(b)(2)-(3)	Yes.	Multiple Effluents and Multiple Monitoring Systems	Specific requirements for installing monitoring systems; must install on each affected source or after combined with another affected source before it is released to the atmosphere provided the monitoring is sufficient to demonstrate compliance with the standard; if more than one monitoring system on an emission point, must report all monitoring system results, unless one monitoring system is a backup
40 CFR 63.8(c)(1)	Yes.	Monitoring System Operation and Maintenance	Maintain monitoring system in a manner consistent with good air pollution control practices
40 CFR 63.8(c)(1)(i)	No.	Operation and Maintenance of CMS	Must maintain and operate each CMS as specified in 40 CFR 63.6(e)(1)

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

<i>General Provision Citation</i>	<i>General Provision Applicable?</i>	<i>Subject of Citation</i>	<i>Explanation (if required)</i>
40 CFR 63.8(c) (1) (ii)	Yes.	Operation and Maintenance of CMS	Must keep parts for routine repairs readily available
40 CFR 63.8(c) (1) (iii)	No.	Operation and Maintenance of CMS	Requirement to develop SSM Plan for CMS
40 CFR 63.8(c) (2) - (8)	Yes.	CMS Requirements	Must install to get representative emission or parameter measurements; must verify operational status before or at performance test
40 CFR 63.8(d)	No.	CMS Quality Control	Requirements for CMS quality control, including calibration, etc.; must keep quality control plan on record for 5 years; keep old versions for 5 years after revisions
40 CFR 63.8(e)	Yes.	CMS Performance Evaluation	Notification, performance evaluation test plan, reports
40 CFR 63.8(f) (1) - (5)	Yes.	Alternative Monitoring Method	Procedures for Administrator to approve alternative monitoring
40 CFR 63.8(f) (6)	Yes.	Alternative to Relative Accuracy Test	Procedures for Administrator to approve alternative relative accuracy tests for CEMS
40 CFR 63.8(g)	Yes.	Data Reduction	COMS 6-minute averages calculated over at least 36 evenly spaced data points; CEMS 1 hour averages computed over at least 4 equally spaced data points; data that cannot be used in average
40 CFR 63.9(a)	Yes.	Notification Requirements	Applicability and State delegation
40 CFR 63.9(b) (1) - (2), (4) - (5)	Yes.	Initial Notifications	Submit notification within 120 days after effective date; notification of intent to construct/reconstruct, notification of commencement of construction/reconstruction, notification of startup; contents of each
40 CFR 63.9(c)	Yes.	Request for Compliance Extension	Can request if cannot comply by date or if installed best available control technology or lowest achievable emission rate
40 CFR 63.9(d)	Yes.	Notification of Special Compliance Requirements for New Sources	For sources that commence construction between proposal and promulgation and want to comply 3 years after effective date
40 CFR 63.9(e)	Yes.	Notification of Performance Test	Notify Administrator 60 days prior

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

General Provision Citation	General Provision Applicable?	Subject of Citation	Explanation (if required)
40 CFR 63.9(f)	No.	Notification of VE/Opacity Test	Notify Administrator 30 days prior
40 CFR 63.9(g)	Yes, however, there are no opacity standards.	Additional Notifications When Using CMS	Notification of performance evaluation; notification about use of COMS data; notification that exceeded criterion for relative accuracy alternative
40 CFR 63.9(h)(1)-(6)	Yes, except as specified in 40 CFR 63.11095(a)(4); also, there are no opacity standards.	Notification of Compliance Status	Contents due 60 days after end of performance test or other compliance demonstration, except for opacity/VE, which are due 30 days after; when to submit to Federal vs. State authority
40 CFR 63.9(i)	Yes.	Adjustment of Submittal Deadlines	Procedures for Administrator to approve change when notifications must be submitted
40 CFR 63.9(j)	Yes.	Change in Previous Information	Must submit within 15 days after the change
40 CFR 63.10(a)	Yes.	Record-keeping/Reporting	Applies to all, unless compliance extension; when to submit to Federal vs. State authority; procedures for owners of more than one source
40 CFR 63.10(b)(1)	Yes.	Record-keeping/Reporting	General requirements; keep all records readily available; keep for 5 years
40 CFR 63.10(b)(2)(i)	No.	Records related to SSM	Recordkeeping of occurrence and duration of startups and shutdowns
40 CFR 63.10(b)(2)(ii)	No. See 40 CFR 63.11094(g) for recordkeeping of (1) occurrence and duration and (2) actions taken during malfunction.	Records related to SSM	Recordkeeping of malfunctions
40 CFR 63.10(b)(2)(iii)	Yes.	Maintenance records	Recordkeeping of maintenance on air pollution control and monitoring equipment
40 CFR 63.10(b)(2)(iv)	No.	Records Related to SSM	Actions taken to minimize emissions during SSM
40 CFR 63.10(b)(2)(v)	No.	Records Related to SSM	Actions taken to minimize emissions during SSM
40 CFR 63.10(b)(2)(vi)-(xi)	Yes.	CMS Records	Malfunctions, inoperative, out-of-control periods

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

General Provision      General Provision  
Citation                      Applicable?

Citation	Applicable?	Subject of Citation	Explanation (if required)
40 CFR 63.10(b)(2)(xii)	Yes.	Records	Records when under waiver
40 CFR 63.10(b)(2)(xiii)	Yes.	Records	Records when using alternative to relative accuracy test
40 CFR 63.10(b)(2)(xiv)	Yes.	Records	All documentation supporting initial notification and notification of compliance status
40 CFR 63.10(b)(3)	Yes.	Records	Applicability determinations
40 CFR 63.10(c)	No.	Records	Additional records for CMS
40 CFR 63.10(d)(1)	Yes.	General Reporting Requirements	Requirement to report
40 CFR 63.10(d)(2)	Yes.	Report of Performance Test Results	When to submit to Federal or State authority
40 CFR 63.10(d)(3)	No.	Reporting Opacity or VE Observations	What to report and when
40 CFR 63.10(d)(4)	Yes.	Progress Reports	Must submit progress reports on schedule if under compliance extension
40 CFR 63.10(d)(5)	No. See 40 CFR 63.11095(d) for malfunction reporting requirements.	SSM Reports	Contents and submission
40 CFR 63.10(e)(1)-(2)	No.	Additional CMS Reports	Must report results for each CEMS on a unit; written copy of CMS performance evaluation; 2-3 copies of COMS performance evaluation
40 CFR 63.10(e)(3)(i)-(iii)	Yes, note that 40 CFR 63.11095 specifies excess emission events for this subpart.	Reports	Schedule for reporting excess emissions

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

<i>General Provision Citation</i>	<i>General Provision Applicable?</i>	<i>Subject of Citation</i>	<i>Explanation (if required)</i>
40 CFR 63.10(e)(3)(iv)-(v)	Yes, 40 CFR 63.11095 specifies excess emission events for this subpart.	Excess Emissions Reports	Requirement to revert to quarterly submission if there is an excess emissions and parameter monitor exceedances (now defined as deviations); provision to request semiannual reporting after compliance for 1 year; submit report by 30th day following end of quarter or calendar half; if there has not been an exceedance or excess emissions (now defined as deviations), report contents in a statement that there have been no deviations; must submit report containing all of the information in 40 CFR 40 CFR 63.8(c)(7)-(8) and 63.10(c)(5)-(13)
40 CFR 63.10(e)(3)(vi)-(viii)	Yes.	Excess Emissions Report and Summary Report	Requirements for reporting excess emissions for CMS; requires all of the information in 40 CFR 40 CFR 63.8(c)(7)-(8) and 63.10(c)(5)-(13)
40 CFR 63.10(e)(4)	Yes.	Reporting COMS Data	Must submit COMS data with performance test data
40 CFR 63.10(f)	Yes.	Waiver for Recordkeeping/Reporting	Procedures for Administrator to waive
40 CFR 63.11(b)	Yes, the section references 40 CFR 63.11(b).	Flares	Requirements for flares
40 CFR 63.12	Yes.	Delegation	State authority to enforce standards
40 CFR 63.13	Yes.	Addresses	Addresses where reports, notifications, and requests are sent
40 CFR 63.14	Yes.	Incorporations by Reference	Test methods incorporated by reference
40 CFR 63.15	Yes.	Availability of Information	Public and confidential information

ExxonMobil Lockport Terminal  
 I.D. No.: 197810AAL  
 Permit No.: 95090243

Date Received: 02/06/2007  
 Date Issued: 10/24/2014

**4. Compliance Assurance Monitoring (CAM) Requirements**

**a. CAM Provisions**

**i. Proper Maintenance**

Pursuant to 40 CFR 64.7(b), at all times, the source shall maintain the monitoring, including but not limited to, maintaining necessary parts for routine repairs of the monitoring equipment.

**ii. Continued Operation**

Pursuant to 40 CFR 64.7(c), except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the source shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit (PSEU) is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of 40 CFR Part 64, including data averages and calculations, or fulfilling a minimum data availability requirement, if applicable. The source shall use all the data collected during all other periods in assessing the operation of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

**iii. Response to Excursions or Exceedances**

A. Pursuant to 40 CFR 64.7(d)(1), upon detecting an excursion or exceedance, the source shall restore operation of the PSEU (including the control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). Such actions may include initial inspection and evaluation, recording that operations returned to normal without operator action (such as through response by a computerized distribution control system), or any necessary follow-up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable.

B. Pursuant to 40 CFR 64.7(d)(2), determination of whether the source has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include but is not limited to, monitoring results, review of operation and maintenance procedures and records, and inspection of the control device.

**b. Monitoring - Monitoring**

Pursuant to 40 CFR 64.7(a), the source shall comply with the monitoring requirements of the CAM Plans as described in 7.4(e) below, pursuant to 40 CFR Part 64 as submitted in the source's CAM plan application.

c. Monitoring - Recordkeeping

Pursuant to 40 CFR 64.9(b)(1), the source shall maintain records of the monitoring data, monitor performance data, corrective actions taken, monitoring equipment maintenance, and other supporting information related to the monitoring requirements established for CAM.

d. Monitoring - Reporting

Pursuant to Sections 39.5(7)(b) and (f) of the Act, the source shall submit the following reporting requirements:

i. Semiannual Reporting

As part of the required Semiannual Monitoring Reports, the source shall submit a CAM report including the following at a minimum:

- A. Summary information on the number, duration, and cause of excursions or exceedances, and the corrective actions taken pursuant to 40 CFR 64.6(c)(3) and 64.9(a)(2)(i).
- B. Summary information on the number, duration, and cause for monitoring equipment downtime incidents, other than downtime associated with calibration checks pursuant to 40 CFR 64.6(c)(3) and 64.9(a)(2)(ii).

e. CAM Plans

The following tables contain the CAM Plans in this CAAPP permit:

Table	Emission Unit Section	PSEU Designation	Pollutant
7.4.1	4.4	Loading Rack	VOM

**Table 7.4.1 - CAM Plan**

Emission Unit Section:	4.4
PSEU Designation:	Loading Rack
Pollutant:	VOM

Indicators:	#1) Combustion Temperature	
<b>General Criteria</b>		
The Monitoring Approach Used to Measure the Indicators:	CPMS measuring temperature	
The Indicator Range Which Provides a Reasonable Assurance of Compliance:	450 Deg F. 15 minutes average- based on Source test	
Quality Improvement Plan (QIP) Threshold Levels:	NA	
<b>General Criteria</b>		
The Specifications for Obtaining Representative Data:	CPMS capable of measuring temperature shall be installed in the firebox	
Verification Procedures to Confirm the Operational Status of the Monitoring:	Daily checks per manufacturer recommendation to verify proper operation	
Quality Assurance and Quality Control (QA/QC) Practices that Ensure the Validity of the Data:	Semi-annual preventive maintenance performed by qualified contractor	
The Monitoring Frequency:	Temperature is monitored continuously	
The Data Collection Procedures That Will Be Used:	Daily log sheet maintained. Alarms are recorded in log book.	
The Data Averaging Period For Determining Whether an Excursion or Exceedance Has Occurred:	15-minutes	

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

## Section 8 - State Only Requirements

## 1. Permitted Emissions for Fees

The annual emissions from the source for purposes of "Duties to Pay Fees" of Condition 2.3(e), not considering insignificant activities as addressed by Section 6, shall not exceed the following limitations. The overall source emissions shall be determined by adding emissions from all emission units. Compliance with these limits shall be determined on a calendar year basis. The Permittee shall maintain records with supporting calculations of how the annual emissions for fee purposes were calculated. This Condition is set for the purpose of establishing fees and is not federally enforceable. See Section 39.5(18) of the Act.

<i>Pollutant</i>		<i>Tons/Year</i>
Volatile Organic Material	(VOM)	55.00
Sulfur Dioxide	(SO <sub>2</sub> )	----
Particulate Matter	(PM)	----
Nitrogen Oxides	(NO <sub>x</sub> )	13.10
HAP, not included in VOM or PM	(HAP)	----
Total		68.10

ExxonMobil Lockport Terminal  
 I.D. No.: 197810AAL  
 Permit No.: 95090243

Date Received: 02/06/2007  
 Date Issued: 10/24/2014

## Attachment 1 - List of Emission Units at This Source

<i>Section</i>	<i>Emission Units</i>	<i>Description</i>
4.1	Existing Internal Floating Roof Storage Tanks for Gasoline/Gasoline Blend Stocks) (Non NSPS Tanks)	The Permittee operates external floating roof storage tanks that are required to have a rim-mounted secondary seal to store various petroleum products. Permanent submerged loading must be used at these tanks, minimizing turbulence and evaporation of VOM during loading.
4.2	Existing Internal Floating Roof Storage Tanks in Non-Gasoline Service	Same tanks described in 4.1 but the section includes all the applicable requirements during non-gasoline service.
4.3	Internal Floating Roof Storage Tanks (NSPS Tanks) in Non Gasoline Service	The Permittee operates an existing internal floating roof storage tank equipped with a liquid-mounted primary seal to store ethanol. Permanent submerged loading must be used for this tank, minimizing turbulence and evaporation of VOM during loading
4.4	Truck Loading Rack	The truck loading/unloading rack is used to load and unload various petroleum products and additives. The Permittee operates a loading rack that consists of three bays that include a total of four loading points. The VOM emissions from the truck loading/unloading rack occur when material is loaded into delivery vehicles. A vapor control combustion unit (VCU) is used to capture and control the emissions that occur as a result of displacement of vapors in the delivery vehicles. The VOM emissions from unloading material are accounted for in the working losses of the storage tanks the material is loaded into, with the exception of fugitive emissions that are attributed to the components, i.e., valves, flanges, etc. associated with the truck loading stations.

ExxonMobil Lockport Terminal  
 I.D. No.: 197810AAL  
 Permit No.: 95090243

Date Received: 02/06/2007  
 Date Issued: 10/24/2014

## Attachment 2 - Acronyms and Abbreviations

acfm	Actual cubic feet per minute
ACMA	Alternative Compliance Market Account
Act	Illinois Environmental Protection Act [415 ILCS 5/1 et seq.]
AP-42	Compilation of Air Pollutant Emission Factors, Volume 1, Stationary Point and Other Sources (and Supplements A through F), USEPA, Office of Air Quality Planning and Standards, Research Triangle Park, NC 27711
ATU	Allotment trading unit
BACT	Best Available Control Technology
BAT	Best Available Technology
Btu	British Thermal Units
CAA	Clean Air Act [42 U.S.C. Section 7401 et seq.]
CAAPP	Clean Air Act Permit Program
CAIR	Clean Air Interstate Rule
CAM	Compliance Assurance Monitoring
CEMS	Continuous Emission Monitoring System
CFR	Code of Federal Regulations
CISWI	Commercial Industrial Solid Waste Incinerator
CO	Carbon monoxide
CO <sub>2</sub>	Carbon dioxide
COMS	Continuous Opacity Monitoring System
CPMS	Continuous Parameter Monitoring System
dscf	Dry standard cubic foot
dscm	Dry standard cubic meter
ERMS	Emissions Reduction Market System
°F	Degrees Fahrenheit
GHG	Green house gas
GACT	Generally Acceptable Control Technology
gr	Grains
HAP	Hazardous air pollutant
Hg	Mercury
HMIWI	Hospital medical infectious waste incinerator
hp	Horsepower
hr	Hour
H <sub>2</sub> S	Hydrogen sulfide
I.D. No.	Identification number of source, assigned by IEPA
IAC	Illinois Administrative Code
ILCS	Illinois Compiled Statutes
IEPA	Illinois Environmental Protection Agency
kw	Kilowatts
LAER	Lowest Achievable Emission Rate
lbs	Pound

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

m	Meter
MACT	Maximum Achievable Control Technology
M	Thousand
MM	Million
mos	Month
MSDS	Material Safety Data Sheet
MSSCAM	Major Stationary Sources Construction and Modification (Non-attainment New Source Review)
MW	Megawatts
NESHAP	National Emission Standards for Hazardous Air Pollutants
NO <sub>x</sub>	Nitrogen oxides
NSPS	New Source Performance Standards
NSR	New Source Review
PB	Lead
PEMS	Predictive Emissions Monitoring System
PM	Particulate matter
PM <sub>10</sub>	Particulate matter with an aerodynamic diameter less than or equal to a nominal 10 microns as measured by applicable test or monitoring methods
PM <sub>2.5</sub>	Particulate matter with an aerodynamic diameter less than or equal to a nominal 2.5 microns as measured by applicable test or monitoring methods
ppm	Parts per million
ppmv	Parts per million by volume
ppmw	Parts per million by weight
PSD	Prevention of Significant Deterioration
PSEU	Pollutant-Specific Emission Unit
psia	Pounds per square inch absolute
PTE	Potential to emit
RACT	Reasonable Available Control Technology
RMP	Risk Management Plan
scf	Standard cubic feet
SCR	Selective catalytic reduction
SIP	State Implementation Plan
SO <sub>2</sub>	Sulfur dioxide
T1	Title I - identifies Title I conditions that have been carried over from an existing permit
T1N	Title I New - identifies Title I conditions that are being established in this permit
T1R	Title I Revised - identifies Title I conditions that have been carried over from an existing permit and subsequently revised in this permit
USEPA	United States Environmental Protection Agency
VOM	Volatile organic material

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

## Attachment 3 - Contact and Reporting Addresses

<p style="text-align: center;">IEPA Compliance Section</p> <p style="text-align: center;">IEPA Stack Test Specialist</p> <p style="text-align: center;">IEPA Air Quality Planning Section</p> <p style="text-align: center;">IEPA Air Regional Field Operations Regional Office #1</p> <p style="text-align: center;">IEPA Permit Section</p>	<p>Illinois EPA, Bureau of Air Compliance &amp; Enforcement Section (MC 40) 1021 North Grand Avenue East P.O. Box 19276 Springfield, Illinois 62794-9276</p> <p>Phone No.: 217/782-2113</p> <p>Illinois EPA, Bureau of Air Compliance Section Source Monitoring - Third Floor 9511 Harrison Street Des Plaines, Illinois 60016</p> <p>Phone No.: 847/294-4000</p> <p>Illinois EPA, Bureau of Air Air Quality Planning Section (MC 39) 1021 North Grand Avenue East P.O. Box 19276 Springfield, Illinois 62794-9276</p> <p>Phone No.: 217/782-2113</p> <p>Illinois EPA, Bureau of Air Regional Office #1 9511 Harrison Street Des Plaines, Illinois 60016</p> <p>Phone No.: 847/294-4000</p> <p>Illinois EPA, Bureau of Air Permit Section (MC 11) 1021 North Grand Avenue East P.O. Box 19506 Springfield, Illinois 62794-9506</p> <p>Phone No.: 217/785-1705</p>
<p style="text-align: center;">USEPA Region 5 - Air Branch</p>	<p>USEPA (AR - 17J) Air and Radiation Division 77 West Jackson Boulevard Chicago, Illinois 60604</p> <p>Phone No.: 312/353-2000</p>

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

Attachment 4 - Example Certification by a Responsible Official

<b>SIGNATURE BLOCK</b>	
<p>NOTE: THIS CERTIFICATION MUST BE SIGNED BY A RESPONSIBLE OFFICIAL. APPLICATIONS WITHOUT A SIGNED CERTIFICATION WILL BE DEEMED AS INCOMPLETE.</p>	
<p>I CERTIFY UNDER PENALTY OF LAW THAT, BASED ON INFORMATION AND BELIEF FORMED AFTER REASONABLE INQUIRY, THE STATEMENTS AND INFORMATION CONTAINED IN THIS APPLICATION ARE TRUE, ACCURATE AND COMPLETE. ANY PERSON WHO KNOWINGLY MAKES A FALSE, FICTITIOUS, OR FRAUDULENT MATERIAL STATEMENT, ORALLY OR IN WRITING, TO THE ILLINOIS EPA COMMITS A CLASS 4 FELONY. A SECOND OR SUBSEQUENT OFFENSE AFTER CONVICTION IS A CLASS 3 FELONY. (415 ILCS 5/44(H))</p>	
<p>AUTHORIZED SIGNATURE:</p>	
BY: _____	_____
AUTHORIZED SIGNATURE	TITLE OF SIGNATORY
_____	_____/_____/_____
TYPED OR PRINTED NAME OF SIGNATORY	DATE

ExxonMobil Lockport Terminal  
I.D. No.: 197810AAL  
Permit No.: 95090243

Date Received: 02/06/2007  
Date Issued: 10/24/2014

