

217/782-2113

FEDERALLY ENFORCEABLE STATE OPERATING PERMIT -- NSPS SOURCE

PERMITTEE

Equinix, LLC - CHI3
Attn: Marion Madeja
1905 Lunt Avenue
Elk Grove Village, Illinois 60007

<u>Application No.:</u> 08010054	<u>I.D. No.:</u> 031440ANI
<u>Applicant's Designation:</u> CH3 Backup Gen	<u>Date Received:</u> January 29, 2008
<u>Subject:</u> Network Neutral Data Center	
<u>Date Issued:</u>	<u>Expiration Date:</u>
<u>Location:</u> 1905 Lunt Avenue, Elk Grove Village, Cook County, 60007	

This permit is hereby granted to the above-designated Permittee to OPERATE emission unit(s) and/or air pollution control equipment consisting of:

Seventeen (17) 2,500 kW (3,634 HP) diesel-powered backup generator sets; and
Four (4) Two-celled cooling towers

as described in the above-referenced application. This Permit is subject to standard conditions attached hereto and the following special condition(s):

- 1a. This federally enforceable state operating permit is issued to limit the emissions of air pollutants from the source to less than major source thresholds (i.e., 100 tons/year for Nitrogen Oxides (NO_x)). As a result, the source is excluded from the requirements to obtain a Clean Air Act Permit Program (CAAPP) permit. The maximum emissions of this source, as limited by the conditions of this permit are described in Attachment A.
- b. Prior to issuance, a draft of this permit has undergone a public notice and comment period.
- c. This permit supersedes all operating permit(s) for this location.
- 2a. The seventeen diesel-powered backup generator sets are subject to the New Source Performance Standards (NSPS) for Stationary Compression Ignition Internal Combustion Engines, 40 CFR 60 Subparts A and IIII. The Illinois EPA is administering these standards in Illinois on behalf of the United States EPA under a delegation agreement.
 - b. Pursuant to 40 CFR 60.4205(b), owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in 40 CFR 60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE.
 - c. Pursuant to 40 CFR 60.4202(b)(1), stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power greater than

2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in 40 CFR 60.4202(b)(1) through (2). For 2007 through 2010 model years, the emission standards in table 1 to 40 CFR 60 Subpart IIII, for all pollutants, for the same maximum engine power.

Table 1 to Subpart IIII of Part 60 –Emission Standards for Stationary Pre-2007 Model Year Engines With a Displacement of <10 Liters per Cylinder and 2007-2010 Model Year Engines >2,237 KW (3,000 HP) and With a Displacement of <10 Liters per Cylinder

Emission standards for stationary pre-2007 model year engines with a displacement of <10 liters per cylinder and 2007-2010 model year engines >2,237 KW (3,000 HP) and with a displacement of <10 liters per cylinder in g/KW-hr (g/HP-hr)					
Maximum engine power	NMHC + NO _x	HC	NO _x	CO	PM
KW>560 (HP>750)		1.3 (1.0)	9.2 (6.9)	11.4 (8.5)	0.54 (0.40)

- d. Pursuant to 40 CFR 60.4206, owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in 40 CFR 60.4204 and 60.4205 according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer, over the entire life of the engine.
- 3a. Pursuant to 35 Ill. Adm. Code 212.123(a), no person shall cause or allow the emission of smoke or other particulate matter, with an opacity greater than 30 percent, into the atmosphere from any emission unit other than those emission units subject to 35 Ill. Adm. Code 212.122.
- b. Pursuant to 35 Ill. Adm. Code 212.123(b), the emission of smoke or other particulate matter from any such emission unit may have an opacity greater than 30 percent but not greater than 60 percent for a period or periods aggregating 8 minutes in any 60 minute period provided that such opaque emissions permitted during any 60 minute period shall occur from only one such emission unit located within a 305 m (1000 ft) radius from the center point of any other such emission unit owned or operated by such person, and provided further that such opaque emissions permitted from each such emission unit shall be limited to 3 times in any 24 hour period.
- 4a. Pursuant to 35 Ill. Adm. Code 214.122(b)(1), no person shall cause or allow the emission of sulfur dioxide into the atmosphere in any one hour period from any new fuel combustion source with actual heat input smaller than, or equal to, 73.2 MW (250 mmBtu/hour), burning liquid fuel exclusively to exceed 1.55 kg of sulfur dioxide per MW-hr of actual heat input when residual fuel oil is burned (0.8 lbs/mmBtu).
- b. Pursuant to 35 Ill. Adm. Code 214.301, no person shall cause or allow the emission of sulfur dioxide into the atmosphere from any process emission unit to exceed 2000 ppm.
- c. Pursuant to 35 Ill. Adm. Code 214.304, the emissions from the burning of fuel at process emission sources located in the Chicago or St. Louis (Illinois)

major metropolitan areas shall comply with applicable 35 Ill. Adm. Code 214 Subparts B through F (i.e., 35 Ill. Adm. Code 214.122).

5. Pursuant to 35 Ill. Adm. Code 218.301, no person shall cause or allow the discharge of more than 3.6 kg/hour (8 lbs/hour) of organic material into the atmosphere from any emission source, except as provided in 35 Ill. Adm. Code 218.302, 218.303, or 218.304 and the following exception: If no odor nuisance exists the limitation of 35 Ill. Adm. Code 218 Subpart G shall apply only to photochemically reactive material.
6. This permit is issued based on the seventeen diesel-powered backup generator sets not being subject to the National Emission Standard for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines, 40 CFR 63 Subpart ZZZZ. Pursuant to 40 CFR 63.6590(c)(1), a new or reconstructed stationary RICE located at an area source must meet the requirements of 40 CFR Part 63 by meeting the requirements of 40 CFR 60 Subpart IIII, for compression ignition engines or 40 CFR 60 Subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under 40 CFR Part 63.
7. Pursuant to 40 CFR 60.11(d), at all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Illinois EPA or USEPA which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.
- 8a. Pursuant to 40 CFR 60.4207(a), beginning October 1, 2007, owners and operators of stationary CI ICE subject to 40 CFR 60 Subpart IIII that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(a).
- b. Pursuant to 40 CFR 60.4207(b), beginning October 1, 2010, owners and operators of stationary CI ICE subject to 40 CFR 60 Subpart IIII with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(b) for nonroad diesel fuel.
- c. Pursuant to 40 CFR 60.4211(a), if you are an owner or operator and must comply with the emission standards specified in 40 CFR 60 Subpart IIII, you must operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer. In addition, owners and operators may only change those settings that are permitted by the manufacturer. You must also meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply to you.
- d. Pursuant to 40 CFR 60.4211(c), if you are an owner or operator of a 2007 model year and later stationary CI internal combustion engine and must comply with the emission standards specified in 40 CFR 60.4204(b) or 40 CFR 60.4205(b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to 40 CFR 60 Subpart IIII and must comply with the emission

standards specified in 40 CFR 60.4205(c), you must comply by purchasing an engine certified to the emission standards in 40 CFR 60.4204(b), or 40 CFR 60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's specifications.

- e. Pursuant to 40 CFR 60.4211(e), emergency stationary ICE may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. There is no time limit on the use of emergency stationary ICE in emergency situations. Anyone may petition the Illinois EPA or USEPA for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency ICE beyond 100 hours per year. For owners and operators of emergency engines meeting standards under 40 CFR 60.4205 but not 40 CFR 60.4204, any operation other than emergency operation, and maintenance and testing as permitted in 40 CFR 60.4011, is prohibited.

- 9a. Pursuant to 40 CFR 80.510(a), beginning June 1, 2007. Except as otherwise specifically provided in 40 CFR 80 Subpart I, all NRLM diesel fuel is subject to the following per-gallon standards:
 - i. Sulfur content. 500 parts per million (ppm) maximum.
 - ii. Cetane index or aromatic content, as follows:
 - A. A minimum cetane index of 40; or
 - B. A maximum aromatic content of 35 volume percent.

- b. Pursuant to 40 CFR 80.510(b), beginning June 1, 2010. Except as otherwise specifically provided in 40 CFR 80 Subpart I, all NR and LM diesel fuel is subject to the following per-gallon standards:
 - i. Sulfur content 15 ppm maximum for NR diesel fuel.
 - ii. Cetane index or aromatic content, as follows:
 - A. A minimum cetane index of 40; or
 - B. A maximum aromatic content of 35 volume percent.

- 10a. The diesel-powered backup generator sets shall only be operated with fuel oil grades No. 1 and 2 (i.e., diesel) as the fuel. The use of any other fuel in the diesel-powered backup generator sets requires that the Permittee first obtain a construction permit from the Illinois EPA and then perform stack testing to verify compliance with all applicable requirements.

- b. The Permittee shall only not keep, store or use distillate fuel oil (Grades No. 1 and 2) at this source with a sulfur content greater than the larger of the following values:

- i. 0.28 weight percent, or
- ii. The Wt. percent given by the formula: Maximum Wt percent sulfur = (0.000015) x (Gross heating value of oil, Btu/lb).
- c. Organic liquid by-products or waste materials shall not be used in the diesel-powered backup generator sets without written approval from the Illinois EPA.
- d. The Illinois EPA shall be allowed to sample all fuels stored at the above location.
- e. This permit is issued based on the cooling tower not using chromium-based water treatment chemicals. As a result, this permit is issued based on the source not being subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Industrial Process Cooling Towers, 40 CFR 63 Subpart Q.
- f. The cooling tower shall each be equipped, operated and maintained with drift eliminators or other comparable features designed to limit the loss of water droplets from the cooling tower to not more than 0.001% of the circulating water flow (0.00001 drift).
- 11a. Emissions and operation of the seventeen (17) diesel-powered backup generator sets will not exceed the following:
 - i. Each diesel-powered backup generator set runtime shall not exceed 500 hours/year. The total combined runtime for all seventeen diesel generator sets shall not exceed 3,910 hours/year.
 - ii. Emissions from the diesel-powered backup generator sets shall not exceed:

<u>Pollutant</u>	<u>Emissions</u>		
	<u>Emission Factor</u> (lb/HP-hr)	<u>Each Genset</u> (lb/hr)	<u>Total for All Gensets</u> (Tons/Year)
Carbon Monoxide (CO)	0.0009	3.27	6.42
Nitrogen Oxides (NO _x)	0.0112	40.70	79.10
Particulate Matter (PM)	0.0003	1.09	2.21
Sulfur Dioxide (SO ₂)	0.00044	1.60	2.87
Volatile Organic Material (VOM)	0.0003	1.09	1.57

The above emission factors are derived manufacturer's data provided in the application for units with power rating of 2,500 kW (3,634 HP) and sulfur dioxide which was calculated from standard factors (Table 3.4-1, AP-42, Fifth Edition, Volume I, Supplement B, October 1996) with a fuel sulfur content (0.05%). Emission totals shall be calculated by multiplying the diesel generator set runtime and the emission factors for each pollutant.

- b. The emissions of particulate matter (PM) from each two celled cooling tower shall not exceed 0.12 tons/year. This limit is based on information in the application indicating a nominal emission rate of 0.028 lb/hour total for each cooling tower operating at an overall design flow rate of 264,000 gallons/hr and continuous operation of the cooling towers.

- c. Compliance with annual limits shall be determined on a monthly basis from the sum of the data for the current month plus the preceding 11 months (running 12 month total).
- 12. The emission of hazardous air pollutants (HAP) as listed in Section 112(b) of the Clean Air Act from the source shall not exceed 0.90 tons/month and 9.0 tons/year of any single HAP and 2.25 tons/month and 22.5 tons/year of any combination of such HAPs. As a result of this condition, this permit is issued based on the emissions of any HAP from this source not triggering the requirement to obtain a CAAPP permit from the Illinois EPA.
- 13. This permit is issued based on each of the diesel-powered backup generator sets having a displacement of less than 30 liters per cylinder and has been certified by the manufacturer to meet the standards of 40 CFR 60 60.4202(a) through (d). As a result this permit is issued based on these diesel-powered backup generator sets not being subject to the testing requirements of 40 CFR 60.8.
- 14a. Pursuant to 35 Ill. Adm. Code 201.282, every emission source or air pollution control equipment shall be subject to the following testing requirements for the purpose of determining the nature and quantities of specified air contaminant emissions and for the purpose of determining ground level and ambient air concentrations of such air contaminants:
 - i. Testing by Owner or Operator. The Illinois EPA may require the owner or operator of the emission source or air pollution control equipment to conduct such tests in accordance with procedures adopted by the Illinois EPA, at such reasonable times as may be specified by the Illinois EPA and at the expense of the owner or operator of the emission source or air pollution control equipment. The Illinois EPA may adopt procedures detailing methods of testing and formats for reporting results of testing. Such procedures and revisions thereto, shall not become effective until filed with the Secretary of State, as required by the APA Act. All such tests shall be made by or under the direction of a person qualified by training and/or experience in the field of air pollution testing. The Illinois EPA shall have the right to observe all aspects of such tests.
 - ii. Testing by the Illinois EPA. The Illinois EPA shall have the right to conduct such tests at any time at its own expense. Upon request of the Illinois EPA, the owner or operator of the emission source or air pollution control equipment shall provide, without charge to the Illinois EPA, necessary holes in stacks or ducts and other safe and proper testing facilities, including scaffolding, but excluding instruments and sensing devices, as may be necessary.
- b. Testing required by Condition 15 shall be performed upon a written request from the Illinois EPA by a qualified independent testing service.
- 15a. Pursuant to 35 Ill. Adm. Code 212.110(c), upon a written notification by the Illinois EPA, the owner or operator of a particulate matter emission unit subject to 35 Ill. Adm. Code Part 212 shall conduct the applicable testing for particulate matter emissions, opacity, or visible emissions at such person's

own expense, to demonstrate compliance. Such test results shall be submitted to the Illinois EPA within thirty (30) days after conducting the test unless an alternative time for submittal is agreed to by the Illinois EPA.

16. Pursuant to 40 CFR 60.4209(a), if you are an owner or operator, you must meet the monitoring requirements of 40 CFR 60.4209. In addition, you must also meet the monitoring requirements specified in 40 CFR 60.4211. If you are an owner or operator of an emergency stationary CI internal combustion engine, you must install a non-resettable hour meter prior to startup of the engine.
- 17a. Pursuant to 40 CFR 60.7(f), any owner or operator subject to the provisions of 40 CFR Part 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.
 - b. Pursuant to 40 CFR 60.7(f), any owner or operator subject to the provisions of 40 CFR Part 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by 40 CFR Part 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least two years following the date of such measurements, maintenance, reports, and records.
18. Pursuant to 40 CFR 60.4214(b), if the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to 40 CFR 60 Subpart IIII, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.
19. Pursuant to 35 Ill. Adm. Code 212.110(e), the owner or operator of an emission unit subject to 35 Ill. Adm. Code Part 212 shall retain records of all tests which are performed. These records shall be retained for at least three (3) years after the date a test is performed.
- 20a. The Permittee shall maintain records of the following items so as to demonstrate compliance with the conditions of this permit:
 - i. Diesel generator sets runtime (hours/month, hours/year);
 - ii. Certification from the fuel supplier of weight percent sulfur content of each fuel shipment received;
 - iii. Amount of fuel used (gallons/month, gallons/year);
 - iv. An inspection, maintenance and repair log of the generators listing each activity performed with date;

- v. Cooling water flow rate (gallons/hour) based on representative operation of the cooling towers;
 - vi. Cooling water total dissolved solids (PM) content, based on representative sampling of water discharge;
 - vii. Total operation of cooling towers (hours/month, hours/year); and
 - viii. Monthly and annual emissions of CO, NO_x, PM, SO₂, and VOM from the source with supporting calculations (tons/month, tons/year).
- b. All records and logs required by this permit shall be retained at a readily accessible location at the source for at least five (5) years from the date of entry and shall be made available for inspection and copying by the Illinois EPA or USEPA upon request. Any records retained in an electronic format (e.g., computer storage device) shall be capable of being retrieved and printed on paper during normal source office hours so as to be able to respond to an Illinois EPA or USEPA request for records during the course of a source inspection.
21. Pursuant to 35 Ill. Adm. Code 212.110(d), a person planning to conduct testing for particulate matter emissions to demonstrate compliance shall give written notice to the Illinois EPA of that intent. Such notification shall be given at least thirty (30) days prior to the initiation of the test unless a shorter period is agreed to by the Illinois EPA. Such notification shall state the specific test methods from 35 Ill. Adm. Code 212.110 that will be used.
- 22a. If there is an exceedance of or deviation from the requirements of this permit as determined by the records required by this permit, the Permittee shall submit a report to the Illinois EPA's Compliance Section in Springfield, Illinois within 30 days after the exceedance or deviation. The report shall include the emissions released in accordance with the recordkeeping requirements, copy of the relevant records, and a description of the exceedance or deviation and efforts to reduce emissions and future occurrences.
- b. Two (2) copies of required reports and notifications shall be sent to:

Illinois Environmental Protection Agency
Division of Air Pollution Control
Compliance Section (#40)
P.O. Box 19276
Springfield, Illinois 62794-9276

and one (1) copy shall be sent to the Illinois EPA's regional office at the following address unless otherwise indicated:

Illinois Environmental Protection Agency
Division of Air Pollution Control
9511 West Harrison
Des Plaines, Illinois 60016

If you have any questions on this permit, please contact Jocelyn Stakely at 217/782-2113.

Edwin C. Bakowski, P.E.
Manager, Permit Section
Division of Air Pollution Control

Date Signed: _____

ECB:JRS:jws

cc: Illinois EPA, FOS Region 1
Lotus Notes

Attachment A - Emissions Summary

This attachment provides a summary of the maximum emissions from the Network Neutral Data Center operating in compliance with the requirements of this federally enforceable permit. In preparing this summary, the Illinois EPA used the annual operating scenario which results in maximum emissions from such a plant. These maximum emissions from the generators utilize annual fuel usage with No. 2 oil. The resulting maximum emissions are below the levels (i.e., 100 tons per year of NO_x) at which this source would be considered a major source for purposes of the Clean Air Act Permit Program. Actual emissions from this source will be less than predicted in this summary to the extent that less material is handled and control measures are more effective than required in this permit.

<u>Equipment</u>	E M I S S I O N S (Tons/Year)				
	CO	NO _x	PM	SO ₂	VOM
17 Diesel-Powered Backup Generator Sets	6.42	79.10	2.21	2.87	1.57
Four (4) Cooling Towers	--	--	0.48	--	--
Totals:	<u>6.42</u>	<u>79.10</u>	<u>2.69</u>	<u>2.87</u>	<u>1.57</u>