

217/785-1705

FEDERALLY ENFORCEABLE STATE OPERATING PERMIT - NSPS and NESHAP SOURCE --  
REVISED

PERMITTEE

Butterball, LLC  
Attn: Lankford Ruffin  
1 Butterball Lane, Post Office Box 2389  
Garner, North Carolina 27629

<u>Application No.:</u> 12100035	<u>I.D. No.:</u> 089469AAH
<u>Applicant's Designation:</u>	<u>Date Received:</u> December 2, 2013
<u>Subject:</u> Smokehouses, Cookers, Boilers, and Generators	
<u>Date Issued:</u> February 18, 2014	<u>Expiration Date:</u> September 27, 2023
<u>Location:</u> 2125 Rochester Drive, Montgomery, Kane County	

This permit is hereby granted to the above-designated Permittee to OPERATE emission source(s) and/or air pollution control equipment consisting of:

Two (2) 20.92 mmBtu/hour Natural Gas-Fired Boilers (Boiler B-1 and Boiler B-2);  
One (1) 16.733 mmBtu/hour Natural Gas-Fired Boiler (Boiler B-3) and  
Twenty-Two (22) Smoke houses (SM-1 - SM-15; SM-21 - SM-27)  
Two (2) 1,490 hp Diesel-Powered Emergency Generators (G1 and G3);  
Three (3) 2,876 hp Diesel-Powered Emergency Generators (G2, G4, and G6); and  
One (1) 1,500 hp Diesel-Powered Emergency Generators (G5);

pursuant to the above-referenced application. This Permit is subject to standard conditions attached hereto and the following special condition(s):

- 1a. This federally enforceable state operating permit is issued:
  - i. To limit the emissions of air pollutants from the source to less than major source thresholds (i.e., 100 tons/year for Nitrogen Oxides (NO<sub>x</sub>), 10 tons/year for any single Hazardous Air Pollutant (HAP), and 25 tons/year for any combination of such HAPs). As a result, the source is excluded from the requirements to obtain a Clean Air Act Permit Program (CAAPP) permit. The maximum emissions of this source, as limited by the conditions of this permit are described in Attachment A.
  - ii. To establish federally enforceable production and operating limitations, which restrict the potential to emit to less than 10 tons/year for any individual Hazardous Air Pollutant (HAP) and 25 tons/year of any combination of such HAPs so that the source is not subject to the requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Industrial, Commercial, and Institutional Boilers and Process Heaters, 40 CFR 63 Subpart DDDDD.

- iii. To limit the potential emissions of VOM from the source to less than 25 tons/year. As a result, the source is excluded from the requirement of 35 Ill. Adm. Code Part 205, Emission Reduction Market System. The maximum emissions of this source, as limited by the conditions of this permit, are described in Attachment A.
  - iv. To establish federally enforceable production and operating limitations, which restrict the potential to emit for NO<sub>x</sub> to less than 100 tons per year so that the source is not subject to the requirements of 35 Ill. Adm. Code Part 217 Subpart E (Industrial Boilers) and 35 Ill. Adm. Code Part 217 Subpart Q (Stationary Reciprocating Internal Combustion Engines And Turbines).
  - v. To establish federally enforceable production and operating limitations, which restrict the potential to emit for VOM to less than 25 tons per year so that the source is not subject to the requirements of 35 Ill. Adm. Code Part 218 Subpart TT (Other Emission Units).
- b. Prior to initial issuance, a draft of this permit has undergone a public notice and comment period.
  - c. This permit supersedes all operating permit(s) for this location.
2. Boilers B-1, B-2, and B-3 are subject to the New Source Performance Standards (NSPS) for Small Industrial-Commercial-Institutional Steam Generating Units, 40 CFR 60, Subparts A and Dc. The Illinois EPA is administering the NSPS in Illinois on behalf of the United States EPA under a delegation agreement. Pursuant to 40 CFR 60.40c(a), except as provided in 40 CFR 60.40c(d), (e), (f), and (g), the affected facility to which 40 CFR 60 Subpart Dc applies is each steam generating unit for which construction, modification, or reconstruction is commenced after June 9, 1989 and that has a maximum design heat input capacity of 29 megawatts (MW) (100 million British thermal units per hour (mmBtu/hour)) or less, but greater than or equal to 2.9 MW (10 mmBtu/hour).
- 3a. Emergency Generators G1, G2, G3, G4, G5, and G6 are subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines, 40 CFR 63 Subparts A and ZZZZ. The Illinois EPA is administering the NESHAP in Illinois on behalf of the United States EPA under a delegation agreement. Pursuant to 40 CFR 63.6590(a), an affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.
- b. Pursuant to 40 CFR 63.6595(a)(1), if you have an existing stationary RICE, excluding existing non-emergency CI stationary RICE, with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than June 15, 2007. If you have an existing non-emergency CI stationary RICE with a site rating of more

than 500 brake HP located at a major source of HAP emissions, an existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary CI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than May 3, 2013. If you have an existing stationary SI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary SI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations and operating limitations no later than October 19, 2013.

- c. Pursuant to 40 CFR 63.6603(a), if you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to 40 CFR 63 Subpart ZZZZ and the operating limitations in Table 1b and Table 2b to 40 CFR 63 Subpart ZZZZ which apply to you.

Table 2d to Subpart ZZZZ of Part 63 – Requirements for Stationary RICE Located at Area Sources of HAP Emissions

As stated in 40 CFR 63.6600 and 63.6640, you must comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

For each...	You must meet the following requirement, except during periods of startup...	During periods of startup you must
4. Emergency stationary CI RICE and black start stationary CI RICE. <sup>2</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	

<sup>1</sup> Sources have the option to utilize an oil analysis program as described in 40 CFR 63.6625(i) in order to extend the specified oil change requirement in Table 2d of 40 CFR 63 Subpart ZZZZ.

<sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Table 2d of 40 CFR 63 Subpart ZZZZ, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the

management practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable.

- d. Pursuant to 40 CFR 63.6675, emergency stationary RICE means any stationary reciprocating internal combustion engine that meets all of the criteria in 40 CFR 63.6675(1) through (3). All emergency stationary RICE must comply with the requirements specified in 40 CFR 63.6640(f) in order to be considered emergency stationary RICE. If the engine does not comply with the requirements specified in 40 CFR 63.6640(f), then it is not considered to be an emergency stationary RICE under 40 CFR Part 60 Subpart ZZZZ.
  - i. The stationary RICE is operated to provide electrical power or mechanical work during an emergency situation. Examples include stationary RICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary RICE used to pump water in the case of fire or flood, etc.
  - ii. The stationary RICE is operated under limited circumstances for situations not included in paragraph (1) of 40 CFR 63.6675, as specified in 40 CFR 63.6640(f).
  - iii. The stationary RICE operates as part of a financial arrangement with another entity in situations not included in paragraph (1) of 40 CFR 63.6675 only as allowed in 40 CFR 63.6640(f)(2)(ii) or (iii) and 40 CFR 63.6640(f)(4)(i) or (ii).
- 4a. Pursuant to 35 Ill. Adm. Code 212.123(a), no person shall cause or allow the emission of smoke or other particulate matter, with an opacity greater than 30 percent, into the atmosphere from any emission unit other than those emission units subject to 35 Ill. Adm. Code 212.122.
- b. Pursuant to 35 Ill. Adm. Code 212.123(b), the emission of smoke or other particulate matter from any such emission unit may have an opacity greater than 30 percent but not greater than 60 percent for a period or periods aggregating 8 minutes in any 60 minute period provided that such opaque emissions permitted during any 60 minute period shall occur from only one such emission unit located within a 305 meter (1000 foot) radius from the center point of any other such emission unit owned or operated by such person, and provided further that such opaque emissions permitted from each such emission unit shall be limited to 3 times in any 24 hour period.

- c. Pursuant to 35 Ill. Adm. Code 212.301, no person shall cause or allow the emission of fugitive particulate matter from any process, including any material handling or storage activity, that is visible by an observer looking generally toward the zenith at a point beyond the property line of the source.
- d. Pursuant to 35 Ill. Adm. Code 212.321(a), except as further provided in 35 Ill. Adm. Code Part 212, no person shall cause or allow the emission of particulate matter into the atmosphere in any one hour period from any new process emission unit which, either alone or in combination with the emission of particulate matter from all other similar process emission units for which construction or modification commenced on or after April 14, 1972, at a source or premises, exceeds the allowable emission rates specified in 35 Ill. Adm. Code 212.321(c).
- 5a. Pursuant to 35 Ill. Adm. Code 214.122(b)(2), no person shall cause or allow the emission of sulfur dioxide into the atmosphere in any one hour period from any new fuel combustion source with actual heat input smaller than, or equal to, 73.2 MW (250 mmBtu/hour), burning liquid fuel exclusively to exceed 0.46 kg of sulfur dioxide per MW-hour of actual heat input when distillate fuel oil is burned (0.3 lbs/mmBtu).
- b. Pursuant to 35 Ill. Adm. Code 214.301, except as further provided by 35 Ill. Adm. Code Part 214, no person shall cause or allow the emission of sulfur dioxide into the atmosphere from any process emission source to exceed 2000 ppm.
- c. Pursuant to 35 Ill. Adm. Code 214.304, the emissions from the burning of fuel at process emission sources located in the Chicago or St. Louis (Illinois) major metropolitan areas shall comply with applicable 35 Ill. Adm. Code 214 Subparts B through F (i.e., 35 Ill. Adm. Code 214.122(b)).
- d. No person shall cause or allow the emission of sulfur dioxide into the atmosphere in any one hour period from any new fuel combustion source with actual heat input smaller than, or equal to, 73.2 MW (250 mmBtu/hour), burning liquid fuel exclusively to exceed 0.46 kg of sulfur dioxide per MW-hour of actual heat input when distillate fuel oil is burned (0.3 lbs/mmBtu).
- 6. Pursuant to 35 Ill. Adm. Code 216.121, no person shall cause or allow the emission of carbon monoxide (CO) into the atmosphere from any fuel combustion emission source with actual heat input greater than 2.9 MW (10 mmBtu/hour) to exceed 200 ppm, corrected to 50 percent excess air.
- 7. Pursuant to 35 Ill. Adm. Code 218.301, no person shall cause or allow the discharge of more than 3.6 kg/hour (8 lbs/hour) of organic material into the atmosphere from any emission unit, except as provided in 35 Ill. Adm. Code 218.302, 218.303, or 218.304 and the following exception: If no odor nuisance exists the limitation of 35 Ill. Adm. Code 218 Subpart G (Use of Organic Material) shall only apply to photochemically reactive material.

- 8a. This permit is issued based on Boilers B-1, B-2, and B-3 not being subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Industrial, Commercial, and Institutional Boilers and Process Heaters, 40 CFR 63 Subpart DDDDD because Boilers B-1, B-2, and B-3 are not located at, or are part of, a major source of HAP as defined in 40 CFR 63.2 or 40 CFR 63.761.
- b. This permit is issued based on Boilers B-1, B-2, and B-3 not being subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Industrial, Commercial, and Institutional Boilers Area Sources, 40 CFR 63 Subpart JJJJJJ. Pursuant to 40 CFR 63.11195(e), a gas-fired boiler as defined in 40 CFR 63 Subpart JJJJJJ are not subject to 40 CFR 63 Subpart JJJJJJ and to any requirements in 40 CFR 63 Subpart JJJJJJ. Pursuant to 40 CFR 63.11237, gas-fired boiler includes any boiler that burns gaseous fuels not combined with any solid fuels, burns liquid fuel only during periods of gas curtailment, gas supply emergencies, or periodic testing on liquid fuel. Periodic testing of liquid fuel shall not exceed a combined total of 48 hours during any calendar year.
9. Pursuant to 35 Ill. Adm. Code 212.314, 35 Ill. Adm. Code 212.301 shall not apply when the wind speed is greater than 40.2 km/hour (25 mph). Determination of wind speed for the purposes of this rule shall be by a one-hour average or hourly recorded value at the nearest official station of the U.S. Weather Bureau or by wind speed instruments operated on the site. In cases where the duration of operations subject to this rule is less than one hour, wind speed may be averaged over the duration of the operations on the basis of on-site wind speed instrument measurements.
10. This permit is issued based on the source not being subject to 35 Ill. Adm. Code 218 Subpart TT (Other Emission Units). Pursuant to 35 Ill. Adm. Code 218.980(b)(2), a source is subject to 35 Ill. Adm. Code 218 Subpart TT if it has the potential to emit 22.7 Mg (25 tons) or more of VOM per year, in aggregate, from emission units, other than furnaces at glass container manufacturing sources and VOM leaks from components, that are not regulated by 35 Ill. Adm. Code 218 Subparts B, E, F, H, Q, R, S, T, (excluding 35 Ill. Adm. Code 218.486), V, X, Y, Z, or BB.
11. Pursuant to 40 CFR 60.11(d), at all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment, in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Illinois EPA or USEPA which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.
- 12a. Pursuant to 40 CFR 63.6605(a), you must be in compliance with the emission limitations and operating limitations in 40 CFR 63 Subpart ZZZZ that apply to you at all times.

- b. Pursuant to 40 CFR 63.6605(b), at all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Illinois EPA or USEPA which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.
- c. Pursuant to 40 CFR 63.6625(e)(3), if you own or operate an existing emergency or black start stationary RICE located at an area source of HAP emissions you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.
- d. Pursuant to 40 CFR 63.6625(f), if you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.
- e. Pursuant to 40 CFR 63.6625(h), if you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to 40 CFR 63 Subpart ZZZZ apply.
- f. Pursuant to 40 CFR 63.6625(i), if you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of Table 2c to 40 CFR 63 Subpart ZZZZ or in items 1 or 4 of Table 2d to 40 CFR 63 Subpart ZZZZ, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to 40 CFR 63 Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to 40 CFR 63 Subpart ZZZZ. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or

operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

- g. Pursuant to 40 CFR 63.6640(a), you must demonstrate continuous compliance with each emission limitation and operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to 40 CFR 63 Subpart ZZZZ that apply to you according to methods specified in Table 6 to 40 CFR 63 Subpart ZZZZ (see also Attachment D).

Table 6 to Subpart ZZZZ of Part 63 – Continuous Compliance With Emission Limitations, Operating Limitations, Work Practices, and Management Practices

As stated in 40 CFR 63.6640, you must continuously comply with the emissions and operating limitations and work or management practices as required by the following:

For each...	Complying with the requirement to:	You must demonstrate continuous compliance by...
9. Existing emergency and black start stationary RICE ≤500 HP located at a major source of HAP, existing non-emergency stationary RICE <100 HP located at a major source of HAP, existing emergency and black start stationary RICE located at an area source of HAP, existing non-emergency stationary CI RICE ≤300 HP located at an area source of HAP, existing non-emergency 2SLB stationary RICE located at an area source of HAP, existing non-emergency landfill or digester gas stationary SI RICE located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE ≤500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that operate 24 hours or less per calendar year	a. Work or Management practices	i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or  ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.

- h. Pursuant to 40 CFR 63.6640(f), if you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in 40 CFR 63.6640(f)(1) through (4). In order for the engine to be considered an emergency stationary RICE under 40 CFR Part 60 Subpart ZZZZ, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in 40 CFR 63.6640(f)(1) through (4), is prohibited. If you do not operate the engine according to the requirements in 40 CFR 63.6640(f)(1) through (4) of this section, the engine will not be considered an emergency engine under 40 CFR Part 60 Subpart ZZZZ and must meet all requirements for non-emergency engines.
- i. There is no time limit on the use of emergency stationary RICE in emergency situations.
- ii. You may operate your emergency stationary RICE for any combination of the purposes specified in 40 CFR 63.6640 (f)(2)(i) through (iii) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by 40 CFR 63.6640 (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).

  - A. Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.
  - B. Emergency stationary RICE may be operated for emergency demand response for periods in which the Reliability Coordinator under the North American Electric Reliability Corporation (NERC) Reliability Standard EOP-002-3, Capacity and Energy Emergencies (incorporated by reference, see 40 CFR 63.14), or other authorized entity as determined by the Reliability Coordinator, has declared an Energy Emergency Alert Level 2 as defined in the NERC Reliability Standard EOP-002-3.
  - C. Emergency stationary RICE may be operated for periods where there is a deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency.

iii. Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in 40 CFR 63.6640 (f) (2) of this section. Except as provided in 40 CFR 63.6640 (f) (4) (i) and (ii) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

A. Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and the power is provided only to the facility itself or to support the local distribution system.

B. The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

1. The engine is dispatched by the local balancing authority or local transmission and distribution system operator.
2. The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.
3. The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.
4. The power is provided only to the facility itself or to support the local transmission and distribution system.
5. The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution

system operator may keep these records on behalf of the engine owner or operator.

- i. Pursuant to 40 CFR 63.6665, Table 8 to 40 CFR 63 Subpart ZZZZ (see also Attachment B) shows which parts of the General Provisions in 40 CFR 63.1 through 63.15 apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with any of the requirements of the General Provisions specified in Table 8: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing stationary RICE that combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency stationary RICE, or an existing limited use stationary RICE. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in the General Provisions specified in Table 8 except for the initial notification requirements: A new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE.
- 13a. In the event that the operation of this source results in an odor nuisance, the Permittee shall take appropriate and necessary actions to minimize odors, including but not limited to, changes in raw material or installation of controls, in order to eliminate the odor nuisance.
  - b. Boilers B-1, B-2, and B-3 shall only be operated with natural gas as the fuel. The use of any other fuel in Boilers B-1, B-2, or B-3 requires that the Permittee first obtain a construction permit from the Illinois EPA and then perform stack testing to verify compliance with all applicable requirements.
  - c. Emergency Generators G1, G2, G3, G4, G5, and G6 shall only be operated with distillate fuel oil as the fuel. The use of any other fuel in Emergency Generators G1, G2, G3, G4, G5, or G6 requires that the Permittee first obtain a construction permit from the Illinois EPA and then perform stack testing to verify compliance with all applicable requirements.
  - d. The Permittee shall not keep, store or use distillate fuel oil (Grades No. 1 and 2) at this source with a sulfur content greater than the larger of the following two values:
    - i. 0.28 weight percent, or

- ii. The wt. percent given by the formula: Maximum wt. percent sulfur = (0.00015) x (Gross heating value of oil, Btu/lb).
  - e. Organic liquid by-products or waste materials shall not be used in any emission unit at this source without written approval from the Illinois EPA.
  - f. The Illinois EPA shall be allowed to sample all fuels stored at the above location.
- 14a. Operation of and emissions from the twenty-two smokehouses combined shall not exceed the following limits:
- i. Wood Chip Usage: 122.6 tons/month, 981.12 tons/year.
  - ii. Emissions from the twenty-two smokehouses:

<u>Pollutant</u>	<u>Emission Factor (Lbs/Ton)</u>	<u>Emissions (Tons/Mo)</u>	<u>(Tons/Yr)</u>
Particulate Matter (PM)	53	3.25	26.00
Volatile Organic Material (VOM)	44	2.70	21.58

These limits are based on the maximum wood chip usage and standard emission factors (Tables 9.5.2-1 and 9.5.2-2, AP-42, Fifth Edition, Volume I, Supplement A, September 1995).

- b. Operation of and emissions from Emergency Generators G1, G2, G3, G4, G5, and G6 (combined) shall not exceed the following limits:

<u>Pollutant</u>	<u>Emission Factor (Lbs/HP-Hr)</u>	<u>Emissions (Lbs/Hr)</u>	<u>(Tons/Yr)</u>
Carbon Monoxide (CO)	0.0055	72.09	14.42
Nitrogen Oxides (NO <sub>x</sub> )	0.024	314.59	62.92
Particulate Matter (PM)	0.0007	9.18	1.84
Sulfur Dioxide (SO <sub>2</sub> )	0.00809	29.69	5.94
Volatile Organic Material (VOM)	0.000705	9.24	1.85

These limits are based on the maximum fuel consumption of 13,108 hp for all six generators operating simultaneously, 400 hours/year of total operation for all six generators combined, and standard emission factors for CO, NO<sub>x</sub>, PM, SO<sub>2</sub> and VOM (Tables 3.4-1, AP-42, Fifth Edition, Volume I, Supplement F, August 2000), and sulfur content of 0.28%.

- c. Operation of and emissions from Boilers B-1, B-2, and B-3 (combined) shall not exceed the following limits:
  - i. Natural Gas Usage: 50.30 mmscf/month, 503.04 mmscf/year.
  - ii. Emissions from the combustion of natural gas:

<u>Pollutant</u>	<u>Emission Factor</u> (lbs/mmscf)	<u>Emissions</u>	
		(Tons/Mo)	(Tons/Yr)
Carbon Monoxide (CO)	84.0	2.11	21.13
Nitrogen Oxides (NO <sub>x</sub> )	100.0	2.52	25.15
Particulate Matter (PM)	7.6	0.19	1.91
Sulfur Dioxide (SO <sub>2</sub> )	0.6	0.02	0.15
Volatile Organic Material (VOM)	5.5	0.14	1.38

These limits are based on the maximum fuel usage and standard emission factors (Tables 1.4-1 and 1.4-2, AP-42, Fifth Edition, Volume I, Supplement D, July 1998).

- d. The emissions of Hazardous Air Pollutants (HAPs) as listed in Section 112(b) of the Clean Air Act from this source shall not exceed 0.9 tons/month and 9.0 tons/year of any single HAP and 2.25 tons/month and 22.5 tons/year of any combination of such HAPs. As a result of this condition, this permit is issued based on the emissions of any HAP from this source not triggering the requirement to obtain a CAAPP permit from the Illinois EPA and the NESHAP for Industrial, Commercial, and Institutional Boilers and Process Heaters, 40 CFR 63 Subpart DDDDD.
  - e. Compliance with annual limits shall be determined on a monthly basis from the sum of the data from the previous month plus the preceding 11 months (i.e., a 12 month running total).
- 15a. Pursuant to 35 Ill. Adm. Code 201.282, every emission source or air pollution control equipment shall be subject to the following testing requirements for the purpose of determining the nature and quantities of specified air contaminant emissions and for the purpose of determining ground level and ambient air concentrations of such air contaminants:
- i. Testing by Owner or Operator. The Illinois EPA may require the owner or operator of the emission source or air pollution control equipment to conduct such tests in accordance with procedures adopted by the Illinois EPA, at such reasonable times as may be specified by the Illinois EPA and at the expense of the owner or operator of the emission source or air pollution control equipment. The Illinois EPA may adopt procedures detailing methods of testing and formats for reporting results of testing. Such procedures and revisions thereto, shall not become effective until filed with the Secretary of State, as required by the APA Act. All such tests shall be made by or under the direction of a person qualified by training and/or experience in the field of air pollution testing. The Illinois EPA shall have the right to observe all aspects of such tests.
  - ii. Testing by the Illinois EPA. The Illinois EPA shall have the right to conduct such tests at any time at its own expense. Upon request of the Illinois EPA, the owner or operator of the

emission source or air pollution control equipment shall provide, without charge to the Illinois EPA, necessary holes in stacks or ducts and other safe and proper testing facilities, including scaffolding, but excluding instruments and sensing devices, as may be necessary.

- b. Testing required by Condition 16 shall be performed upon a written request from the Illinois EPA by a qualified independent testing service.
16. Pursuant to 35 Ill. Adm. Code 212.110(c), upon a written notification by the Illinois EPA, the owner or operator of a particulate matter emission unit subject to 35 Ill. Adm. Code Part 212 shall conduct the applicable testing for particulate matter emissions, opacity, or visible emissions at such person's own expense, to demonstrate compliance. Such test results shall be submitted to the Illinois EPA within thirty (30) days after conducting the test unless an alternative time for submittal is agreed to by the Illinois EPA.
- 17a. Pursuant to 40 CFR 60.7(b), any owner or operator subject to the provisions of 40 CFR Part 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.
- b. Pursuant to 40 CFR 60.7(f), any owner or operator subject to the provisions of 40 CFR Part 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by 40 CFR Part 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least two years following the date of such measurements, maintenance, reports, and records.
- 18a. i. Pursuant to 40 CFR 60.48c(g)(1), except as provided under 40 CFR 60.48c(g)(2) and (g)(3), the owner or operator of each affected facility shall record and maintain records of the amounts of each fuel combusted during each operating day.
- ii. Pursuant to 40 CFR 60.48c(g)(2), as an alternative to meeting the requirements of 40 CFR 60.48c(g)(1), the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in 40 CFR 60.48c(f) to demonstrate compliance with the SO<sub>2</sub> standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel combusted during each calendar month.

- iii. Pursuant to 40 CFR 60.48c(g)(2), as an alternative to meeting the requirements of 40 CFR 60.48c(g)(1), the owner or operator of an affected facility or multiple affected facilities located on a contiguous property unit where the only fuels combusted in any steam generating unit (including steam generating units not subject to 40 CFR 60 Subpart Dc) at that property are natural gas, wood, distillate oil meeting the most current requirements in 40 CFR 60.42c to use fuel certification to demonstrate compliance with the SO<sub>2</sub> standard, and/or fuels, excluding coal and residual oil, not subject to an emissions standard (excluding opacity) may elect to record and maintain records of the total amount of each steam generating unit fuel delivered to that property during each calendar month.
  - b. Pursuant to 40 CFR 60.48c(i), all records required under 40 CFR 60.48 shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record.
- 19. Pursuant to 40 CFR 63.10(b)(3), if an owner or operator determines that his or her stationary source that emits (or has the potential to emit, without considering controls) one or more hazardous air pollutants regulated by any standard established pursuant to Section 112(d) or (f) of the Clean Air Act, and that stationary source is in the source category regulated by the relevant standard, but that source is not subject to the relevant standard (or other requirement established under 40 CFR Part 63) because of limitations on the source's potential to emit or an exclusion, the owner or operator must keep a record of the applicability determination on site at the source for a period of 5 years after the determination, or until the source changes its operations to become an affected source, whichever comes first. The record of the applicability determination must be signed by the person making the determination and include an analysis (or other information) that demonstrates why the owner or operator believes the source is unaffected (e.g., because the source is an area source). The analysis (or other information) must be sufficiently detailed to allow the USEPA and/or Illinois EPA to make a finding about the source's applicability status with regard to the relevant standard or other requirement. If relevant, the analysis must be performed in accordance with requirements established in relevant subparts of 40 CFR Part 63 for this purpose for particular categories of stationary sources. If relevant, the analysis should be performed in accordance with USEPA guidance materials published to assist sources in making applicability determinations under Section 112 of the Clean Air Act, if any. The requirements to determine applicability of a standard under 40 CFR 63.1(b)(3) and to record the results of that determination under 40 CFR 63.10(b)(3) shall not by themselves create an obligation for the owner or operator to obtain a Title V permit.
- 20a. Pursuant to 40 CFR 63.6655(a), if you must comply with the emission and operating limitations, you must keep the records described in 40 CFR 63.6655(a)(1) through (a)(5), (b)(1) through (b)(3) and (c).

- i. A copy of each notification and report that you submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in 40 CFR 63.10(b)(2)(xiv).
  - ii. Records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment.
  - iii. Records of performance tests and performance evaluations as required in 40 CFR 63.10(b)(2)(viii).
  - iv. Records of all required maintenance performed on the air pollution control and monitoring equipment.
  - v. Records of actions taken during periods of malfunction to minimize emissions in accordance with 40 CFR 63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.
- b. Pursuant to 40 CFR 63.6655(e)(2), you must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate an existing stationary CI RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to 40 CFR 63 Subpart ZZZZ.
- c. Pursuant to 40 CFR 63.6655(f), if you own or operate any of the stationary RICE in paragraphs (f)(1) through (2) of this section, you must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engine is used for the purposes specified in 40 CFR 63.6640(f)(2)(ii) or (iii) or 40 CFR 63.6640(f)(4)(ii), the owner or operator must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation for these purposes.
- i. An existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions that does not meet the standards applicable to non-emergency engines.
  - ii. An existing emergency stationary RICE located at an area source of HAP emissions that does not meet the standards applicable to non-emergency engines.

- d. Pursuant to 40 CFR 63.6660(a), your records must be in a form suitable and readily available for expeditious review according to 40 CFR 63.10(b)(1).
  - e. Pursuant to 40 CFR 63.6660(b), as specified in 40 CFR 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.
  - f. Pursuant to 40 CFR 63.6660(c), you must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to 40 CFR 63.10(b)(1).
21. Pursuant to 35 Ill. Adm. Code 212.110(e), the owner or operator of an emission unit subject to 35 Ill. Adm. Code Part 212 shall retain records of all tests which are performed. These records shall be retained for at least three (3) years after the date a test is performed.
- 22a. The Permittee shall maintain records of the following items so as to demonstrate compliance with the conditions of this permit:
- i. Natural gas usage in Boilers B-1, B-2, and B-3, (mmscf/month and mmscf/year);
  - ii. Distillate fuel oil usage for emergency generators G1, G2, G3, G4, G5, and G6 (gallons/month and gallons/year);
  - iii. Hours of operation of the emergency generators, (hours/month and hours/year);
  - iv. The sulfur content of the distillate fuel oil used at the source (% weight), this shall be recorded for each shipment of oil delivered to the source;
  - v. Wood chip usage for the smokehouses (tons/month and tons/year); and
  - vi. Monthly and annual emissions of CO, NO<sub>x</sub>, PM, SO<sub>2</sub>, VOM and HAPs from the source with supporting calculations (tons/month and tons/year).
- b. All records and logs required by this permit shall be retained at a readily accessible location at the source for at least five (5) years from the date of entry and shall be made available for inspection and copying by the Illinois EPA or USEPA upon request. Any records retained in an electronic format (e.g., computer storage device) shall be capable of being retrieved and printed on paper during normal source office hours so as to be able to respond to an Illinois EPA or USEPA request for records during the course of a source inspection.

23. Pursuant to 40 CFR 60.7(a)(4), any owner or operator subject to the provisions of 40 CFR Part 60 shall furnish the Illinois EPA or USEPA written notification or, if acceptable to both the Illinois EPA and USEPA and the owner or operator of a source, electronic notification, as follows: A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Illinois EPA or USEPA may request additional relevant information subsequent to this notice.
- 24a. Pursuant to 40 CFR 63.6640(b), you must report each instance in which you did not meet each emission limitation or operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to 40 CFR 63 Subpart ZZZZ that apply to you. These instances are deviations from the emission and operating limitations in 40 CFR 63 Subpart ZZZZ. These deviations must be reported according to the requirements in 40 CFR 63.6650. If you change your catalyst, you must reestablish the values of the operating parameters measured during the initial performance test. When you reestablish the values of your operating parameters, you must also conduct a performance test to demonstrate that you are meeting the required emission limitation applicable to your stationary RICE.
- b. Pursuant to 40 CFR 63.6640(e), you must also report each instance in which you did not meet the requirements in Table 8 to 40 CFR 63 Subpart ZZZZ that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to 40 CFR 63 Subpart ZZZZ: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to 40 CFR 63 Subpart ZZZZ, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or reconstructed limited use stationary RICE.

- c. Pursuant to 40 CFR 63.6645(a), you must submit all of the notifications in 40 CFR 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following;
  - i. An existing stationary CI RICE located at an area source of HAP emissions.
  - ii. This requirement does not apply if you own or operate an existing stationary RICE less than 100 HP, an existing stationary emergency RICE, or an existing stationary RICE that is not subject to any numerical emission standards.
- d. Pursuant to 40 CFR 63.6645(a)(5), the notification requirements of 40 CFR 63.6645(a) do not apply to owner or operator of an existing stationary emergency RICE.
- e. Pursuant to 40 CFR 63.6650(d), for each deviation from an emission or operating limitation that occurs for a stationary RICE where you are not using a CMS to comply with the emission or operating limitations in 40 CFR 63 Subpart ZZZZ, the Compliance report must contain the information in 40 CFR 63.6650(c)(1) through (4) and the information in 40 CFR 63.6650(d)(1) and (2).
  - i. The total operating time of the stationary RICE at which the deviation occurred during the reporting period.
  - ii. Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.
- 25. Pursuant to 35 Ill. Adm. Code 212.110(d), a person planning to conduct testing for particulate matter emissions to demonstrate compliance shall give written notice to the Illinois EPA of that intent. Such notification shall be given at least thirty (30) days prior to the initiation of the test unless a shorter period is agreed to by the Illinois EPA. Such notification shall state the specific test methods from 35 Ill. Adm. Code 212.110 that will be used.
- 26. Pursuant to 35 Ill. Adm. Code 218.990, upon request by the Illinois EPA, the owner or operator of an emission unit which is exempt from the requirements of 35 Ill. Adm. Code 218 Subparts PP, QQ, RR, TT or 35 Ill. Adm. Code 218.208(b) shall submit records to the Illinois EPA within 30 calendar days from the date of the request that document that the emission unit is exempt from those requirements.
- 27a. If there is an exceedance of or a deviation from the requirements of this permit as determined by the records required by this permit, the Permittee shall submit a report to the Illinois EPA's Compliance Section in Springfield, Illinois within 30 days after the exceedance or deviation. The report shall include the emissions released in

accordance with the recordkeeping requirements, a copy of the relevant records, and a description of the exceedance or deviation and efforts to reduce emissions and future occurrences.

- b. Two (2) copies of required reports and notifications shall be sent to:

Illinois Environmental Protection Agency  
Division of Air Pollution Control  
Compliance Section (#40)  
P.O. Box 19276  
Springfield, Illinois 62794-9276

and one (1) copy shall be sent to the Illinois EPA's regional office at the following address unless otherwise indicated:

Illinois Environmental Protection Agency  
Division of Air Pollution Control  
9511 West Harrison  
Des Plaines, Illinois 60016

It should be noted that this permit has been revised to incorporate Construction Permit No. 13120001 and the 0.657 mmBtu/hour Natural Gas-Fired Pressure Washer, the 0.9498 mmBtu/hour Natural Gas-Fired Pressure Washer, and the 0.72054 mmBtu/hour Natural Gas-Fired Pressure Washer are exempt from permitting pursuant to 35 Ill. Adm. Code 201.146(i).

If you have any questions on this permit, please call Michael Dragovich at 217/785-1705.

Raymond E. Pilapil  
Acting Manager, Permit Section  
Division of Air Pollution Control

Date Signed: \_\_\_\_\_

REP:MJD:psj

cc: Illinois EPA, FOS Region 1  
Lotus Notes

Attachment A - Emission Summary

This attachment provides a summary of the maximum emissions from the source operating in compliance with the requirements of this federally enforceable permit. In preparing this summary, the Illinois EPA used the annual operating scenario which results in maximum emissions from such a plant. The resulting maximum emissions are below the levels, (e.g., 100 tons/year for NO<sub>x</sub>, 10 tons/year for any single HAP, and 25 tons/year for any combination of such HAPs) at which this source would be considered a major source for purposes of the Clean Air Act Permit Program. Actual emissions from this source will be less than predicted in this summary to the extent that less material is handled, and control measures are more effective than required in this permit.

<u>Emission Unit</u>	E M I S S I O N S (Tons/Year)						Single <u>HAP</u>	Combined <u>HAPs</u>
	<u>CO</u>	<u>NO<sub>x</sub></u>	<u>PM</u>	<u>SO<sub>2</sub></u>	<u>VOM</u>			
22 Smokehouses			26.00		21.58			
Emergency Generators G1, G2, G3, G4, G5, and G6	14.42	62.92	1.84	5.94	1.85			
Boilers B-1, B-2, and B-3	<u>21.13</u>	<u>25.15</u>	<u>1.91</u>	<u>0.15</u>	<u>1.38</u>	<u>----</u>	<u>----</u>	
Totals	35.55	88.07	29.75	6.09	24.81	9.0	22.5	

Attachment B - Table 8 to Subpart ZZZZ of Part 63—Applicability of General Provisions to Subpart ZZZZ.

As stated in 40 CFR 63.6665, you must comply with the following applicable general provisions.

General provisions citation	Subject of citation	Applies to subpart	Explanation
§63.1	General applicability of the General Provisions	Yes.	
§63.2	Definitions	Yes	Additional terms defined in 40 CFR 63.6675.
§63.3	Units and abbreviations	Yes.	
§63.4	Prohibited activities and circumvention	Yes.	
§63.5	Construction and reconstruction	Yes.	
§63.6(a)	Applicability	Yes.	
§63.6(b) (1) - (4)	Compliance dates for new and reconstructed sources	Yes.	
§63.6(b) (5)	Notification	Yes.	
§63.6(b) (6)	[Reserved]		
§63.6(b) (7)	Compliance dates for new and reconstructed area sources that become major sources	Yes.	
§63.6(c) (1) - (2)	Compliance dates for existing sources	Yes.	
§63.6(c) (3) - (4)	[Reserved]		
§63.6(c) (5)	Compliance dates for existing area sources that become major sources	Yes.	
§63.6(d)	[Reserved]		
§63.6(e)	Operation and maintenance	No.	
§63.6(f) (1)	Applicability of standards	No.	
§63.6(f) (2)	Methods for determining compliance	Yes.	
§63.6(f) (3)	Finding of compliance	Yes.	
§63.6(g) (1) - (3)	Use of alternate standard	Yes.	
§63.6(h)	Opacity and visible mission standards	No	Subpart ZZZZ does not contain opacity or visible emission standards.
§63.6(i)	Compliance extension procedures and criteria	Yes.	
§63.6(j)	Presidential compliance exemption	Yes.	

General provisions citation	Subject of citation	Applies to subpart	Explanation
§63.7(a) (1)-(2)	Performance test dates	Yes	Subpart ZZZZ contains performance test dates at 40 CFR 63.6610, 63.6611, and 63.6612.
§63.7(a) (3)	CAA section 114 authority	Yes.	
§63.7(b) (1)	Notification of performance test	Yes	Except that 40 CFR 63.7(b) (1) only applies as specified in 40 CFR 63.6645.
§63.7(b) (2)	Notification of rescheduling	Yes	Except that 40 CFR 63.7(b) (2) only applies as specified in 40 CFR 63.6645.
§63.7(c)	Quality assurance/test plan	Yes	Except that 40 CFR 63.7(c) only applies as specified in 40 CFR 63.6645.
§63.7(d)	Testing facilities	Yes.	
§63.7(e) (1)	Conditions for conducting performance tests	No.	Subpart ZZZZ specifies conditions for conducting performance tests at 40 CFR 63.6620.
§63.7(e) (2)	Conduct of performance tests and reduction of data	Yes	Subpart ZZZZ specifies test methods at 40 CFR 63.6620.
§63.7(e) (3)	Test run duration	Yes.	
§63.7(e) (4)	Administrator may require other testing under section 114 of the CAA	Yes.	
§63.7(f)	Alternative test method provisions	Yes.	
§63.7(g)	Performance test data analysis, recordkeeping, and reporting	Yes.	
§63.7(h)	Waiver of tests	Yes.	
§63.8(a) (1)	Applicability of monitoring requirements	Yes	Subpart ZZZZ contains specific requirements for monitoring at 40 CFR 63.6625.
§63.8(a) (2)	Performance specifications	Yes.	
§63.8(a) (3)	[Reserved]		
§63.8(a) (4)	Monitoring for control devices	No.	
§63.8(b) (1)	Monitoring	Yes.	
§63.8(b) (2)-(3)	Multiple effluents and multiple monitoring systems	Yes.	
§63.8(c) (1)	Monitoring system operation and maintenance	Yes.	

General provisions citation	Subject of citation	Applies to subpart	Explanation
§63.8(c) (1) (i)	Routine and predictable SSM	Yes.	
§63.8(c) (1) (ii)	SSM not in Startup Shutdown Malfunction Plan	Yes.	
§63.8(c) (1) (iii)	Compliance with operation and maintenance requirements	Yes.	
§63.8(c) (2) - (3)	Monitoring system installation	Yes.	
§63.8(c) (4)	Continuous monitoring system (CMS) requirements	Yes	Except that subpart ZZZZ does not require Continuous Opacity Monitoring System (COMS).
§63.8(c) (5)	COMS minimum procedures	No	Subpart ZZZZ does not require COMS.
§63.8(c) (6) - (8)	CMS requirements	Yes	Except that subpart ZZZZ does not require COMS.
§63.8(d)	CMS quality control	Yes.	
§63.8(e)	CMS performance evaluation	Yes	Except for 40 CFR 63.8(e) (5) (ii), which applies to COMS.
		Except that 40 CFR 63.8(e) only applies as specified in 40 CFR 63.6645.	
§63.8(f) (1) - (5)	Alternative monitoring method	Yes	Except that 40 CFR 63.8(f) (4) only applies as specified in 40 CFR 63.6645.
§63.8(f) (6)	Alternative to relative accuracy test	Yes	Except that 40 CFR 63.8(f) (6) only applies as specified in 40 CFR 63.6645.
§63.8(g)	Data reduction	Yes	Except that provisions for COMS are not applicable. Averaging periods for demonstrating compliance are specified at 40 CFR 63.6635 and 63.6640.
§63.9(a)	Applicability and State delegation of notification requirements	Yes.	
§63.9(b) (1) - (5)	Initial notifications	Yes	Except that 40 CFR 63.9(b) (3) is reserved.

General provisions citation	Subject of citation	Applies to subpart	Explanation
		Except that 40 CFR 63.9(b) only applies as specified in 40 CFR 63.6645.	
§63.9(c)	Request for compliance extension	Yes	Except that 40 CFR 63.9(c) only applies as specified in 40 CFR 63.6645.
§63.9(d)	Notification of special compliance requirements for new sources	Yes	Except that 40 CFR 63.9(d) only applies as specified in 40 CFR 63.6645.
§63.9(e)	Notification of performance test	Yes	Except that 40 CFR 63.9(e) only applies as specified in 40 CFR 63.6645.
§63.9(f)	Notification of visible emission (VE)/opacity test	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.9(g) (1)	Notification of performance evaluation	Yes	Except that 40 CFR 63.9(g) only applies as specified in 40 CFR 63.6645.
§63.9(g) (2)	Notification of use of COMS data	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.9(g) (3)	Notification that criterion for alternative to RATA is exceeded	Yes	If alternative is in use.
		Except that 40 CFR 63.9(g) only applies as specified in 40 CFR 63.6645.	
§63.9(h) (1) - (6)	Notification of compliance status	Yes	Except that notifications for sources using a CEMS are due 30 days after completion of performance evaluations. 40 CFR 63.9(h) (4) is reserved.
			Except that 40 CFR 63.9(h) only applies as specified in 40 CFR 63.6645.
§63.9(i)	Adjustment of submittal deadlines	Yes.	

General provisions citation	Subject of citation	Applies to subpart	Explanation
§63.9(j)	Change in previous information	Yes.	
§63.10(a)	Administrative provisions for recordkeeping/reporting	Yes.	
§63.10(b)(1)	Record retention	Yes.	
§63.10(b)(2)(i)-(v)	Records related to SSM	No.	
§63.10(b)(2)(vi)-(xi)	Records	Yes.	
§63.10(b)(2)(xii)	Record when under waiver	Yes.	
§63.10(b)(2)(xiii)	Records when using alternative to RATA	Yes	For CO standard if using RATA alternative.
§63.10(b)(2)(xiv)	Records of supporting documentation	Yes.	
§63.10(b)(3)	Records of applicability determination	Yes.	
§63.10(c)	Additional records for sources using CEMS	Yes	Except that 40 CFR 63.10(c)(2)-(4) and (9) are reserved.
§63.10(d)(1)	General reporting requirements	Yes.	
§63.10(d)(2)	Report of performance test results	Yes.	
§63.10(d)(3)	Reporting opacity or VE observations	No	Subpart ZZZZ does not contain opacity or VE standards.
§63.10(d)(4)	Progress reports	Yes.	
§63.10(d)(5)	Startup, shutdown, and malfunction reports	No.	
§63.10(e)(1) and (2)(i)	Additional CMS Reports	Yes.	
§63.10(e)(2)(ii)	COMS-related report	No	Subpart ZZZZ does not require COMS.
§63.10(e)(3)	Excess emission and parameter exceedances reports	Yes.	Except that 40 CFR 63.10(e)(3)(i)(C) is reserved.
§63.10(e)(4)	Reporting COMS data	No	Subpart ZZZZ does not require COMS.
§63.10(f)	Waiver for recordkeeping/reporting	Yes.	
§63.11	Flares	No.	
§63.12	State authority and delegations	Yes.	
§63.13	Addresses	Yes.	
§63.14	Incorporation by reference	Yes.	
§63.15	Availability of information	Yes.	