

217/782-2113

LIFETIME OPERATING PERMIT

PERMITTEE

Woodbine Service Garage
Attn: William J. Hayes
3625 Woodbine Street
Stockton, Illinois 61085

Application No.: 73010799
Applicant's Designation: NEWTON
Subject: Bulk Plant
Date Issued: February 7, 2000
Location: 3625 Woodbine Street, Stockton

I.D. No.: 085822AAA
Date Received: January 18, 2000
Expiration Date: See Condition 1.

This permit is hereby granted to the above-designated Permittee to OPERATE emission unit(s) and/or air pollution control equipment consisting of:

Two 12,000 Gallon Gasoline Storage Tanks

pursuant to the above-referenced application. This permit is subject to standard conditions attached hereto and the following special condition(s):

- 1a. This permit shall expire 180 days after the Illinois EPA sends a written request for the renewal of this permit.
- b. This permit shall terminate if it is withdrawn or is superseded by a revised permit.
2. Emissions and operation of the 2 storage tanks shall not exceed the following limits:

Gasoline Throughput		Volatile Organic Material Emissions	
(Gal/Mo)	(Gal/Yr)	(Lb/Hr)	(Tons/Yr)
5,000	50,000	0.27	1.2

These limits are based on standard AP-42 emission factors and maximum annual throughput. Compliance shall be determined from a running total of 12 months of data.

3. At all times the Permittee shall, to the extent practicable, maintain and operate the equipment, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions.

4. In the event that the operation of this source results in an odor nuisance, the Permittee shall take appropriate and necessary actions to minimize odors, including but not limited to, changes in raw material or installation of controls, in order to eliminate the nuisance.
5. The Illinois EPA shall be allowed to sample all fuels stored at the above location.
6. The Permittee shall maintain monthly records of the following items:
 - a. Gasoline throughput (gallon/month and gallon/year).
7. All records and logs required by this permit shall be retained at a readily accessible location at the source for at least three years from the date of entry and shall be made available for inspection and copying by the Illinois EPA upon request. Any records retained in an electronic format (e.g., computer) shall be capable of being retrieved and printed on paper during normal source office hours so as to be able to respond to an Illinois EPA request for records during the course of a source inspection.
8. If there is an exceedance of the requirements of this permit as determined by the records required by this permit, the Permittee shall submit a report to the Illinois EPA's Compliance Section in Springfield, Illinois within 30 days after the exceedance. The report shall include the emissions released in accordance with the recordkeeping requirements, a copy of the relevant records, and a description of the exceedance or violation and efforts to reduce emissions and future occurrences.
9. Two (2) copies of required reports and notifications concerning equipment operation or repairs, performance testing or a continuous monitoring system shall be sent to:

Illinois Environmental Protection Agency
Division of Air Pollution Control
Compliance Section (#40)
P.O. Box 19276
Springfield, Illinois 62794-9276

and one (1) copy shall be sent to the Illinois EPA's regional office at the following address unless otherwise indicated:

Illinois Environmental Protection Agency
Division of Air Pollution Control
5415 North University Avenue
Peoria, Illinois 61614

10. Persons with lifetime operating permits must obtain a revised permit for any of the following changes at the source:
 - a. An increase in emissions above the amount the emission unit or the source is permitted to emit;
 - b. A modification;
 - c. A change in operations that will result in the source's noncompliance with conditions in the existing permit; or
 - d. A change in ownership, company name, or address, so that the application or existing permit is not longer accurate.

It should be noted that the three 12,000 gallon distillate fuel oil #2 storage tanks and the two 2,000 gallon distillate fuel oil #1 storage tanks are exempt from state permit requirements, pursuant to 35 Ill. Adm. Code 201.146(n).

If you have any questions on this permit, please contact Randy Solomon at 217/782-2113.

Donald E. Sutton, P.E.
Manager, Permit Section
Division of Air Pollution Control

DES:RBS:psj

cc: Illinois EPA, FOS, Region 2
USEPA