

DRAFT/PROPOSED CAAPP PERMIT
October 16, 2009

217/782-2113

RENEWAL
TITLE V - CLEAN AIR ACT PERMIT PROGRAM (CAAPP) PERMIT

PERMITTEE

City of Carmi
Attn: Doug Leggett
225 East Main Street
Carmi, Illinois 62821

Application No.: 95060125

ID No.: 193010AAF

Applicant's Designation:

Date Received: June 9, 2006

Operation of: Power Plant

Date Issued: TBD

Expiration Date: TBD¹

Source Location: North Second and Shipley, Carmi, White County

Responsible Official: James T. Gaines, Mayor

This permit is hereby granted to the above-designated Permittee to OPERATE a power plant, pursuant to the above referenced permit application. This permit is subject to the conditions contained herein.

If you have any questions concerning this permit, please contact Kaushal Desai at 217/782-2113.

Edwin C. Bakowski, P.E.
Manager, Permit Section
Division of Air Pollution Control

ECB:KKD:psj

cc: Illinois EPA, FOS, Region 3

¹ Except as provided in Condition 8.7 of this permit.

TABLE OF CONTENTS

	<u>PAGE</u>
1.0 SOURCE IDENTIFICATION	4
1.1 Source	
1.2 Owner/Parent Company	
1.3 Operator	
1.4 General Source Description	
2.0 LIST OF ABBREVIATIONS/ACRONYMS USED IN THIS PERMIT	5
3.0 INSIGNIFICANT ACTIVITIES	6
3.1 Identification of Insignificant Activities	
3.2 Compliance with Applicable Requirements	
3.3 Addition of Insignificant Activities	
4.0 SIGNIFICANT EMISSION UNITS AT THIS SOURCE	8
5.0 OVERALL SOURCE CONDITIONS	9
5.1 Source Description	
5.2 Applicable Regulations	
5.3 Non-Applicability of Regulations of Concern	
5.4 Source-Wide Operational and Production Limits and Work Practices	
5.5 Source-Wide Emission Limitations	
5.6 General Recordkeeping Requirements	
5.7 General Reporting Requirements	
5.8 General Operational Flexibility/Anticipated Operating Scenarios	
5.9 General Compliance Procedures	
6.0 NOT APPLICABLE TO THIS PERMIT	15
7.0 UNIT SPECIFIC CONDITIONS	16
7.1 Unit 1: Group 1 Distillate Fuel Fired Internal Combustion Engines	
Group 2 Distillate Fuel Oil and/or Natural Gas Fired Internal Combustion Engines	
8.0 GENERAL PERMIT CONDITIONS	23
8.1 Permit Shield	
8.2 Applicability of Title IV Requirements	
8.3 Emissions Trading Programs	
8.4 Operational Flexibility/Anticipated Operating Scenarios	
8.5 Testing Procedures	
8.6 Reporting Requirements	
8.7 Obligation to Comply with Title I Requirements	

9.0	STANDARD PERMIT CONDITIONS	28
9.1	Effect of Permit	
9.2	General Obligations of Permittee	
9.3	Obligation to Allow Illinois EPA Surveillance	
9.4	Obligation to Comply with Other Requirements	
9.5	Liability	
9.6	Recordkeeping	
9.7	Annual Emissions Report	
9.8	Requirements for Compliance Certification	
9.9	Certification	
9.10	Defense to Enforcement Actions	
9.11	Permanent Shutdown	
9.12	Reopening and Reissuing Permit for Cause	
9.13	Severability Clause	
9.14	Permit Expiration and Renewal	
10.0	ATTACHMENTS	
10.1	Attachment 2 - Example Certification by a Responsible Official	1-1
10.2	Attachment 3 - Guidance on Revising This Permit	2-1
10.3	Attachment 4 - Form 199-CAAPP, Application For Construction Permit (For CAAPP Sources Only)	3-1
10.4	Attachment 5 - Guidance on Renewing This Permit	4-1

1.0 SOURCE IDENTIFICATION

1.1 Source

City of Carmi - Power Plant
North Second and Shipley
Carmi, Illinois 62821
618/382-5015

I.D. No.: 193010AAF
Standard Industrial Classification: 4911, Electric Generation

1.2 Owner/Parent Company

City of Carmi
225 East Main Street
Carmi, Illinois 62821

1.3 Operator

City of Carmi - Electric Department
225 East Main Street
Carmi, Illinois 62821

James Brock
618/382-5015

1.4 General Source Description

The City of Carmi - Power Plant is located at North Second and Shipley in the City of Carmi. The source operates engine driven electric generators. The source serves as a peaking station, generating electric power for the community and surrounding area when the normal sources of electric power are not available, due to planned repair and maintenance, unexpected breakdowns, or high levels of electricity consumption.

2.0 LIST OF ABBREVIATIONS/ACRONYMS USED IN THIS PERMIT

Act	Illinois Environmental Protection Act [415 ILCS 5/1 et seq.]
AP-42	Compilation of Air Pollutant Emission Factors, Volume 1, Stationary Point and Other Sources (and Supplements A through F), USEPA, Office of Air Quality Planning and Standards, Research Triangle Park, NC 27711
Btu	British thermal unit
CAA	Clean Air Act [42 U.S.C. Section 7401 et seq.]
CAAPP	Clean Air Act Permit Program
CAM	Compliance Assurance Monitoring
CFR	Code of Federal Regulations
ERMS	Emissions Reduction Market System
HAP	Hazardous Air Pollutant
ft ³	Cubic foot
hr	hour
IAC	Illinois Administrative Code
I.D. No.	Identification Number of Source, assigned by Illinois EPA
ILCS	Illinois Compiled Statutes
Illinois EPA	Illinois Environmental Protection Agency
KW	kilowatts
lb	pound
mmBtu	Million British thermal units
mo	month
NESHAP	National Emission Standards for Hazardous Air Pollutants
NO _x	Nitrogen Oxides
NSPS	New Source Performance Standards
PM	Particulate Matter
PM ₁₀	Particulate matter with an aerodynamic diameter less than or equal to a nominal 10 microns as measured by applicable test or monitoring methods
ppm	parts per million
PSD	Prevention of Significant Deterioration
RMP	Risk Management Plan
SO ₂	Sulfur Dioxide
T1	Title I - identifies Title I conditions that have been carried over from an existing permit
T1N	Title I New - identifies Title I conditions that are being established in this permit
T1R	Title I Revised - identifies Title I conditions that have been carried over from an existing permit and subsequently revised in this permit
USEPA	United States Environmental Protection Agency
VOM	Volatile Organic Material
yr	year

3.0 INSIGNIFICANT ACTIVITIES

3.1 Identification of Insignificant Activities

The following activities at the source constitute insignificant activities as specified in 35 IAC 201.210:

- 3.1.1 Activities determined by the IEPA to be insignificant activities, pursuant to 35 IAC 201.210(a)(1) and 201.211, as follows:

None

- 3.1.2 Activities that are insignificant activities based upon maximum emissions, pursuant to 35 IAC 201.210(a)(2) or (a)(3), as follows:

None

- 3.1.3 Activities that are insignificant activities based upon their type or character, pursuant to 35 IAC 201.210(a)(4) through (18), as follows:

Storage tanks of virgin or re-refined distillate oil

Emergency generator with power output less than 150 horsepower

Boiler/heaters, each with heat input less than 1.0 mmBtu/hr that fire only oil or oil in combination with only natural gas, propane or liquefied petroleum gas

- 3.1.4 Activities that are considered insignificant activities pursuant to 35 IAC 201.210(b).

3.2 Compliance with Applicable Requirements

Insignificant activities are subject to applicable requirements notwithstanding status as insignificant activities. In particular, in addition to regulations of general applicability, such as 35 IAC 212.301 and 212.123 (Condition 5.2.2), the Permittee shall comply with the following requirements, as applicable:

- 3.2.1 For each cold cleaning degreaser, the Permittee shall comply with the applicable equipment and operating requirements of 35 IAC 215.182, 218.182, or 219.182.

- 3.2.2 For each particulate matter process emission unit, the Permittee shall comply with the applicable particulate matter emission limit of 35 IAC 212.321 or 212.322. For example, the particulate matter emissions from a process emission unit shall not exceed 0.55 pounds per hour if the

emission unit's process weight rate is 100 pounds per hour or less, pursuant to 35 IAC 266.110.

- 3.2.3 For each organic material emission unit that uses organic material, e.g., a mixer or printing line, the Permittee shall comply with the applicable VOM emission limit of 35 IAC 215.301, 218.301, or 219.301, which requires that organic material emissions not exceed 8.0 pounds per hour or do not qualify as photochemically reactive material as defined in 35 IAC 211.4690.

3.3 Addition of Insignificant Activities

- 3.3.1 The Permittee is not required to notify the Illinois EPA of additional insignificant activities present at the source of a type that is identified in Condition 3.1, until the renewal application for this permit is submitted, pursuant to 35 IAC 201.212(a).
- 3.3.2 The Permittee must notify the Illinois EPA of any proposed addition of a new insignificant activity of a type addressed by 35 IAC 201.210(a) and 201.211 other than those identified in Condition 3.1, pursuant to Section 39.5(12)(b) of the Act.
- 3.3.3 The Permittee is not required to notify the Illinois EPA of additional insignificant activities present at the source of a type identified in 35 IAC 201.210(b).

4.0 SIGNIFICANT EMISSION UNITS AT THIS SOURCE

Emission Group	Description	Unit Designation (Model No./Serial No.)	Rated Design Capacity (mmBtu/Hr)	Date Constructed	Emission Control Equipment
Group 1	Internal Combustion Engines Fired with Distillate Fuel Oil Only	Engine No. 5 (33D16/816513)	6.6	1939	None
		Engine No. 7 (33F16/911564)	10.6	1948	None
Group 2	Internal Combustion Engines Fired Either with Distillate Fuel Oil or a Combination of Distillate Fuel Oil and Natural Gas	Engine No. 5 (33F16/869724)	7.9	1945	None
		Engine No. 8 (33D16/930299)	12.3	1950	None
		Engine No. 9 (DGR38/58024)	17.8	1958	None
		Engine No. 10 (DSGR38/58025)	16.3	1958	None
		Engine No. 11 (DSGRV-12/63051)	25.8	1958	None
		Engine No. 12 (33TDD/38D867010TDSFM12)	22.3	1967	None
		Engine No. 13 (FSG-1320-HSC/1030-1309)	41.4	1973	None

5.0 OVERALL SOURCE CONDITIONS

5.1 Source Description

- 5.1.1 This permit is issued based on the source requiring a CAAPP permit as a major source of nitrogen oxides (NO) emissions for purposes of CAAPP, i.e., a source with the potential to emit 100 tons per year or more of NO_x.
- 5.1.2 This permit is issued based on the source not being a major source of HAPs.

5.2 Applicable Regulations

- 5.2.1 Specific emission units at this source are subject to particular regulations as set forth in Section 7 (Unit-Specific Conditions) of this permit.
- 5.2.2 In addition, emission units at this source are subject to the following regulations of general applicability:
 - a. No person shall cause or allow the emission of fugitive particulate matter from any process, including any material handling or storage activity, that is visible by an observer looking generally overhead at a point beyond the property line of the source unless the wind speed is greater than 40.2 kilometers per hour (25 miles per hour), pursuant to 35 IAC 212.301 and 212.314.
 - b. No person shall cause or allow the emission of smoke or other particulate matter, with an opacity greater than 30 percent, into the atmosphere from any emission unit other than those emission units subject to the requirements of 35 IAC 212.122, pursuant to 35 IAC 212.123(a), except as allowed by 35 IAC 212.123(b) and 212.124.
 - c. No person shall cause or allow the emissions of sulfur dioxide into the atmosphere from any process emission unit to exceed 2,000 ppmv pursuant to 35 IAC 214.301.

5.2.3 Ozone Depleting Substances

The Permittee shall comply with the standards for recycling and emissions reduction of ozone depleting substances pursuant to 40 CFR Part 82, Subpart F, except as provided for motor vehicle air conditioners in Subpart B of 40 CFR Part 82:

- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to 40 CFR 82.156.

- b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
 - c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.
- 5.2.4
- a. Should this stationary source become subject to a regulation under 40 CFR Parts 60, 61, or 63, or 35 IAC after the date issued of this permit, then the owner or operator shall, in accordance with the applicable regulation(s), comply with the applicable requirements by the date(s) specified and shall certify compliance with the applicable requirements of such regulation(s) as part of the annual compliance certification, as required by 40 CFR Part 70 or 71.
 - b. No later than upon the submittal for renewal of this permit, the owner or operator shall submit, as part of an application, the necessary information to address either the non-applicability of, or demonstrate compliance with all applicable requirements of any potentially applicable regulation which was promulgated after the date issued of this permit.
- 5.2.5 Episode Action Plan
- a. If the source is required to have an episode action plan pursuant to 35 IAC 244.142, the Permittee shall maintain at the source and have on file with the Illinois EPA a written episode action plan (plan) for reducing the levels of emissions during yellow alerts, red alerts, and emergencies, consistent with safe operating procedures. The plan shall contain the information specified in 35 IAC 244.144.
 - b. The Permittee shall immediately implement the appropriate steps described in this plan should an air pollution alert or emergency be declared.
 - c. If a change occurs at the source which requires a revision of the plan (e.g., operational change, change in the source contact person), a copy of the revised plan shall be submitted to the Illinois EPA for review within 30 days of the change. Such plans shall be further revised if disapproved by the Illinois EPA.

- d. For sources required to have a plan pursuant to 35 IAC 244.142, a copy of the original plan and any subsequent revisions shall be sent to:
 - i. Illinois EPA, Compliance Section; and
 - ii. For sources located in Cook County and outside of the city of Chicago: Cook County Department of Environmental Control; or
 - iii. For sources located within the city of Chicago: Chicago Department of Environmental Control.

5.3 Non-Applicability of Regulations of Concern

N/A

5.4 Source-Wide Operational and Production Limits and Work Practices

In addition to the source-wide requirements in the Standard Permit Conditions in Section 9, the Permittee shall fulfill the following source-wide operational and production limitations and/or work practice requirements:

None

5.5 Source-Wide Emission Limitations

5.5.1 Permitted Emissions for Fees

The annual emissions from the source, not considering insignificant activities as addressed by Section 3.0 of this permit, shall not exceed the following limitations. The overall source emissions shall be determined by adding emissions from all emission units. Compliance with these limits shall be determined on a calendar year basis. These limitations (Condition 5.5.1) are set for the purpose of establishing fees and are not federally enforceable.

Permitted Emissions of Regulated Pollutants

Pollutant	Tons/Year
Volatile Organic Material (VOM)	14
Sulfur Dioxide (SO ₂)	4
Particulate Matter (PM)	7
Nitrogen Oxides (NO _x)	226
HAP, not included in VOM or PM	---
Total	251

- The Permittee has determined its emissions for purposes of fees based on 10% of the theoretical

capacity of the source, even though this is much greater than the normal annual operation of this peaking station, which is on the order of less than 1% of the theoretical capacity. The source has set its permitted emissions at this higher level to satisfy its obligation for availability of reserve electrical generating capacity.

Compliance with annual limits shall be determined on a monthly basis from the sum of the data for the current month plus the preceding 11 months (running 12 month total).

5.5.2 Other Source-Wide Emission Limitations

Other source-wide emission limitations are not set for this source pursuant to either the federal rules for Prevention of Significant Deterioration (PSD), 40 CFR 52.21, Illinois EPA rules for Major Stationary Sources Construction and Modification, 35 IAC Part 203, or Section 502(b)(10) of the CAA.

5.6 General Recordkeeping Requirements

5.6.1 Emission Records

- a. The Permittee shall maintain records of the following items for the source to demonstrate compliance with Condition 5.5.1, pursuant to Section 39.5(7)(b) of the Act:

Total annual emissions on a calendar year basis for the emission units covered by Section 7 (Unit Specific Conditions) of this permit.

- b. Total emissions of each, NO_x, SO₂, VOM, and PM in tons/mo with supporting calculations.

5.6.2 Fuel Records

- a. The Permittee shall maintain the records of, amount of fuel oil (in gal) and sulfur content for each shipment of fuel oil received
- b. The Permittee shall maintain records of the sulfur content of the fuel oil supply to the engines, based on the weighted average of material in the storage tank, or the sulfur content of the supply shall be assumed to be the highest sulfur content in any shipment in the tank.

- c. The Permittee shall maintain monthly records of the following items so as to demonstrate compliance with the limits in Condition 5.5:
 - i. Total usage of fuel oil for the engines, gal/mo;
 - ii. Total usage of natural gas for the engines, million scf/mo;
 - iii. Usage of fuel oil for Group 2 engines, gal/mo, as determined from fuel oil usage logs, or calculated from the usage of natural gas, i.e., approximated by the amount of fuel oil that would be used in conjunction with the total amount of natural gas used (gallons of fuel oil/scf of natural gas), with supporting calculations;
 - iv. Usage of fuel oil for Group 1 engines, determined as the total usage (Item i.) less usage for Group 2 engines (Item iii.); and

5.6.3 General Records for Operating Scenarios

None

5.6.4 Retention and Availability of Records

- a. All records and logs required by this permit shall be retained for at least five years from the date of entry (unless a longer retention period is specified by the particular recordkeeping provision), shall be kept at a location at the source that is readily accessible to the IEPA, and shall be made available for inspection and copying by the IEPA and USEPA upon request.
- b. Any records retained in an electronic format (e.g., computer) shall be capable of being retrieved and printed on paper during normal source office hours so as to be able to respond to an IEPA request for records during the course of a source inspection.

5.7 General Reporting Requirements

5.7.1 General Source-Wide Reporting Requirements

The Permittee shall promptly notify the Illinois EPA, Compliance Section, of deviations of the source with the permit requirements as follows, pursuant to Section 39.5(7)(f)(ii) of the Act. Reports shall describe the probable cause of such deviations, and any corrective actions or preventive measures taken.

5.7.2 Annual Emissions Report

The annual emissions report required pursuant to Condition 9.7 shall contain emissions information for the previous calendar year.

5.8 General Operational Flexibility/Anticipated Operating Scenarios

None

5.9 General Compliance Procedures

5.9.1 General Procedures for Calculating Emissions

Compliance with the source-wide emission limits specified in Condition 5.5 shall be based on the recordkeeping requirements of Conditions 5.6 and 5.7, and compliance procedures in Section 7 (Unit Specific Conditions) of this permit.

6.0 NOT APPLICABLE TO THIS PERMIT

7.0 UNIT SPECIFIC CONDITIONS

7.1 Unit 1

Group 1: Internal combustion engines fired with distillate fuel Only

Group 2: Internal combustion engines fired with distillate fuel oil only or a combination of distillate fuel oil and natural gas

7.1.1 Description

The Permittee operates internal combustion engines for electric generation that are only fired with distillate fuel oil (Group 1) or are dual fuel fired (Group 2) used for peak electric generation or emergency electric generation. In addition to actual operation to generate electricity, each engine must be periodically "exercised" to confirm the engine will operate when needed to generate electricity.

7.1.2 List of Emission Units and Air Pollution Control Equipment

Unit 1 Group No.	Engine No.	Description	Emission Control Equipment
Group 1	Engine #5	Fairbanks-Morse 33D16	None
	Engine #7	Fairbanks-Morse 33F16	None
Group 2	Engine #5	Fairbanks-Morse 33F16	None
	Engine #8	Fairbanks-Morse 33D16	None
	Engine #9	Enterprise DGSR38	None
	Engine #10	Enterprise DGSR38	None
	Engine #11	Enterprise DGSRV-12	None
	Engine #12	Fairbanks-Morse 38TDD	None
	Engine #13	Norberg FSG-1320-HSC	None

7.1.3 Applicability Provisions and Applicable Regulations

- a. An "affected" engine for the purpose of these unit specific conditions is an engine which is only fired with distillate fuel oil (Group 1) or are dual fuel fired (Group 2). As of the "date issued" as shown on page 1 of this permit, the affected engines are identified in Condition 7.1.2.
- b. Each affected engine is subject to the emission limits identified in Conditions 5.2.2, 5.5.1, and 5.5.2.
- c. Startup Provisions

The Permittee is authorized to operate an affected engine with emissions in excess of the applicable

limit of Condition 5.2.2(b) (i.e., 35 IAC 212.123) during startup pursuant to 35 IAC 201.262, as the Permittee has affirmatively demonstrated that all reasonable efforts have been made to minimize startup emissions, duration of individual starts, and frequency of startups. This authorization is subject to the following:

- i. This authorization only extends for a period of up to two-hours following initial firing of fuel during each startup event.
- ii. The Permittee shall take the following measures to minimize startup emissions, the duration of startups and minimize the frequency of startups:
 - A. Implementation of established startup procedures, including preheating an engine prior to startup when sufficient time is available; and
 - B. Operating the engines as peaking units.
- iii. The Permittee shall fulfill applicable recordkeeping and reporting requirements of Condition 7.1.9(b) and 7.1.10(b).

7.1.4 Non-Applicability of Regulations of Concern

- a. This permit is issued based on affected engines not being subject to the requirements of 35 IAC 212.321 or 212.322 because a process weight rate weight cannot be set for the affected engine so that such rules can reasonably be applied.
- b. This permit is issued based on the affected engines not being subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources, because the affected engines do not use an add-on control device to achieve compliance with an emission limitation or standard.
- c. The affected engines are not subject to the New Source Performance Standards (NSPS) for Compression Ignition Internal Combustion Engines, 40 CFR Part 60, Subpart IIII, because the Permittee did not commence construction (date that construction commences is the date the engine is ordered by the Permittee) of the affected engines after July 11, 2005.
- d. The affected engines are excluded from the requirements of the National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating

Internal Combustion Engines 40 CFR Part 63, Subpart ZZZZ, because the affected engines are existing compression ignition (CI) stationary RICE, pursuant to 40 CFR 63.6590(b)(3).

7.1.5 Operational and Production Limits and Work Practices

None

7.1.6 Emission Limitations

Other than Conditions 5.2.2 and the source wide emission limitations in Condition 5.5, the affected engines are not subject to any specific emission limitations.

7.1.7 Testing Requirements

- a. Within 45 days of a written request by the Illinois EPA, the Permittee shall have the opacity of an affected engine determined by a certified observer in accordance with USEPA Test Method 9 during representative operating conditions of the engine as specified by the Illinois EPA. The Illinois EPA may require such observations if, based on its observations if the engine opacity does not comply with 35 IAC 212.123, or the affected engine is poorly maintained or operated so as to make compliance with 35 IAC 212.123 uncertain.
- b.
 - i. The Permittee shall notify the Illinois EPA at least 15 days in advance of the date and time of observations, in order to allow the Illinois EPA to witness the observations. This notification shall include the name and employer of the certified observer(s) and identify any concerns for successful completion of observations, i.e., lack of suitable point for proper observation or inability to conduct observations under specified conditions;
 - ii. The Permittee shall promptly notify the Illinois EPA of any changes in the date and time of observation; and
 - iii. The Permittee shall provide a copy of its observer's readings to the Illinois EPA at the time of observations, if Illinois EPA personnel are present at the conclusion of observations.
- c. The Permittee shall submit a written report for these observations within 15 days of the date of observation. This report shall include:

- i. Date, place, and time of observations;
- ii. Name and employer of certified observer;
- iii. Copy of current certification;
- iv. Description of observation conditions;
- v. Description of engine operating conditions;
- vi. Raw data;
- vii. Opacity determination; and
- viii. Conclusion.

7.1.8 Monitoring Requirements

None

7.1.9 Recordkeeping Requirements

- a. In addition to the records required by Condition 5.6, the Permittee shall maintain records of the following items for each affected engine to demonstrate compliance with conditions 5.2.2 and 5.5.1 pursuant to Section 39.5(7)(b) of the Act:

- i. The maximum sulfur content of fuel oil that may be burned in the engine and comply with Condition 5.2.2(c), with supporting calculations;
- ii. Operation of an engine with an oil in excess of this sulfur content (as recorded pursuant to Condition 7.1.9(a)), as determined from the records required by Condition 5.6.1, with date duration, sulfur content of oil, and explanation; and
- iii. Operation of an engine following the end of startup or two hours of operation, whichever occurs first, with opacity above normal, with explanation, whether opacity may have exceeded the limits of Condition 5.2.2(b), and duration of operation until achievement of normal opacity or shutdown.

- b. Records for Startup

The Permittee shall maintain the following records, pursuant to Section 39.5(7)(b) of the Act:

- i. Records for each startup of an affected engine, that, as a minimum, shall include:
 - A. Date and type of startup, i.e., exercise of engine or startup to generate electricity;
 - B. Duration of the startup, i.e., start time and time startup discontinued or normal operation achieved, i.e., stable operation at load;
 - C. The nature of opacity, i.e., severity and duration, during the startup and the nature of opacity at the conclusion of startup, if above normal;
 - D. Whether exceedance of Condition 5.2.2(b) may have occurred during startup, with explanation and estimated duration (minutes);
 - E. For startup to generate electricity: if normal operation was not achieved within 1 hour, an explanation why startup could not be achieved in one hour; a detailed description of the startup, including reason for operation and whether preheat or reduced loading was performed; and an explanation why preheat, reduced loading, and other established startup procedures could not be performed, if not performed;
- ii. A maintenance and repair log for each affected engine, listing each activity performed with date.

7.1.10 Reporting Requirements

a. Notifications

The Permittee shall promptly notify the Illinois EPA, of deviations of an affected engine with the permit requirements as follows, pursuant to Section 39.5(7)(f)(ii) of the Act. Reports shall describe the probable cause of such deviations, and any corrective actions or preventive measures taken:

- i. Notification within 60 days of operation of an affected engine that may not have been compliance with the opacity limitations in Condition 5.2.2(b), other than during startup as addressed by Condition 7.1.3(c), as determined from the records required by

Condition 7.1.9(b), with a copy of such record for each incident; and

- ii. Notification within 30 days of any operation of an affected engine that is not in compliance with the SO₂ emission limitations in Conditions 5.2.2(c), as determined from the records required by Condition 5.6.1 and 7.1.9(a) and (b), with a copy of such records for each incident.

b. Reporting for Startups of Engines

The Permittee shall provide an annual report, submitted with the Annual Emission Report, to the Illinois EPA, pursuant to Section 39.5(7)(b) of the Act, concerning startup of engines subject to Condition 7.1. At a minimum, this report shall include:

- i. For each engine, the total number of startups to generate electricity and the total number of such startups that may have resulted in opacity in excess of Condition 5.2.2(b) (i.e., 35 IAC 212.123); and
- ii. For each engine, the estimated duration of excess opacity during startup, minutes/year.

c. Reporting for Changes Made in Accordance with Operation Flexibility

The Permittee shall notify the Illinois EPA, within 30 days of any change in the type of fuel routinely combusted in a Group 2 engine as allowed in accordance with the Operational Flexibility provisions of Condition 7.1.11.

For the purpose of this reporting requirement, the periodic firing of distillate fuel oil to confirm that an engine is able to start or the firing of distillate fuel oil when the natural gas supply is interrupted shall not be considered a change in the type of fuel routinely combusted. Operation of a dual-fuel engine solely on distillate fuel oil in other circumstances, or the subsequent return to dual-fuel operation shall be considered a change in the type of fuel routinely combusted.

7.1.11 Operational Flexibility/Anticipated Operating Scenarios

The Permittee is authorized to make the following physical or operational change with respect to affected engines without prior notification to the IEPA or revision of this permit. This condition does not affect the Permittee's

obligation to properly obtain a construction permit in a timely manner for any activity constituting construction or modification of the source, as defined in 35 IAC 201.102:

a. Group 1 Engines

None

b. Group 2 Engines

Changes in the type of fuel combusted in affected engines from a combination of distillate fuel oil and natural gas to distillate fuel oil only.

7.1.12 Compliance Procedures

None

8.0 GENERAL PERMIT CONDITIONS

8.1 Permit Shield

Pursuant to Section 39.5(7)(j) of the Act, the Permittee has requested and has been granted a permit shield. This permit shield provides that compliance with the conditions of this permit shall be deemed compliance with applicable requirements which were applicable as of the date the proposed permit for this source was issued, provided that either the applicable requirements are specifically identified within this permit, or the Illinois EPA, in acting on this permit application, has determined that other requirements specifically identified are not applicable to this source and this determination (or a concise summary thereof) is included in this permit.

This permit shield does not extend to applicable requirements which are promulgated after October 12, 2009 (the date of issuance of the draft permit) unless this permit has been modified to reflect such new requirements.

8.2 Applicability of Title IV Requirements (Acid Deposition Control)

This source is not an affected source under Title IV of the CAA and is not subject to requirements pursuant to Title IV of the CAA.

8.3 Emissions Trading Programs

No permit revision shall be required for increases in emissions allowed under any USEPA approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for elsewhere in this permit and that are authorized by the applicable requirement [Section 39.5(7)(o)(vii) of the Act].

As of the date of issuance of this permit, there are no such economic incentive, marketable permit or emission trading programs that have been approved by USEPA.

8.4 Operational Flexibility/Anticipated Operating Scenarios

8.4.1 Changes Specifically Addressed by Permit

Physical or operational changes specifically addressed by the Conditions of this permit that have been identified as not requiring Illinois EPA notification may be implemented without prior notice to the Illinois EPA.

8.4.2 Changes Requiring Prior Notification

The Permittee is authorized to make physical or operational changes that contravene express permit terms without applying for or obtaining an amendment to this

permit, provided that [Section 39.5(12)(a)(i) of the Act]:

- a. The changes do not violate applicable requirements;
- b. The changes do not contravene federally enforceable permit terms or conditions that are monitoring (including test methods), recordkeeping, reporting, or compliance certification requirements;
- c. The changes do not constitute a modification under Title I of the CAA;
- d. Emissions will not exceed the emissions allowed under this permit following implementation of the physical or operational change; and
- e. The Permittee provides written notice to the Illinois EPA, Division of Air Pollution Control, Permit Section, at least 7 days before commencement of the change. This notice shall:
 - i. Describe the physical or operational change;
 - ii. Identify the schedule for implementing the physical or operational change;
 - iii. Provide a statement of whether or not any New Source Performance Standard (NSPS) is applicable to the physical or operational change and the reason why the NSPS does or does not apply;
 - iv. Provide emission calculations which demonstrate that the physical or operational change will not result in a modification; and
 - v. Provide a certification that the physical or operational change will not result in emissions greater than authorized under the Conditions of this permit.

8.5 Testing Procedures

Tests conducted to measure composition of materials, efficiency of pollution control devices, emissions from process or control equipment, or other parameters shall be conducted using standard test methods. Documentation of the test date, conditions, methodologies, calculations, and test results shall be retained pursuant to the recordkeeping procedures of this permit. Reports of any tests conducted as required by this permit or as the result of a request by the Illinois EPA shall be submitted as specified in Condition 8.6.

8.6 Reporting Requirements

8.6.1 Monitoring Reports

If monitoring is required by any applicable requirements or conditions of this permit, a report summarizing the required monitoring results, as specified in the conditions of this permit, shall be submitted to the Air Compliance Section of the Illinois EPA every six months as follows [Section 39.5(7)(f) of the Act]:

<u>Monitoring Period</u>	<u>Report Due Date</u>
January - June	September 1
July - December	March 1

All instances of deviations from permit requirements must be clearly identified in such reports. All such reports shall be certified in accordance with Condition 9.9.

8.6.2 Test Notifications

Unless otherwise specified elsewhere in this permit, a written test plan for any test required by this permit shall be submitted to the Illinois EPA for review at least 60 days prior to the testing pursuant to Section 39.5(7)(a) of the Act. The notification shall include at a minimum:

- a. The name and identification of the affected unit(s);
- b. The person(s) who will be performing sampling and analysis and their experience with similar tests;
- c. The specific conditions under which testing will be performed, including a discussion of why these conditions will be representative of maximum emissions and the means by which the operating parameters for the source and any control equipment will be determined;
- d. The specific determination of emissions and operation which are intended to be made, including sampling and monitoring locations;
- e. The test method(s) which will be used, with the specific analysis method, if the method can be used with different analysis methods;
- f. Any minor changes in standard methodology proposed to accommodate the specific circumstances of testing, with justification; and

- g. Any proposed use of an alternative test method, with detailed justification.

8.6.3 Test Reports

Unless otherwise specified elsewhere in this permit, the results of any test required by this permit shall be submitted to the Illinois EPA within 60 days of completion of the testing. The test report shall include at a minimum [Section 39.5(7)(e)(i) of the Act]:

- a. The name and identification of the affected unit(s);
- b. The date and time of the sampling or measurements;
- c. The date any analyses were performed;
- d. The name of the company that performed the tests and/or analyses;
- e. The test and analytical methodologies used;
- f. The results of the tests including raw data, and/or analyses including sample calculations;
- g. The operating conditions at the time of the sampling or measurements; and
- h. The name of any relevant observers present including the testing company's representatives, any Illinois EPA or USEPA representatives, and the representatives of the source.

8.6.4 Reporting Addresses

- a. The following addresses should be utilized for the submittal of reports, notifications, and renewals:
 - i. Illinois EPA - Air Compliance Section
Illinois Environmental Protection Agency
Bureau of Air
Compliance Section (MC 40)
P.O. Box 19276
Springfield, Illinois 62794-9276
 - ii. Illinois EPA - Air Regional Field Office
Illinois Environmental Protection Agency
Division of Air Pollution Control
2009 Mall Street
Collinsville, Illinois 62234

iii. Illinois EPA - Air Permit Section

Illinois Environmental Protection Agency
Division of Air Pollution Control
Permit Section (MC 11)
P.O. Box 19506
Springfield, Illinois 62794-9506

iv. USEPA Region 5 - Air Branch

USEPA (AE - 17J)
Air & Radiation Division
77 West Jackson Boulevard
Chicago, Illinois 60604

- b. Unless otherwise specified in the particular provision of this permit, reports shall be sent to the Illinois EPA - Air Compliance Section with a copy sent to the Illinois EPA - Air Regional Field Office.

8.7 Obligation to Comply with Title I Requirements

Any term, condition, or requirement identified in this permit by T1, T1R, or T1N is established or revised pursuant to title I provisions and is included in this permit pursuant to both Section 39.5 of the Act and Title I provisions of the CAA. Notwithstanding the expiration date on the first page of this permit, the Title I conditions remain in effect pursuant to Title I provisions until the Illinois EPA deletes or revises them in accordance with Title I procedures.

9.0 STANDARD PERMIT CONDITIONS

9.1 Effect of Permit

9.1.1 The issuance of this permit does not release the Permittee from compliance with State and Federal regulations which are part of the Illinois State Implementation Plan, as well as with other applicable statutes and regulations of the United States or the State of Illinois or applicable ordinances, except as specifically stated in this permit and as allowed by law and rule [Section 39.5(7)(j)(iv) of the Act].

9.1.2 In particular, this permit does not alter or affect the following:

- a. The provisions of Section 303 (emergency powers) of the CAA, including USEPA's authority under that Section;
- b. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
- c. The applicable requirements of the acid rain program consistent with Section 408(a) of the CAA; and
- d. The ability of USEPA to obtain information from a source pursuant to Section 114 (inspections, monitoring, and entry) of the CAA.

9.1.3 Notwithstanding the conditions of this permit specifying compliance practices for applicable requirements, any person (including the Permittee) may also use other credible evidence to establish compliance or noncompliance with applicable requirements.

9.2 General Obligations of Permittee

9.2.1 Duty to Comply

The Permittee must comply with all terms and conditions of this permit. Any permit noncompliance constitutes a violation of the CAA and the Act, and is grounds for any or all of the following: enforcement action, permit termination, revocation and reissuance, modification, or denial of a permit renewal application [Section 39.5(7)(o)(i) of the Act].

The Permittee shall meet applicable requirements that become effective during the permit term in a timely manner unless an alternate schedule for compliance with the applicable requirement is established.

9.2.2 Duty to Maintain Equipment

The Permittee shall maintain all equipment covered under this permit in such a manner that the performance or operation of such equipment shall not cause a violation of applicable requirements.

9.2.3 Duty to Cease Operation

No person shall cause, threaten or allow the continued operation of any emission unit during malfunction or breakdown of the emission unit or related air pollution control equipment if such operation would cause a violation of an applicable emission standard, regulatory requirement, ambient air quality standard or permit limitation unless such malfunction or breakdown is allowed by a permit condition [Section 39.5(6)(c) of the Act].

9.2.4 Disposal Operations

The source shall be operated in such a manner that the disposal of air contaminants collected by the equipment operations, or activities shall not cause a violation of the Act or regulations promulgated thereunder.

9.2.5 Duty to Pay Fees

The Permittee must pay fees to the Illinois EPA consistent with the fee schedule approved pursuant to Section 39.5(18) of the Act, and submit any information relevant thereto [Section 39.5(7)(o)(vi) of the Act]. The check should be payable to "Treasurer, State of Illinois" and sent to: Fiscal Services Section, Illinois Environmental Protection Agency, P.O. Box 19276, Springfield, Illinois 62794-9276.

9.3 Obligation to Allow Illinois EPA Surveillance

Upon presentation of proper credentials and other documents, the Permittee shall allow the Illinois EPA, or an authorized representative to perform the following [Section 39.5(7)(a) and (p)(ii) of the Act and 415 ILCS 5/4]:

- a. Enter upon the Permittee's premises where an actual or potential emission unit is located; where any regulated equipment, operation, or activity is located or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect during hours of operation any sources, equipment (including monitoring and air pollution control

equipment), practices, or operations regulated or required under this permit;

- d. Sample or monitor any substances or parameters at any location:
 - i. At reasonable times, for the purposes of assuring permit compliance; or
 - ii. As otherwise authorized by the CAA, or the Act.
- e. Obtain and remove samples of any discharge or emission of pollutants authorized by this permit; and
- f. Enter and utilize any photographic, recording, testing, monitoring, or other equipment for the purposes of preserving, testing, monitoring, or recording any activity, discharge or emission at the source authorized by this permit.

9.4 Obligation to Comply with Other Requirements

The issuance of this permit does not release the Permittee from applicable State and Federal laws and regulations, and applicable local ordinances addressing subjects other than air pollution control.

9.5 Liability

9.5.1 Title

This permit shall not be considered as in any manner affecting the title of the premises upon which the permitted source is located.

9.5.2 Liability of Permittee

This permit does not release the Permittee from any liability for damage to person or property caused by or resulting from the construction, maintenance, or operation of the sources.

9.5.3 Structural Stability

This permit does not take into consideration or attest to the structural stability of any unit or part of the source.

9.5.4 Illinois EPA Liability

This permit in no manner implies or suggests that the Illinois EPA (or its officers, agents or employees) assumes any liability, directly or indirectly, for any

loss due to damage, installation, maintenance, or operation of the source.

9.5.5 Property Rights

This permit does not convey any property rights of any sort, or any exclusive privilege [Section 39.5(7)(o)(iv) of the Act].

9.6 Recordkeeping

9.6.1 Control Equipment Maintenance Records

A maintenance record shall be kept on the premises for each item of air pollution control equipment. As a minimum, this record shall show the dates of performance and nature of preventative maintenance activities.

9.6.2 Records of Changes in Operation

A record shall be kept describing changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under this permit, and the emissions resulting from those changes [Section 39.5(12)(b)(iv) of the Act].

9.6.3 Retention of Records

- a. Records of all monitoring data and support information shall be retained for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records, original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit [Section 39.5(7)(e)(ii) of the Act].
- b. Other records required by this permit shall be retained for a period of at least 5 years from the date of entry unless a longer period is specified by a particular permit provision.

9.7 Annual Emissions Report

The Permittee shall submit an annual emissions report to the Illinois EPA, Compliance Section no later than May 1 of the following year, as required by 35 IAC Part 254.

9.8 Requirements for Compliance Certification

Pursuant to Section 39.5(7)(p)(v) of the Act, the Permittee shall submit annual compliance certifications. The compliance

certifications shall be submitted no later than May 1 or more frequently as specified in the applicable requirements or by permit condition. The compliance certifications shall be submitted to the Air Compliance Section, Air Regional Field Office, and USEPA Region 5 - Air Branch. The addresses for the submittal of the compliance certifications are provided in Condition 8.6.4 of this permit.

- a. The certification shall include the identification of each term or condition of this permit that is the basis of the certification; the compliance status; whether compliance was continuous or intermittent; the method(s) used for determining the compliance status of the source, both currently and over the reporting period consistent with the conditions of this permit.
- b. All compliance certifications shall be submitted to USEPA Region 5 in Chicago as well as to the Illinois EPA.
- c. All compliance reports required to be submitted shall include a certification in accordance with Condition 9.9.

9.9 Certification

Any document (including reports) required to be submitted by this permit shall contain a certification by a responsible official of the Permittee that meets the requirements of Section 39.5(5) of the Act [Section 39.5(7)(p)(i) of the Act]. An example Certification by a Responsible Official is included as an attachment to this permit.

9.10 Defense to Enforcement Actions

9.10.1 Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit [Section 39.5(7)(o)(ii) of the Act].

9.10.2 Emergency Provision

- a. An emergency shall be an affirmative defense to an action brought for noncompliance with the technology-based emission limitations under this permit if the following conditions are met through properly signed, contemporaneous operating logs, or other relevant evidence:
 - i. An emergency occurred as provided in Section 39.5(7)(k) of the Act and the Permittee can identify the cause(s) of the emergency.

Normally, an act of God such as lightning or flood is considered an emergency;

- ii. The permitted source was at the time being properly operated;
 - iii. The Permittee submitted notice of the emergency to the Illinois EPA within two working days of the time when emission limitations were exceeded due to the emergency. This notice must contain a detailed description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - iv. During the period of the emergency the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission limitations, standards, or regulations in this permit.
- b. This provision is in addition to any emergency or upset provision contained in any applicable requirement. This provision does not relieve a Permittee of any reporting obligations under existing federal or state laws or regulations.

9.11 Permanent Shutdown

This permit only covers emission units and control equipment while physically present at the indicated source location(s). Unless this permit specifically provides for equipment relocation, this permit is void for the operation or activity of any item of equipment on the date it is removed from the permitted location(s) or permanently shut down. This permit expires if all equipment is removed from the permitted location(s), notwithstanding the expiration date specified on this permit.

9.12 Reopening and Reissuing Permit for Cause

9.12.1 Permit Actions

This permit may be modified, reopened, and reissued, for cause pursuant to Section 39.5(15) of the Act. The filing of a request by the Permittee for a permit modification, revocation, and reissuance, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition [Section 39.5(7)(o)(iii) of the Act].

9.12.2 Reopening and Revision

This permit must be reopened and revised if any of the following occur [Section 39.5(15)(a) of the Act]:

- a. Additional requirements become applicable to the equipment covered by this permit and three or more years remain before expiration of this permit;
- b. Additional requirements become applicable to an affected source for acid deposition under the acid rain program;
- c. The Illinois EPA or USEPA determines that this permit contains a material mistake or inaccurate statement when establishing the emission standards or limitations, or other terms or conditions of this permit; and
- d. The Illinois EPA or USEPA determines that this permit must be revised to ensure compliance with the applicable requirements of the Act.

9.12.3 Inaccurate Application

The Illinois EPA has issued this permit based upon the information submitted by the Permittee in the permit application. Any misinformation, false statement or misrepresentation in the application shall be grounds for revocation under Section 39.5(15)(b) of the Act.

9.12.4 Duty to Provide Information

The Permittee shall furnish to the Illinois EPA, within a reasonable time specified by the Illinois EPA any information that the Illinois EPA may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. Upon request, the Permittee shall also furnish to the Illinois EPA copies of records required to be kept by this permit, or for information claimed to be confidential, the Permittee may furnish such records directly to USEPA along with a claim of confidentiality [Section 39.5(7)(o)(v) of the Act].

9.13 Severability Clause

The provisions of this permit are severable, and should any one or more be determined to be illegal or unenforceable, the validity of the other provisions shall not be affected. The rights and obligations of the Permittee shall be construed and enforced as if this permit did not contain the particular provisions held to be invalid and the applicable requirements

underlying these provisions shall remain in force [Section 39.5(7)(i) of the Act].

9.14 Permit Expiration and Renewal

The right to operate terminates on the expiration date unless the Permittee has submitted a timely and complete renewal application. For a renewal to be timely it must be submitted no later than 9 and no sooner than 12 months prior to expiration. The equipment may continue to operate during the renewal period until final action is taken by the Illinois EPA, in accordance with the original permit conditions [Section 39.5(5)(1), (n), and (o) of the Act].

10.0 ATTACHMENTS

10.1 Attachment 1 - Example Certification by a Responsible Official

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Signature: _____

Name: _____

Official Title: _____

Telephone No.: _____

Date Signed: _____

10.2 Attachment 2 - Guidance on Revising This Permit

The Permittee must submit an application to the Illinois EPA using the appropriate revision classification in accordance with Sections 39.5(13) and (14) of the Act and 35 IAC 270.302. Specifically, there are currently three classifications for revisions to a CAAPP permit. These are:

1. Administrative Permit Amendment;
2. Minor Permit Modification; and
3. Significant Permit Modification.

The Permittee must determine, request, and submit the necessary information to allow the Illinois EPA to use the appropriate procedure to revise the CAAPP permit. A brief explanation of each of these classifications follows.

1. Administrative Permit Amendment
 - Corrects typographical errors;
 - Identifies a change in the name, address, or phone number of any person identified in the permit, or provides a similar minor administrative change at the source;
 - Requires more frequent monitoring or reporting by the Permittee;
 - Allows for a change in ownership or operational control of the source where no other change in the permit is necessary, provided that a written agreement containing a specific date for transfer of permit responsibility, coverage, and liability between the current and new Permittees has been submitted to the Illinois EPA;
 - Incorporates into the CAAPP permit a construction permit, provided the conditions of the construction permit meet the requirements for the issuance of CAAPP permits; or
 - Incorporates into the CAAPP permit revised limitations or other requirements resulting from the application of an approved economic incentives rule, marketable permits rule, or generic emissions trading rule.
2. Minor Permit Modification
 - Do not violate any applicable requirement;

- Do not involve significant changes to existing monitoring, reporting, or recordkeeping requirements in the permit;
- Do not require a case-by-case determination of an emission limitation or other standard, or a source-specific determination of ambient impacts, or a visibility or increment analysis;
- Do not seek to establish or change a permit term or condition for which there is no corresponding underlying requirement and which avoids an applicable requirement to which the source would otherwise be subject. Such terms and conditions include:
 - A federally enforceable emissions cap assumed to avoid classification as a modification under any provision of Title I of the CAA; and
 - An alternative emissions limit approved pursuant to regulations promulgated under Section 112(i)(5) of the CAA.
- Are not modifications under any provision of Title I of the CAA; and
- Are not required to be processed as a significant permit modification.

An application for a minor permit modification shall include the following:

- A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
- The source's suggested draft permit/conditions;
- Certification by a responsible official that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used; and
- Information as contained on form 271-CAAPP for the Illinois EPA to use to notify USEPA and affected States.

3. Significant Permit Modification

- Applications that do not qualify as either minor permit modifications or as administrative permit amendments;
- Applications requesting a significant change in existing monitoring permit terms or conditions;
- Applications requesting a relaxation of reporting or recordkeeping requirements; and
- Cases in which, in the judgment of the Illinois EPA, action on an application for modification would require decisions to be made on technically complex issues.

An application for a significant permit modification shall include the following:

- A detailed description of the proposed change(s), including all physical changes to equipment, changes in the method of operation, changes in emissions of each pollutant, and any new applicable requirements which will apply as a result of the proposed change. Note that the Permittee need only submit revised forms for equipment and operations that will be modified.

The Illinois EPA requires the information on the following appropriate forms to be submitted in accordance with the proper classification:

- Form 273-CAAPP, REQUEST FOR ADMINISTRATIVE PERMIT AMENDMENT FOR CAAPP PERMIT; or
- Form 271-CAAPP, MINOR PERMIT MODIFICATION FOR CAAPP PERMIT; or
- Form 200-CAAPP, APPLICATION FOR CAAPP PERMIT (for significant modification).

Application forms can be obtained from the Illinois EPA website at <http://www.epa.state.il.us/air/forms>.

Note that the request to revise the permit must be certified for truth, accuracy, and completeness by a responsible official.

Note that failure to submit the required information may require the Illinois EPA to deny the application. The Illinois EPA reserves the right to require that additional information be submitted as needed to evaluate or take final action on applications pursuant to Section 39.5(5)(g) of the Act and 35 IAC 270.305.



Illinois Environmental Protection Agency
 Division Of Air Pollution Control -- Permit Section
 P.O. Box 19506
 Springfield, Illinois 62794-9506

Application For Construction Permit (For CAAPP Sources Only)	For Illinois EPA use only
	I.D. number:
	Permit number:
Date received:	

This form is to be used by CAAPP sources to supply information necessary to obtain a construction permit. Please attach other necessary information and completed CAAPP forms regarding this construction/modification project.

Source Information		
1. Source name:		
2. Source street address:		
3. City:	4. Zip code:	
5. Is the source located within city limits? <input type="checkbox"/> Yes <input type="checkbox"/> No		
6. Township name:	7. County:	8. I.D. number:

Owner Information		
9. Name:		
10. Address:		
11. City:	12. State:	13. Zip code:

Operator Information (if different from owner)		
14. Name		
15. Address:		
16. City:	17. State:	18. Zip code:

Applicant Information	
19. Who is the applicant? <input type="checkbox"/> Owner <input type="checkbox"/> Operator	20. All correspondence to: (check one) <input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Source
21. Attention name and/or title for written correspondence:	
22. Technical contact person for application:	23. Contact person's telephone number:

This Agency is authorized to require and you must disclose this information under 415 ILCS 5/39. Failure to do so could result in the application being denied and penalties under 415 ILCS 5 et seq. It is not necessary to use this form in providing this information. This form has been approved by the forms management center.

Summary Of Application Contents	
24. Does the application address whether the proposed project would constitute a new major source or major modification under each of the following programs: a) Non-attainment New Source Review – 35 IAC Part 203; b) Prevention of Significant Deterioration (PSD) – 40 CFR 52.21; c) Hazardous Air Pollutants: Regulations Governing Constructed or Reconstructed Major Sources – 40 CFR Part 63?	<input type="checkbox"/> Yes <input type="checkbox"/> No
25. Does the application identify and address all applicable emissions standards, including those found in the following: a) Board Emission Standards – 35 IAC Chapter I, Subtitle B; b) Federal New Source Performance Standards – 40 CFR Part 60; c) Federal Standards for Hazardous Air Pollutants – 40 CFR Parts 61 and 63?	<input type="checkbox"/> Yes <input type="checkbox"/> No
26. Does the application include a process flow diagram(s) showing all emission units and control equipment, and their relationship, for which a permit is being sought?	<input type="checkbox"/> Yes <input type="checkbox"/> No
27. Does the application include a complete process description for the emission units and control equipment for which a permit is being sought?	<input type="checkbox"/> Yes <input type="checkbox"/> No
28. Does the application include the information as contained in completed CAAPP forms for all appropriate emission units and air pollution control equipment, listing all applicable requirements and proposed exemptions from otherwise applicable requirements, and identifying and describing any outstanding legal actions by either the USEPA or the Illinois EPA? Note: The use of "APC" application forms is not appropriate for applications for CAAPP sources. CAAPP forms should be used to supply information.	<input type="checkbox"/> Yes <input type="checkbox"/> No
29. If the application contains TRADE SECRET information, has such information been properly marked and claimed, and have two separate copies of the application suitable for public inspection and notice been submitted, in accordance with applicable rules and regulations?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Applicable, No TRADE SECRET information in this application

Note 1: Answering "No" to any of the above may result in the application being deemed incomplete.

Signature Block	
This certification must be signed by a responsible official. Applications without a signed certification will be returned as incomplete.	
30. I certify under penalty of law that, based on information and belief formed after reasonable inquiry, the statements and information contained in this application are true, accurate and complete. Authorized Signature: E	
_____	_____
AUTHORIZED SIGNATURE	TITLE OF SIGNATORY
_____	_____ / _____ / _____
TYPED OR PRINTED NAME OF SIGNATORY	DATE

Note 2: An operating permit for the construction/modification permitted in a construction permit must be obtained by applying for the appropriate revision to the source's CAAPP permit, if necessary.

10.4 Attachment 4 - Guidance on Renewing This Permit

Timeliness - Pursuant to Section 39.5(5)(n) of the Act and 35 IAC 270.301(d), a source must submit to the Illinois EPA a complete CAAPP application for the renewal of a CAAPP permit not later than 9 months before the date of permit expiration of the existing CAAPP permit in order for the submittal to be deemed timely. Note that the Illinois EPA typically sends out renewal notices approximately 18 months prior to the expiration of the CAAPP permit.

The CAAPP application must provide all of the following information in order for the renewal CAAPP application to be deemed complete by the Illinois EPA:

1. A completed renewal application form 200-CAAPP, APPLICATION FOR CAAPP PERMIT.
2. A completed compliance plan form 293-CAAPP, COMPLIANCE PLAN/SCHEDULE OF COMPLIANCE FOR CAAPP PERMIT.
3. A completed compliance certification form 296-CAAPP, COMPLIANCE CERTIFICATION, signed by the responsible official.
4. Any applicable requirements that became effective during the term of the permit and that were not included in the permit as a reopening or permit revision.
5. If this is the first time this permit is being renewed and this source has not yet addressed CAM, the application should contain the information on form 464-CAAPP, COMPLIANCE ASSURANCE MONITORING (CAM) PLAN.
6. Information addressing any outstanding transfer agreement pursuant to the ERMS.
7.
 - a. If operations of an emission unit or group of emission units remain unchanged and are accurately depicted in previous submittals, the application may contain a letter signed by a responsible official that requests incorporation by reference of existing information previously submitted and on file with the Illinois EPA. This letter must also include a statement that information incorporated by reference is also being certified for truth and accuracy by the responsible official's signing of the form 200-CAAPP, APPLICATION FOR CAAPP PERMIT and the form 296-CAAPP, COMPLIANCE CERTIFICATION. The boxes should be marked yes on form 200-CAAPP, APPLICATION FOR CAAPP PERMIT, as existing information is being incorporated by reference.
 - b. If portions of current operations are not as described in previous submittals, then in addition to the information above for operations that remain unchanged, the application must contain the necessary

information on all changes, e.g., discussion of changes, new or revised CAAPP forms, and a revised fee form 292-CAAPP, FEE DETERMINATION FOR CAAPP PERMIT, if necessary.

8. Information about all off-permit changes that were not prohibited or addressed by the permit to occur without a permit revision and the information must be sufficient to identify all applicable requirements, including monitoring, recordkeeping, and reporting requirements, for such changes.
9. Information about all changes made under 40 CFR 70.4(b)(12)(i) and (ii) that require a 7-day notification prior to the change without requiring a permit revision.

The Illinois EPA will review all applications for completeness and timeliness. If the renewal application is deemed both timely and complete, the source shall continue to operate in accordance with the terms and conditions of its CAAPP permit until final action is taken on the renewal application.

Notwithstanding the completeness determination, the Illinois EPA may request additional information necessary to evaluate or take final action on the CAAPP renewal application. If such additional information affects your allowable emission limits, a revised form 292-CAAPP, FEE DETERMINATION FOR CAAPP PERMIT must be submitted with the requested information. The failure to submit to the Illinois EPA the requested information within the time frame specified by the Illinois EPA, may force the Illinois EPA to deny your CAAPP renewal application pursuant to Section 39.5 of the Act.

Application forms may be obtained from the Illinois EPA website at <http://www.epa.state.il.us/air/forms.html>.

If you have any questions regarding this matter, please contact a permit analyst at 217/782-2113.

Mail renewal applications to:

Illinois Environmental Protection Agency
Division of Air Pollution Control
Permit Section (MC 11)
P.O. Box 19506
Springfield, Illinois 62794-9506

KKD:95060125:psj