

217/782-2113

CONSTRUCTION PERMIT - REVISED

PERMITTEE

Dixon/Lee Energy Partners, L.L.C.
Attn: Mike Carolan
40 Tower Lane
Avon, Connecticut 06001

Application No.: 98110054 I.D. No.: 103020ACJ
Applicant's Designation: DIXON/LEE Date Received: May 28, 1999
Subject: Landfill Gas to Electricity Power Plant
Date Issued: June 14, 1999
Location: 1279 North Bataan Road, Dixon

Permit is hereby granted to the above-designated Permittee to CONSTRUCT emission source(s) and/or air pollution control equipment consisting of three engine generators as described in the above-referenced application. This Permit is subject to standard conditions attached hereto and the following special condition(s):

1. Emissions and operation of the three engine generators shall not exceed the following limits:

<u>Rated Output (HP)</u>	<u>Pollutant</u>	<u>Emission Factor (g/HP-Hr)</u>	<u>Emissions (Lb/Hr) (Tons/Yr)</u>	
4,161	NO _x	1.11	10.2	44.6
	CO	2.21	20.3	88.9
	VOM	0.25	2.3	10.0

These limits are based on the maximum rated output for each engine (1387 HP for each engine), the maximum hours of operation (8.760 hours/year) and emission factors provided by the manufacturer. Compliance with the annual limits shall be determined from a running total of 12 months of data.

2. The three engine generators may be operated for a period of 180 days under this Construction Permit.

It should be noted that this permit has been revised to allow the three engine generators to be operated for a period of 180 days under this Construction Permit.

If you have any questions on this, please call Jason Schnepf at 217/782-2113.

Donald E. Sutton, P.E.
Manager, Permit Section
Division of Air Pollution Control

DES:JMS:psj

cc: Region 2