

217/785-1705

FEDERALLY ENFORCEABLE STATE OPERATING PERMIT -- NSPS and NESHAP SOURCE

PERMITTEE

Provident Hospital of Cook County
Attn: Thomas Whelan
500 East 51st Street
Chicago, Illinois 60615

<u>Application No.:</u> 07050072	<u>I. D. No.:</u> 031600FWB
<u>Applicant's Designation:</u>	<u>Date Received:</u> May 24, 2007
<u>Subject:</u> General Medical and Surgical Hospital	
<u>Date Issued:</u> October 30, 2014	<u>Expiration Date:</u> October 30, 2024
<u>Location:</u> 500 East 51st Street, Chicago, Cook County, 60615	

This permit is hereby granted to the above-designated Permittee to OPERATE emission unit(s) and/or air pollution control equipment consisting of:

- Two (2) 55.4 mmBtu/hour Natural Gas/Distillate Fuel Oil-Fired Boilers (Boilers B-1 and B-2);
- One (1) 12.6 mmBtu/hour Natural Gas Fired Boiler (B-3);
- Two (2) 750kW (1,006 HP) Diesel Emergency Generator Sets (Diesel Generators 1 and 2); and
- One (1) Ethylene Oxide Sterilizer

pursuant to the above-referenced application. This permit is subject to standard conditions attached hereto and the following special condition(s):

- 1a. This federally enforceable state operating permit is issued:
 - i. To limit the emissions of air pollutants from the source to less than major source thresholds (i.e., 100 tons/year Sulfur Dioxide (SO₂)). As a result the source is excluded from the requirements to obtain a Clean Air Act Permit Program (CAAPP) permit. The maximum emissions of this source, as limited by the conditions of this permit, are described in Attachment A.
 - ii. To establish federally enforceable production and operating limitations, which restrict the potential to emit for NO_x to less than 100 tons per year so that the source is not subject to the requirements of 35 Ill. Adm. Code Part 217 Subpart Q (Stationary Reciprocating Internal Combustion Engines And Turbines).
- b. Prior to issuance, a draft of this permit has undergone a public notice and comment period.
- c. This permit supersedes all operating permit(s) for this location.
- 2a. Boilers B-1, B-2, & B-3 are subject to the New Source Performance Standard (NSPS) for Small Industrial-Commercial-Institutional Steam Generating Units, 40 CFR 60, Subparts A and Dc. The Illinois EPA is administering the NSPS in Illinois on behalf of the United States EPA

under a delegation agreement. Pursuant to 40 CFR 60.40c(a), except as provided in 40 CFR 60.40c(d), (e), (f), and (g), the affected facility to which 40 CFR 60 Subpart Dc applies is each steam generating unit for which construction, modification, or reconstruction is commenced after June 9, 1989 and that has a maximum design heat input capacity of 29 megawatts (MW) (100 million British thermal units per hour (mmBtu/hour)) or less, but greater than or equal to 2.9 MW (10 mmBtu/hour).

- b. Pursuant to 40 CFR 60.42c(d), on and after the date on which the initial performance test is completed or required to be completed under 40 CFR 60.8, whichever date comes first, no owner or operator of an affected facility that combusts oil shall cause to be discharged into the atmosphere from that affected facility any gases that contain SO₂ in excess of 215 ng/J (0.50 lb/mmBtu) heat input from oil; or, as an alternative, no owner or operator of an affected facility that combusts oil shall combust oil in the affected facility that combusts greater than 0.5 weight percent sulfur. The percent reduction requirements are not applicable to affected facilities under this paragraph.
 - c. Pursuant to 40 CFR 60.42c(h)(1), for distillate oil-fired affected facilities with heat input capacities between 2.9 and 29 MW (10 and 100 mmBtu/hour), compliance with the emission limits or fuel oil sulfur limits under 40 CFR 60.42c may be determined based on a certification from the fuel supplier, as described under 40 CFR 60.48c(f), as applicable.
 - d. Pursuant to 40 CFR 60.42c(i), the SO₂ emission limits, fuel oil sulfur limits, and percent reduction requirements under 40 CFR 60.42c apply at all times, including periods of startup, shutdown, and malfunction.
 - e. Pursuant to 40 CFR 60.43c(c), on and after the date on which the initial performance test is completed or required to be completed under 40 CFR 60.8, whichever date comes first, no owner or operator of an affected facility that combusts coal, wood, or oil and has a heat input capacity of 8.7 MW (30 mmBtu/hour) or greater shall cause to be discharged into the atmosphere from that affected facility any gases that exhibit greater than 20 percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 percent opacity. Owners and operators of an affected facility that elect to install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) for measuring PM emissions according to the requirements of 40 CFR 60 Subpart Dc and are subject to a federally enforceable PM limit of 0.030 lb/mmBtu or less are exempt from this opacity standard.
 - f. Pursuant to 40 CFR 60.43c(d), the PM and opacity standards under 40 CFR 60.43c apply at all times, except during periods of startup, shutdown, or malfunction.
3. The ethylene oxide sterilizer is subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Hospital Ethylene Oxide Sterilizers, 40 CFR 63 Subparts A and WWWW. The Illinois EPA is

administering the NESHAP in Illinois on behalf of the United States EPA under a delegation agreement. Pursuant to 40 CFR 63.10382(a), you are subject to 40 CFR 63 Subpart WWWW if you own or operate an ethylene oxide sterilization facility at a hospital that is an area source of hazardous air pollutant (HAP) emissions.

- 4a. Pursuant to 35 Ill. Adm. Code 212.123(a), no person shall cause or allow the emission of smoke or other particulate matter, with an opacity greater than 30 percent, into the atmosphere from any emission unit other than those emission units subject to 35 Ill. Adm. Code 212.122.
- b. Pursuant to 35 Ill. Adm. Code 212.123(b), the emission of smoke or other particulate matter from any such emission unit may have an opacity greater than 30 percent, but not greater than 60 percent for a period or periods aggregating 8 minutes in any 60 minute period provided that such opaque emissions permitted during any 60 minute period shall occur from only one such emission unit located within a 305 meter (1000 foot) radius from the center point of any other such emission unit owned or operated by such person, and provided further that such opaque emissions permitted from each such emission unit shall be limited to 3 times in 24 hour period.
- c. Pursuant to 35 Ill. Adm. Code 212.206, no person shall cause or allow the emission of particulate matter into the atmosphere in any one hour period to exceed 0.15 kg of particulate matter per MW-hour of actual heat input from any fuel combustion emission unit using liquid fuel exclusively (0.10 lbs/mmBtu).
- 5a. Pursuant to 35 Ill. Adm. Code 214.122(b)(2), no person shall cause or allow the emission of sulfur dioxide into the atmosphere in any one hour period from any new fuel combustion source with actual heat input smaller than, or equal to, 73.2 MW (250 mmBtu/hour), burning liquid fuel exclusively to exceed 0.46 kg of sulfur dioxide per MW-hour of actual heat input when distillate fuel oil is burned (0.3 lbs/mmBtu).
- b. Pursuant to 35 Ill. Adm. Code 214.301, except as further provided by 35 Ill. Adm. Code Part 214, no person shall cause or allow the emission of sulfur dioxide into the atmosphere from any process emission unit to exceed 2000 ppm.
- c. Pursuant to 35 Ill. Adm. Code 214.304, the emissions from the burning of fuel at process emission sources located in the Chicago or St. Louis (Illinois) major metropolitan areas shall comply with applicable 35 Ill. Adm. Code Part 214 Subparts B through F (i.e., 35 Ill. Adm. Code 214.122(b)(2)).
6. Pursuant to 35 Ill. Adm. Code 216.121, no person shall cause or allow the emission of carbon monoxide (CO) into the atmosphere from any fuel combustion emission source with actual heat input greater than 2.9 MW (10 mmBtu/hour) to exceed 200 ppm, corrected to 50 percent excess air.

7. Pursuant to 35 Ill. Adm. Code 218.301, no person shall cause or allow the discharge of more than 3.6 kg/hour (8 lbs/hour) of organic material into the atmosphere from any emission source, except as provided in 35 Ill. Adm. Code 218.302, 218.303, or 218.304 and the following exception: If no odor nuisance exists the limitation of 35 Ill. Adm. Code Part 218 Subpart G (Use of Organic Material) shall apply only to photochemically reactive material.
- 8a. This permit is issued based on the three ethylene oxide sterilizers not being subject to the requirements of the NESHAP for Ethylene Oxide Emissions Standards for Sterilization Facilities, 40 CFR 63 Subpart O. Pursuant to 40 CFR 63.360(e), 40 CFR 63 Subpart O does not apply to ethylene oxide sterilization operations at stationary sources such as hospitals, doctors offices, clinics, or other facilities whose primary purpose is to provide medical services to humans or animals.
- b. This permit is issued based on Diesel Generators 1 and 2 not being subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines, 40 CFR 63 Subpart ZZZZ. Pursuant to 40 CFR 63.6585(f)(3), existing institutional emergency stationary RICE located at an area source of HAP emissions that do not operate or are not contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii) and that do not operate for the purpose specified in 40 CFR 63.6640(f)(4)(ii) are not subject to 40 CFR 63 Subpart ZZZZ. The stationary RICE must meet the definition of an emergency stationary RICE in 40 CFR 63.6675, which includes operating according to the provisions specified in 40 CFR 63.6640(f).
- c. This permit is issued based on the source not being subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Industrial, Commercial, and Institutional Boilers and Process Heaters, 40 CFR 63 Subpart DDDDD because this source is not or is part of, a major source of HAP as defined in 40 CFR 63.2.
- d. This permit is issued based on Boilers not being subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Industrial, Commercial, and Institutional Boilers and Process Heaters, 40 CFR 63 Subpart DDDDD because Auxiliary Boilers #1 & #2 will not be located at, or will be part of, a major source of HAP as defined in 40 CFR 63.2.
- e. This permit is issued based on Boilers B-1, B-2, and B-3 not being subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Industrial, Commercial, and Institutional Boilers Area Sources, 40 CFR 63 Subpart JJJJJJ. Pursuant to 40 CFR 63.11195(e), a gas-fired boiler as defined in 40 CFR 63 Subpart JJJJJJ are not subject to 40 CFR 63 Subpart JJJJJJ and to any requirements in 40 CFR 63 Subpart JJJJJJ. Pursuant to 40 CFR 63.11237, gas-fired boiler includes any boiler that burns gaseous fuels not combined with any solid fuels, burns liquid fuel only during periods of gas curtailment, gas supply

emergencies, or periodic testing on liquid fuel. Periodic testing of liquid fuel shall not exceed a combined total of 48 hours during any calendar year.

9. Pursuant to 35 Ill. Adm. Code 218.303, the provisions of 35 Ill. Adm. Code 218.301 and 218.302 (Use of Organic Material) shall not apply to fuel combustion emission units.
- 10a. Pursuant to 40 CFR 60.11(b), compliance with opacity standards in 40 CFR Part 60 shall be determined by conducting observations in accordance with Method 9 in Appendix A of 40 CFR Part 60, any alternative method that is approved by the Illinois EPA or USEPA, or as provided in 40 CFR 60.11(e)(5). For purposes of determining initial compliance, the minimum total time of observations shall be 3 hours (30 6-minute averages) for the performance test or other set of observations (meaning those fugitive-type emission sources subject only to an opacity standard).
- b. Pursuant to 40 CFR 60.11(c), the opacity standards set forth in 40 CFR Part 60 shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.
- c. Pursuant to 40 CFR 60.11(d), at all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Illinois EPA or USEPA which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.
- 11a. Pursuant to 40 CFR 63.6640(f), if you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in 40 CFR 63.6640 (f)(1) through (4). In order for the engine to be considered an emergency stationary RICE under 40 CFR 63 Subpart ZZZZ, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in 40 CFR 63.6640(f)(1) through (4), is prohibited. If you do not operate the engine according to the requirements in 40 CFR 63.6640(f)(1) through (4), the engine will not be considered an emergency engine under 40 CFR 63 Subpart ZZZZ and must meet all requirements for non-emergency engines.
 - i. There is no time limit on the use of emergency stationary RICE in emergency situations.
 - ii. You may operate your emergency stationary RICE for any combination of the purposes specified in 40 CFR 63.6640(f)(2)(i)

through (iii) for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by 40 CFR 63.6640(f)(3) and (4) counts as part of the 100 hours per calendar year allowed by this 40 CFR 63.6640(f)(2).

- A. Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Illinois EPA or USEPA for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.
 - B. Emergency stationary RICE may be operated for emergency demand response for periods in which the Reliability Coordinator under the North American Electric Reliability Corporation (NERC) Reliability Standard EOP-002-3, Capacity and Energy Emergencies, or other authorized entity as determined by the Reliability Coordinator, has declared an Energy Emergency Alert Level 2 as defined in the NERC Reliability Standard EOP-002-3.
 - C. Emergency stationary RICE may be operated for periods where there is a deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency.
- iii. Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted towards the 100 hours per calendar year for maintenance and testing and emergency demand response provided in 40 CFR 63.6640(f)(2). Except as provided in 40 CFR 63.6640(f)(4)(i) and (ii), the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.
- A. Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and

the power is provided only to the facility itself or to support the local distribution system.

- B. The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:
 - I. The engine is dispatched by the local balancing authority or local transmission and distribution system operator.
 - II. The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.
 - III. The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.
 - IV. The power is provided only to the facility itself or to support the local transmission and distribution system.
 - V. The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.
- b. Pursuant to 40 CFR 63.6675, emergency stationary RICE means any stationary reciprocating internal combustion engine that meets all of the criteria in paragraphs (1) through (3) of this definition. All emergency stationary RICE must comply with the requirements specified in 40 CFR 63.6640(f) in order to be considered emergency stationary RICE. If the engine does not comply with the requirements specified in 40 CFR 63.6640(f), then it is not considered to be an emergency stationary RICE under 40 CFR 63 Subpart ZZZZ.
 - i. The stationary RICE is operated to provide electrical power or mechanical work during an emergency situation. Examples include stationary RICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is

interrupted, or stationary RICE used to pump water in the case of fire or flood, etc.

- ii. The stationary RICE is operated under limited circumstances for situations not included in paragraph (1) of this definition, as specified in 40 CFR 63.6640(f).
 - iii. The stationary RICE operates as part of a financial arrangement with another entity in situations not included in paragraph (1) of this definition only as allowed in 40 CFR 63.6640(f)(2)(ii) or (iii) and 40 CFR 63.6640(f)(4)(i) or (ii).
- 12a. Pursuant to 40 CFR 63.10390, you must sterilize full loads of items having a common aeration time, except under medically necessary circumstances, as that term is defined in 40 CFR 63.10448.
- b. Pursuant to 40 CFR 63.10420, for each sterilization unit not equipped with an air pollution control device, you must demonstrate continuous compliance with the management practice standard in 40 CFR 63.10390 by recording the date and time of each sterilization cycle, whether each sterilization cycle contains a full load of items, and if not, a statement from a hospital central services staff, a hospital administrator, or a physician that it was medically necessary.
 - c. Pursuant to 40 CFR 63.10440, Table 1 to 40 CFR 63 Subpart WWWW (see also Attachment B) shows which parts of the General Provisions in 40 CFR 63.1 through 63.16 apply to you.
- 13a. In the event that the operation of this source results in an odor nuisance, the Permittee shall take appropriate and necessary actions to minimize odors, including but not limited to, changes in raw material or installation of controls, in order to eliminate the odor nuisance.
- b. Boilers B-1 and B-2 shall only be operated with natural gas or distillate fuel oil as the fuel. The use of any other fuel in Boiler B-1 or B-2 requires that the Permittee first obtain a construction permit from the Illinois EPA and then perform stack testing to verify compliance with all applicable requirements.
 - c. Boiler B-3 shall only be operated with natural gas as the fuel. The use of any other fuel in Boiler B-3 requires that the Permittee first obtain a construction permit from the Illinois EPA and then perform stack testing to verify compliance with all applicable requirements.
 - d. Diesel Generators 1 and 2 shall only be operated with distillate fuel oil as the fuel. The use of any other fuel in Diesel Generator 1 or 2 requires that the Permittee first obtain a construction permit from the Illinois EPA and then perform stack testing to verify compliance with all applicable requirements.

- e. The Permittee shall not keep, store or use distillate fuel oil (Grades No. 1 and 2) at this source with a sulfur content greater than the larger of the following two values:
 - i. 0.28 weight percent, or
 - ii. The weight percent given by the formula: Maximum weight percent sulfur = $(0.000015) \times (\text{Gross heating value of oil, Btu/lb})$.
- f. Organic liquid by-products or waste materials shall not be used in any emission unit at this source without written approval from the Illinois EPA.
- g. The Illinois EPA shall be allowed to sample all fuels stored at the above location.
- 14a. Emissions and operation of Boilers B-1, B-2, and B-3 combined shall not exceed the following limits:
 - i. Natural Gas Usage: 20 mmscf/Month, 200 mmscf/Year
 - ii. Emissions for the combustion of natural gas in the boilers:

<u>Pollutant</u>	Emission	Emissions	
	Factor (lbs/mmscf)	(Tons/Mo)	(Tons/Yr)
Carbon Monoxide (CO)	84.0	0.84	8.40
Nitrogen Oxides (NO _x)	100.0	1.00	10.00
Particulate Matter (PM)	7.6	0.08	0.76
Sulfur Dioxide (SO ₂)	0.6	0.01	0.06
Volatile Organic Material (VOM)	5.5	0.06	0.55

These limits are based on the maximum fuel usage and standard emission factors (Tables 1.4-1 and 1.4-2, AP-42, Fifth Edition, Volume I, Supplement D, July 1998).

- iii. Distillate Fuel Oil usage (Boilers B-1 and B-2): 100 kgal/year
- iv. Emissions from the combustion of #2 fuel oil in Boilers B-1 and B-2:

<u>Pollutant</u>	Emission	Emissions	
	Factor (lbs/10 ³ Gal)	(lbs/Hr)	(Tons/Yr)
Carbon Monoxide (CO)	5.00	3.96	0.25
Nitrogen Oxides (NO _x)	20.00	15.83	1.00
Particulate Matter (PM)	2.00	1.58	0.10
Sulfur Dioxide (SO ₂)	39.76	39.76	1.99
Volatile Organic Material (VOM)	0.34	0.16	0.01

These limits are based on the maximum firing rates (55.4 mmBtu/hour, each), the maximum annual fuel usage, a heat content of 140,000 Btu/gallon, a sulfur content of 0.28% by weight, and standard emission factors (Tables 1.3-1 and 1.3-3, AP-42, Fifth Edition, Volume I, Supplement E, September 1999, corrected May 2010).

- b. Emissions and operation of Diesel Generators 1 and 2 shall not exceed the following:
 - i. Total hours of operation for the two 750 kW diesel generators shall not exceed 500 hours/year each.
 - ii. Emissions from Diesel Generators (combined) shall not exceed:

<u>Pollutant</u>	<u>Emission Factor</u> (lb/HP-Hr)	<u>Emissions</u>	
		(lbs/Hr)	(Tons/Yr)
Carbon Monoxide (CO)	0.0055	11.06	2.77
Nitrogen Oxides (NO _x)	0.024	48.28	12.07
Particulate Matter (PM)	0.0007	1.41	0.35
Sulfur Dioxide (SO ₂)	0.00227	4.56	1.14
Volatile Organic Material (VOM)	0.00064	1.29	0.32

The above limits are based on the rated output of the engines powering the generators (750 kW, each), a sulfur content of 0.28% by weight, 500 hours/year of operation, and standard emission factors (Table 3.4-1, AP-42, Fifth Edition, Volume I, Supplement B, October 1996).

- c. This permit is issued based on emissions of VOM from the one (1) ethylene oxide sterilizer. For this purpose, VOM emissions from emission source shall not exceed emission rates of 0.1 tons/year and 0.7 ton/year.
- d. Compliance with the annual limits of this permit shall be determined on a monthly basis from the sum of the data for the current month plus the preceding 11 months (running 12 month total).
- 15. This permit is issued based on the Potential to Emit (PTE) for Hazardous Air Pollutants (HAPs) as listed in Section 112(b) of the Clean Air Act from this source being less than 10 tons/year of any single HAP and 25 tons/year of any combination of such HAPs. As a result, this permit is issued based on the emissions of all HAPs from this source not triggering the requirement to obtain a CAAPP permit from the Illinois EPA.
- 16a. Pursuant to 40 CFR 60.8(a), at such other times as may be required by the Illinois EPA or USEPA under section 114 of the Clean Air Act, the owner or operator of such facility shall conduct performance test(s) for boilers 2 and 3 and furnish the Illinois EPA or USEPA a written report of the results of such performance test(s).

- b. Pursuant to 40 CFR 60.8(b), performance tests shall be conducted and data reduced in accordance with the test methods and procedures contained in each applicable subpart of 40 CFR Part 60 unless the Illinois EPA or USEPA:
 - i. Specifies or approves, in specific cases, the use of a reference method with minor changes in methodology;
 - ii. Approves the use of an equivalent method;
 - iii. Approves the use of an alternative method the results of which he has determined to be adequate for indicating whether a specific source is in compliance;
 - iv. Waives the requirement for performance tests because the owner or operator of a source has demonstrated by other means to the Illinois EPA's or USEPA's satisfaction that the affected facility is in compliance with the standard; or
 - v. Approves shorter sampling times and smaller sample volumes when necessitated by process variables or other factors. Nothing in this paragraph shall be construed to abrogate the Illinois EPA's or USEPA's authority to require testing under section 114 of the Clean Air Act.
- c. Pursuant to 40 CFR 60.8(c), performance tests shall be conducted under such conditions as the Illinois EPA or USEPA shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Illinois EPA or USEPA such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.
- d. Pursuant to 40 CFR 60.8(d), the owner or operator of an affected facility shall provide the Illinois EPA or USEPA at least 30 days prior notice of any performance test, except as specified under other subparts, to afford the Illinois EPA or USEPA the opportunity to have an observer present. If after 30 days' notice for an initially scheduled performance test, there is a delay (due to operational problems, etc.) in conducting the scheduled performance test, the owner or operator of an affected facility shall notify the Illinois EPA or USEPA as soon as possible of any delay in the original test date, either by providing at least 7 days prior notice of the rescheduled date of the performance test, or by arranging a rescheduled date with the Illinois EPA or USEPA by mutual agreement.

- e. Pursuant to 40 CFR 60.8(e), the owner or operator of an affected facility shall provide, or cause to be provided, performance testing facilities as follows:
 - i. Sampling ports adequate for test methods applicable to such facility. This includes:
 - A. Constructing the air pollution control system such that volumetric flow rates and pollutant emission rates can be accurately determined by applicable test methods and procedures; and
 - B. Providing a stack or duct free of cyclonic flow during performance tests, as demonstrated by applicable test methods and procedures.
 - ii. Safe sampling platform(s).
 - iii. Safe access to sampling platform(s).
 - iv. Utilities for sampling and testing equipment.
- f. Pursuant to 40 CFR 60.8(f), unless otherwise specified in the applicable subpart of 40 CFR Part 60, each performance test shall consist of three separate runs using the applicable test method. Each run shall be conducted for the time and under the conditions specified in the applicable standard under 40 CFR Part 60. For the purpose of determining compliance with an applicable standard under 40 CFR Part 60, the arithmetic means of results of the three runs shall apply. In the event that a sample is accidentally lost or conditions occur in which one of the three runs must be discontinued because of forced shutdown, failure of an irreplaceable portion of the sample train, extreme meteorological conditions, or other circumstances, beyond the owner or operator's control, compliance may, upon the Illinois EPA's or USEPA's approval, be determined using the arithmetic mean of the results of the two other runs.
- g. Pursuant to 40 CFR 60.11(b), compliance with opacity standards in 40 CFR Part 60 shall be determined by conducting observations in accordance with Method 9 in Appendix A of 40 CFR Part 60, any alternative method that is approved by the Illinois EPA or USEPA, or as provided in 40 CFR 60.11(e)(5). For purposes of determining initial compliance, the minimum total time of observations shall be 3 hours (30 6-minute averages) for the performance test or other set of observations (meaning those fugitive-type emission sources subject only to an opacity standard).
- h. Pursuant to 40 CFR 60.11(e)(2), except as provided in 40 CFR 60.11(e)(3), the owner or operator of an affected facility to which an opacity standard in 40 CFR Part 60 applies shall conduct opacity observations in accordance with 40 CFR 60.11(b), shall record the opacity of emissions, and shall report to the Illinois EPA or USEPA the

opacity results along with the results of the initial performance test required under 40 CFR 60.8. The inability of an owner or operator to secure a visible emissions observer shall not be considered a reason for not conducting the opacity observations concurrent with the initial performance test.

- 17a. Pursuant to 40 CFR 60.44c(g), for oil-fired affected facilities where the owner or operator seeks to demonstrate compliance with the fuel oil sulfur limits under 40 CFR 60.42c based on shipment fuel sampling, the initial performance test shall consist of sampling and analyzing the oil in the initial tank of oil to be fired in the steam generating unit to demonstrate that the oil contains 0.5 weight percent sulfur or less. Thereafter, the owner or operator of the affected facility shall sample the oil in the fuel tank after each new shipment of oil is received, as described under 40 CFR 60.46c(d)(2).
 - b. Pursuant to 40 CFR 60.44c(h), for affected facilities subject to 40 CFR 60.42c(h)(1), (2), or (3) where the owner or operator seeks to demonstrate compliance with the SO₂ standards based on fuel supplier certification, the performance test shall consist of the certification, the certification from the fuel supplier, as described under 40 CFR 60.48c(f), as applicable.
 - c. Pursuant to 40 CFR 60.45c(a)(8), the owner or operator of an affected facility subject to the PM and/or opacity standards under 40 CFR 60.43c shall conduct an initial performance test as required under 40 CFR 60.8, and shall conduct subsequent performance tests as requested by the Administrator, to determine compliance with the standards using the following procedures and reference methods: Method 9 of Appendix A-4 of 40 CFR 60 shall be used for determining the opacity of stack emissions.
- 18a. Pursuant to 35 Ill. Adm. Code 201.282, every emission source or air pollution control equipment shall be subject to the following testing requirements for the purpose of determining the nature and quantities of specified air contaminant emissions and for the purpose of determining ground level and ambient air concentrations of such air contaminants:
 - i. Testing by Owner or Operator. The Illinois EPA may require the owner or operator of the emission source or air pollution control equipment to conduct such tests in accordance with procedures adopted by the Illinois EPA, at such reasonable times as may be specified by the Illinois EPA and at the expense of the owner or operator of the emission source or air pollution control equipment. The Illinois EPA may adopt procedures detailing methods of testing and formats for reporting results of testing. Such procedures and revisions thereto, shall not become effective until filed with the Secretary of State, as required by the APA Act. All such tests shall be made by or under the direction of a person qualified by training and/or experience in the field of

air pollution testing. The Illinois EPA shall have the right to observe all aspects of such tests.

- ii. Testing by the Illinois EPA. The Illinois EPA shall have the right to conduct such tests at any time at its own expense. Upon request of the Illinois EPA, the owner or operator of the emission source or air pollution control equipment shall provide, without charge to the Illinois EPA, necessary holes in stacks or ducts and other safe and proper testing facilities, including scaffolding, but excluding instruments and sensing devices, as may be necessary.
- b. Testing required by Condition 19 shall be performed upon a written request from the Illinois EPA by a qualified independent testing service.
- 19. Pursuant to 35 Ill. Adm. Code 212.110(c), upon a written notification by the Illinois EPA, the owner or operator of a particulate matter emission unit subject to 35 Ill. Adm. Code Part 212 shall conduct the applicable testing for particulate matter emissions, opacity, or visible emissions at such person's own expense, to demonstrate compliance. Such test results shall be submitted to the Illinois EPA within thirty (30) days after conducting the test unless an alternative time for submittal is agreed to by the Illinois EPA.
- 20a. Pursuant to 40 CFR 60.46c(d)(2), as an alternative fuel sampling procedure for affected facilities combusting oil, oil samples may be collected from the fuel tank for each steam generating unit immediately after the fuel tank is filled and before any oil is combusted. The owner or operator of the affected facility shall analyze the oil sample to determine the sulfur content of the oil. If a partially empty fuel tank is refilled, a new sample and analysis of the fuel in the tank would be required upon filling. Results of the fuel analysis taken after each new shipment of oil is received shall be used as the daily value when calculating the 30-day rolling average until the next shipment is received. If the fuel analysis shows that the sulfur content in the fuel tank is greater than 0.5 weight percent sulfur, the owner or operator shall ensure that the sulfur content of subsequent oil shipments is low enough to cause the 30-day rolling average sulfur content to be 0.5 weight percent sulfur or less.
- b. Pursuant to 40 CFR 60.46c(e), the monitoring requirements of 40 CFR 60.46c(a) and (d) shall not apply to affected facilities subject to 40 CFR 60.42c(h)(1), (2), or (3) where the owner or operator of the affected facility seeks to demonstrate compliance with the SO₂ standards based on fuel supplier certification, as described under 40 CFR 60.48c(f), as applicable.
- c. Pursuant to 40 CFR 60.47c(c), owners and operators of an affected facilities that burn only distillate oil that contains no more than 0.5 weight percent sulfur and/or liquid or gaseous fuels with potential sulfur dioxide emission rates of 26 ng/J (0.060 lb/mmBtu) heat input or

less and that do not use a post-combustion technology to reduce SO₂ or PM emissions and that are subject to an opacity standard in 40 CFR 60.43c(c) are not required to operate a COMS if they follow the applicable procedures in 40 CFR 60.48c(f).

- 21a. Pursuant to 40 CFR 60.7(b), any owner or operator subject to the provisions of 40 CFR Part 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.
- b. Pursuant to 40 CFR 60.7(f), any owner or operator subject to the provisions of 40 CFR Part 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by 40 CFR Part 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least two years following the date of such measurements, maintenance, reports, and records.
- 22a. Pursuant to 40 CFR 60.48c(e)(11), the owner or operator of each affected facility subject to the SO₂ emission limits, fuel oil sulfur limits, or percent reduction requirements under 40 CFR 60.42c shall keep records including the following information, as applicable. If fuel supplier certification is used to demonstrate compliance, records of fuel supplier certification as described under 40 CFR 60.48c(f)(1), (2), (3), or (4), as applicable. In addition to records of fuel supplier certifications, the report shall include a certified statement signed by the owner or operator of the affected facility that the records of fuel supplier certifications submitted represent all of the fuel combusted during the reporting period.
- b. Pursuant to 40 CFR 60.48c(f)(1), fuel supplier certification shall include the following information for distillate oil:
 - i. The name of the oil supplier;
 - ii. A statement from the oil supplier that the oil complies with the specifications under the definition of distillate oil in 40 CFR 60.41c; and
 - iii. The sulfur content of the oil.
- c.
 - i. Pursuant to 40 CFR 60.48c(g)(1), except as provided under 40 CFR 60.48c(g)(2) and (g)(3), the owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each operating day.

- ii. Pursuant to 40 CFR 60.48c(g)(2), as an alternative to meeting the requirements of 40 CFR 60.48c(g)(1), the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in 40 CFR 60.48c(f) to demonstrate compliance with the SO₂ standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel combusted during each calendar month.
 - iii. Pursuant to 40 CFR 60.48c(g)(3), as an alternative to meeting the requirements of 40 CFR 60.48c(g)(1), the owner or operator of an affected facility or multiple affected facilities located on a contiguous property unit where the only fuels combusted in any steam generating unit (including steam generating units not subject to 40 CFR 60 Subpart Dc) at that property are natural gas, wood, distillate oil meeting the most current requirements in 40 CFR 60.42C to use fuel certification to demonstrate compliance with the SO₂ standard, and/or fuels, excluding coal and residual oil, not subject to an emissions standard (excluding opacity) may elect to record and maintain records of the total amount of each steam generating unit fuel delivered to that property during each calendar month.
 - d. Pursuant to 40 CFR 60.48c(i), all records required under 40 CFR 60.48 shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record.
23. Pursuant to 40 CFR 63.10(b)(3), if an owner or operator determines that his or her stationary source that emits (or has the potential to emit, without considering controls) one or more hazardous air pollutants regulated by any standard established pursuant to Section 112(d) or (f) of the Clean Air Act, and that stationary source is in the source category regulated by the relevant standard, but that source is not subject to the relevant standard (or other requirement established under 40 CFR Part 63) because of limitations on the source's potential to emit or an exclusion, the owner or operator must keep a record of the applicability determination on site at the source for a period of 5 years after the determination, or until the source changes its operations to become an affected source, whichever comes first. The record of the applicability determination must be signed by the person making the determination and include an analysis (or other information) that demonstrates why the owner or operator believes the source is unaffected (e.g., because the source is an area source). The analysis (or other information) must be sufficiently detailed to allow the USEPA and/or Illinois EPA to make a finding about the source's applicability status with regard to the relevant standard or other requirement. If relevant, the analysis must be performed in accordance with requirements established in relevant subparts of 40 CFR Part 63 for this purpose for particular categories of stationary sources. If relevant, the analysis should be performed in accordance with USEPA guidance materials published to assist sources in making applicability determinations under Section 112 of the Clean Air Act, if any. The

requirements to determine applicability of a standard under 40 CFR 63.1(b)(3) and to record the results of that determination under 40 CFR 63.10(b)(3) shall not by themselves create an obligation for the owner or operator to obtain a Title V permit.

- 24a. Pursuant to 40 CFR 63.10432, you must keep the records specified in 40 CFR 63.10432(a) and (b).
 - i. A copy of the Initial Notification of Compliance Status that you submitted to comply with 40 CFR 63 Subpart WWWW.
 - ii. Records required by 40 CFR 63.10420 for each sterilization unit not equipped with an air pollution control device.
 - b. Pursuant to 40 CFR 63.10434(a), your records must be in a form suitable and readily available for expeditious review.
 - c. Pursuant to 40 CFR 63.10434(b), you must keep each record for 5 years following the date of each record.
 - d. Pursuant to 40 CFR 63.10434(c), you must keep each record onsite for at least 2 years after the date of each record. You may keep the records offsite for the remaining 3 years.
25. Pursuant to 35 Ill. Adm. Code 212.110(e), the owner or operator of an emission unit subject to 35 Ill. Adm. Code Part 212 shall retain records of all tests which are performed. These records shall be retained for at least three (3) years after the date a test is performed.
- 26a. The Permittee shall maintain records of the following items to demonstrate compliance with the Conditions of this permit:
 - i. Natural gas usage for Boilers B-1, B-2, and B-3 (therms/month and therms/year);
 - ii. Fuel oil usage for Boilers B-1 and B-2 (gallons/month and gallons/year);
 - iii. Certification from the fuel oil supplier of the weight percent sulfur content of the distillate fuel oil used in the boilers and the diesel-powered generator sets with each fuel oil shipment received (weight %);
 - iv. Diesel generator set runtime (hours/month and hours/year);
 - v. An inspection, maintenance and repair log of the diesel-powered generator sets listing each activity performed with date;
 - vi. Ethylene oxide usage for the sterilizer (lbs/month and lbs/year); and

- vii. Monthly and annual emissions of CO, NO_x, PM, SO₂, VOM and HAPs from the source with supporting calculations (tons/month and tons/year).
 - b. All records and logs required by this permit shall be retained at a readily accessible location at the source for at least five (5) years from the date of entry and shall be made available for inspection and copying by the Illinois EPA or USEPA upon request. Any records retained in an electronic format (e.g., computer storage device) shall be capable of being retrieved and printed on paper during normal source office hours so as to be able to respond to an Illinois EPA or USEPA request for records during the course of a source inspection.
27. Pursuant to 40 CFR 60.7(a)(4), any owner or operator subject to the provisions of 40 CFR Part 60 shall furnish the Illinois EPA or USEPA written notification or, if acceptable to both the Illinois EPA and USEPA and the owner or operator of a source, electronic notification, as follows: A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Illinois EPA or USEPA may request additional relevant information subsequent to this notice.
- 28a. Pursuant to 40 CFR 60.48c(b), the owner or operator of each affected facility subject to the SO₂ emission limits of 40 CFR 60.42c, or the PM or opacity limits of 40 CFR 60.43c, shall submit to the Illinois EPA or USEPA the performance test data from the initial and any subsequent performance tests and, if applicable, the performance evaluation of the CEMS and/or COMS using the applicable performance specifications in Appendix B of 40 CFR Part 60.
- b. Pursuant to 40 CFR 60.48c(d), the owner or operator of each affected facility subject to the SO₂ emission limits, fuel oil sulfur limits, or percent reduction requirements under 40 CFR 60.42c shall submit reports to the Illinois EPA or USEPA.
 - c. Pursuant to 40 CFR 60.48c(j), the reporting period for the reports required under 40 CFR 60 Subpart Dc is each six-month period. All reports shall be submitted to the Illinois EPA or USEPA and shall be postmarked by the 30th day following the end of the reporting period.
29. Pursuant to 35 Ill. Adm. Code 212.110(d), a person planning to conduct testing for particulate matter emissions to demonstrate compliance shall give written notice to the Illinois EPA of that intent. Such notification shall be given at least thirty (30) days prior to the initiation of the test unless a shorter period is agreed to by the

Illinois EPA. Such notification shall state the specific test methods from 35 Ill. Adm. Code 212.110 that will be used.

30a. If there is an exceedance of or a deviation from the requirements of this permit as determined by the records required by this permit, the Permittee shall submit a report to the Illinois EPA's Compliance Section in Springfield, Illinois within 30 days after the exceedance or deviation. The report shall include the emissions released in accordance with the recordkeeping requirements, a copy of the relevant records, and a description of the exceedance or deviation and efforts to reduce emissions.

b. Two (2) copies of required reports and notifications shall be sent to:

Illinois Environmental Protection Agency
Division of Air Pollution Control
Compliance Section (#40)
P.O. Box 19276
Springfield, Illinois 62794-9276

and one (1) copy shall be sent to the Illinois EPA's regional office at the following address unless otherwise indicated:

Illinois Environmental Protection Agency
Division of Air Pollution Control
9511 West Harrison
Des Plaines, Illinois 60016

Telephone: 847/294-4000 Fax: 847/294-4018

If you have any questions concerning this permit, please call Jocelyn Stakely at 217/785-1705.

Raymond E. Pilapil
Acting Manager, Permit Section
Division of Air Pollution Control

Date Signed: _____

REP:JRS:psj

cc: Illinois EPA, FOS Region 1
Lotus Notes

Attachment A - Emission Summary

This attachment provides a summary of the maximum emissions from the General Medical and Surgical Hospital operating in compliance with the requirements of this federally enforceable permit. In preparing this summary, the Illinois EPA used the annual operating scenario which results in maximum emissions from such a plant. The resulting maximum emissions are below the levels (e.g., 100 tons/year for SO₂) at which this source would be considered a major source for purposes of the Clean Air Act Permit Program. Actual emissions from this source will be less than predicted in this summary to the extent that less material is handled and control measures are more effective than required in this permit.

<u>Emission Unit</u>	E M I S S I O N S (Tons/Year)				
	<u>CO</u>	<u>NO_x</u>	<u>PM</u>	<u>SO₂</u>	<u>VOM</u>
Boilers B-1, B-2, & B-3 (Natural Gas)	8.40	10.00	0.76	0.06	0.55
Boilers B-1 & B-2 (#2 Fuel Oil)	0.25	1.00	0.10	1.99	0.02
Diesel Generators 1 and 2	2.77	12.07	0.35	1.21	0.35
Ethylene Oxide Sterilizer	-----	-----	-----	-----	<u>0.70</u>
Totals:	11.42	23.07	1.21	3.25	1.62

Attachment B - Table 1 to 40 CFR Subpart WWWW - Applicability of General Provisions to Subpart WWWW

As required in 40 CFR 63.10440, you must comply with the requirements of the General Provisions (40 CFR part 63, subpart A) shown in the following table:

Citation	Subject	Applies to subpart WWWW	Explanation
§63.1(a) (1)-(4), (6), (10)-(12), (b)(1), (3)	Applicability	Yes	
§63.1(a) (5), (7)-(9)	[Reserved]		
§63.1(b)(2)	[Reserved]		
§63.1(c) (1)-(2)	Applicability of 40 CFR Part 63 after a relevant standard has been set	Yes	40 CCFR 63.10446 exempts affected sources from the obligation to obtain title V operating permits for purposes of being subject to 40 CFR 63 Subpart WWWW.
§63.1(c) (3)-(4)	[Reserved]		
§63.1(c)(5)	Subject to notification requirements	No	
§63.1(d)	[Reserved]		
§63.1(e)	Emission limitation by permit	Yes	
§63.2	Definitions	Yes	
§63.3	Units and abbreviations	Yes	
§63.4	Prohibited activities	Yes	
§63.5	Construction/reconstruction	No	
§63.6(a), (b)(1)-(5), (7)	Compliance with standards and maintenance requirements	Yes	
§63.6(b)(6)	[Reserved]		
§63.6(c)(1)	Compliance dates for existing sources	Yes	Subpart WWWW requires compliance 1 year after the effective date.
§63.6(c) (2), (5)	Compliance dates for CAA section 112(f) standards and for area sources that become major	No	
§63.6(c) (3)-(4)	[Reserved]		
§63.6(d)	[Reserved]		

Citation	Subject	Applies to subpart WWWW	Explanation
§63.6(e)-(h)	Alternative nonopacity emission standard	No	
§63.6(i)-(j)	Compliance extension	Yes	
§63.7	Performance testing requirements	No	
§63.8	Monitoring requirements	No	
§63.9(a)	Applicability and initial notifications addressees	Yes	
§63.9(b)	Initial notifications	No	
§63.9(c)	Request for extension of compliance	Yes	
§63.9(d)-(j)	Other notifications	No	
§63.10(a)(1)-(2)	Recordkeeping and reporting requirements, applicability	Yes	
§63.10(a)(3)-(4)	General information	Yes	
§63.10(a)(5)-(7)	Recordkeeping and reporting requirements, reporting schedules	No	
§63.10(b)(1)	Retention time	Yes	
§63.10(b)(2)-(f)	Recordkeeping and reporting requirements	No	
§63.11	Control device requirements	No	
§63.12	State authority and delegations	Yes	
§§63.13-63.16	Addresses, Incorporations by Reference, availability of information, performance track provisions	Yes	