

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

BUREAU OF AIR

DIVISION of AIR POLLUTION CONTROL

PERMIT SECTION

PROJECT SUMMARY for the
DRAFT CLEAN AIR ACT PERMIT PROGRAM (CAAPP) PERMIT

City of Chicago-Department of Aviation
O'Hare International Airport, Chicago, Illinois 60666

Illinois EPA ID Number: 031600FQP

Application Number: 95110002

Application Type: Renewal

Start of Public Comment Period: April 19, 2007

Close of Public Comment Period: May 19, 2007

Permit Engineer/Technical Contact: Anatoly Belogorsky, 217/782-2113

Community Relations/Comments Contact: Brad Frost, 217/782-7027

(This Project Summary generally describes the source and explains the draft permit. This document has been prepared pursuant to Section 39.5(8)(b) of the Illinois Environmental Protection Act, which requires "a statement that sets forth the legal and factual basis for the draft CAAPP permit conditions.")

I. INTRODUCTION

This source has applied for a renewal of the Clean Air Act Permit Program (CAAPP) operating permit. The CAAPP is the program established in Illinois for operating permits for significant stationary sources as required by Title V of the federal Clean Air Act and Section 39.5 of Illinois' Environmental Protection Act. The conditions in a CAAPP permit are enforceable by the Illinois Environmental Protection Agency (Illinois EPA), the USEPA, and the public. This document is for informational purposes only and does not shield the Permittee from enforcement actions or its responsibility to comply with applicable regulations. This document shall not constitute a defense to a violation of the Act or any rule or regulation.

A CAAPP permit contains conditions identifying the applicable state and federal air pollution control requirements that apply to a source. The permit also establishes emission limits, appropriate compliance procedures, and specific operational flexibility. The appropriate compliance procedures may include monitoring, record keeping, and reporting to show compliance with these requirements. The Permittee must carry out these procedures on an on-going basis to demonstrate that the source is operating in accordance with the requirements of the permit. Further explanations of the specific provisions of the draft CAAPP permit are contained in the attachments to this document, which also identify the various emission units at the source.

II. GENERAL SOURCE DESCRIPTION

a. Nature of source

City of Chicago-Department of Aviation is located at O'Hare International Airport in Chicago and operates airport support operations (boilers, emergency turbines, storage). The City of Chicago owns the O'Hare International Airport, all of which is located on contiguous property. The City of Chicago leases property to many other parties who may or may not operate stationary emission sources of air pollution within the boundaries of the O'Hare International Airport. Some of the major airlines which operate at the O'Hare International Airport conduct their own airplane maintenance. Since the City of Chicago does not control the operations of these companies, along with other smaller tenants, it has been determined that the stationary sources of air pollution operated by these airlines are not part of the same Part 70 site as the stationary sources of air pollution operated by the City of Chicago-Department of Aviation. City of Chicago-Department of Fleet Management operated at O'Hare International Airport is a support facility for Department of Aviation operations, and therefore it requires a separate CAAPP permit.

b. Ambient air quality status for the area

This source is located in an area that is designated non-attainment of the National Ambient Air Quality Standards for ozone and PM_{2.5} and attainment for all other criteria pollutants.

c. Major source status

The source requires a CAAPP permit as a major source of NO_x and SO₂ emissions.

d. Source Emissions

The following table lists actual annual emissions of criteria pollutants from this source, as reported in the Annual Emission Reports sent to the Illinois EPA.

Pollutant	Annual Emissions (tons)				
	2001	2002	2003	2004	2005
CO	5.77	5.47	25.91	29.23	29.23
NO _x	6.88	6.52	38.72	38.72	38.72
PM	0.52	0.49	3.04	3.04	3.04
SO ₂	0.06	0.1	6.57	6.57	6.57
VOM	0.43	0.41	2.29	2.29	2.29

III. NEW SOURCE REVIEW / TITLE I CONDITIONS

This draft permit contains terms and conditions that address the applicability of permit programs for new and modified sources under Title I of the Clean Air Act (CAA) and regulations promulgated thereunder, including 40 CFR 52.21, Prevention of Significant Deterioration (PSD) and 35 IAC Part 203, Major Stationary Sources Construction and Modification. Any such terms and conditions are identified within the draft permit by T1, T1R, or T1N. Any conditions established in a construction permit pursuant to Title I and not revised or deleted in this draft permit, remain in effect pursuant to Title I provisions until such time that the Illinois EPA revises or deletes them. Where the source has requested that the Illinois EPA establish new conditions or revise such conditions in a Title I permit, those conditions are consistent with the information provided in the CAAPP application and will remain in effect pursuant to Title I provisions until such time that the Illinois EPA revises or deletes them.

This draft permit establishes new Title I requirements for the following units:

Boilers: EU-7 (ID BLR-008L01 through 008L03); EU-8 (ID BLR-62001 & 62002)

Turbine: EU-6 (ID EG-891L01)

The new limits are established because no construction permits with federally enforceable limits had been established at the time of construction of those units.

IV. COMPLIANCE INFORMATION

The source has certified compliance with all applicable rules and regulations; therefore, a compliance schedule is not required for this source. In addition, the draft permit requires the source to certify its compliance status on an annual basis. Also, the Annual Emission Reports and latest inspection report have been reviewed which indicate compliance.

However, the source had violated the timeline for the submission of the CAAPP renewal application (9 months prior to an expiration date). Current renewal CAAPP application was received by Illinois EPA on March 1, 2007, months after expiration date (June 18, 2006) of the CAAPP permit for this source. Currently, the enforcement case is under review of the Illinois Attorney General Office.

V. PROPOSED ILLINOIS EPA ACTION / REQUEST FOR COMMENTS

It is the Illinois EPA's preliminary determination that this source's permit application meets the standards for issuance of a CAAPP permit. The Illinois EPA is therefore proposing to issue a CAAPP permit, subject to the conditions proposed in the draft permit.

Comments are requested by the Illinois EPA for the draft or proposed permit, pursuant to 35 IAC Part 252 and Sections 39.5(8) and (9) of the Illinois Environmental Protection Act. A final decision on the draft or proposed permit will not be made until the public, affected states, and USEPA have had an opportunity to comment. The Illinois EPA is not required to accept recommendations that are not based on applicable requirements. If substantial public interest is shown in this matter, the Illinois EPA will consider holding a public hearing in accordance with 35 IAC Part 166.

ATTACHMENT 1: Summary of Source-Wide Requirements

- a. The following table indicates the source-wide emissions control programs and planning requirements that are applicable to this source. These programs are addressed in Sections 5 and 6 of the draft permit.

Program/Plan	Applicable
Emissions Reduction Market System (ERMS)	Y
Nitrogen Oxides (NO _x) Trading Program	N/A
Acid Rain Program	N/A
Fugitive Particulate Matter (PM) Operating Program	Y
Risk Management Plan (RMP)	N/A
PM ₁₀ Contingency Measure Plan	N/A

- b. The following table indicates source-wide site-specific requirements addressed in Section 5 of the draft permit.

Non-Applicable Rules and Requirements w/justification
<ul style="list-style-type: none"> • None
Title I Conditions and/or Synthetic Minor Limits
<ul style="list-style-type: none"> • None
Testing, Monitoring and Recordkeeping
<ul style="list-style-type: none"> • <u>Testing</u>: General requirements
<ul style="list-style-type: none"> • <u>Monitoring</u>: N/A
<ul style="list-style-type: none"> • <u>Recordkeeping</u>: General requirements

ATTACHMENT 2: Summary of Requirements for Specific Emission Units

The following tables include information on the requirements that apply to significant emission units at this source. The requirements are found in Section 7 of the draft permit, which is further divided into subsection, i.e., Section 7.1, 7.2, etc., for the different categories of units at the source. A separate table is provided for each subsection in Section 7 of the draft permit. An explanation of acronyms and abbreviations is contained in Section 2 of the draft permit.

Table 1 (Section 7.1 of the draft permit)

Emission Unit	
Name	Boilers
Description	Natural gas and distillate fuel oil #2 external combustion units located at the source are used to produce steam and hot water for maintenance and comfort heating purposes
Date Constructed	1968 through 2005
Emission Control Equipment	None
Applicable Rules and Requirements	
Emission Standards	<ul style="list-style-type: none"> • 35 IAC 216.121: CO limitation • 35 IAC 212.206: PM limitation for burning fuel oil • 35 IAC 214.122(b)(2): SO₂ limitation for burning fuel oil • 35 IAC 212.123(a): opacity limitation
Streamlining	N/A
Title I Conditions	<ul style="list-style-type: none"> • <u>EU-2 (ID HTWG-4001 through HTWG-4008):</u> TI conditions carried over from initial CAAPP permit • <u>EU-7 (ID BLR-008L01 through 008L03):</u> TIN conditions first time established in this permit • <u>EU-8 (ID BLR-62001 & 62002):</u> TIN conditions first time established in this permit

Non-applicability (justification)	<ul style="list-style-type: none"> • 35 IAC 217.141: each boiler is less than 250 mmBtu/hr • 35 IAC Part 218, Subpart G: exemption for fuel combustion emission units based on 35 IAC 218.303 • 40 CFR 60.43c(c): boilers are less than 30 mmBtu/hr; larger boilers constructed prior to 1989 • 40 CFR Part 64, Compliance Assurance Monitoring (CAM): the affected boiler does not use an add-on control device
Periodic Monitoring (other than basic regulatory requirements)	
Testing	<ul style="list-style-type: none"> • Testing opacity once a year. Boilers fire natural gas and use fuel oil #2 for backup purposes • Testing PM emissions once every five years while burning fuel oil #2 (fuel oil #2 is used for backup purposes) • Sampling and analyzing of the initial tank of oil and demonstrating that it contains less than the required weight percent sulfur (fuel oil #2 is used for backup purposes)
Emissions Monitoring	<ul style="list-style-type: none"> • Monitoring of the sulfur content in fuel oil
Operational Monitoring	<ul style="list-style-type: none"> • No direct operational monitoring is established
Inspections	<ul style="list-style-type: none"> • No inspection requirements are established
Recordkeeping	<ul style="list-style-type: none"> • Natural gas and fuel oil usage • Emissions released • Records of tests (sampling)
Reporting	
Prompt Reporting	<ul style="list-style-type: none"> • Excess of production and emission limits within 30 days of occurrence • See also Attachment 3 for Prompt Reporting of Deviations
Other Reporting	N/A
Other Information	
Footnotes	N/A

Table 2 (Section 7.2 of the draft permit)

Emission Unit	
Name	Emergency Turbine
Description	One emergency diesel fuel-fired turbine is used as a back-up unit in cases of power loss
Date Constructed	1987
Emission Control Equipment	None
Applicable Rules and Requirements	
Emission Standards	<ul style="list-style-type: none"> • 35 IAC 218.301: hourly VOM emission limit • 40 CFR 60 Subpart GG "Standards of Performance for Stationary Gas Turbines", 40 CFR 60.333: sulfur dioxide emissions; sulfur content in the fuel oil • 35 IAC 212.123(a): opacity limit
Streamlining	N/A
Title I Conditions	<ul style="list-style-type: none"> • <u>EU-3 (ID EG-H4007)</u>: TI conditions carried over from initial CAAPP permit

Non-applicability (justification)	<ul style="list-style-type: none"> • 40 CFR 60.332(a) (Standards for Nitrogen Oxides): the turbine is operated on the emergency basis only and excluded from applicability pursuant to 40 CFR 60.332(g) • 40 CFR Part 63, Subpart ZZZZ: the source is not major for HAP emissions • 40 CFR Part 64, Compliance Assurance Monitoring (CAM): the affected turbine does not use an add-on control device
Periodic Monitoring (other than basic regulatory requirements)	
Testing	<ul style="list-style-type: none"> • Testing opacity once a year (turbine is used for emergency standby purposes only) • Sulfur dioxide emissions upon request • Sulfur content in fuel oil (turbine is used for emergency standby purposes only)
Emissions Monitoring	<ul style="list-style-type: none"> • Monitoring of the sulfur content in fuel oil
Operational Monitoring	<ul style="list-style-type: none"> • No direct operational monitoring is established
Inspections	<ul style="list-style-type: none"> • No inspection requirements are established
Recordkeeping	<ul style="list-style-type: none"> • Fuel oil usage • Hours of operation • Emissions released • Sulfur content in fuel oil • Records of tests (sampling)
Reporting	
Prompt Reporting	<ul style="list-style-type: none"> • Excess of production and emission limits within 30 days of occurrence • See also Attachment 3 for Prompt Reporting of Deviations
Other Reporting	N/A
Other Information	
Footnotes	N/A

Table 3 (Section 7.3 of the draft permit)

Emission Unit	
Name	Emergency Diesel Generator
Description	One emergency diesel fuel-fired internal combustion generator is used as a back-up unit in cases of power loss
Date Constructed	2002

Emission Control Equipment	None
Applicable Rules and Requirements	
Emission Standards	<ul style="list-style-type: none"> • 35 IAC 218.301: hourly VOM emission limit • 35 IAC 212.123(a): opacity limit
Streamlining	N/A
Title I Conditions	<ul style="list-style-type: none"> • <u>EU-6 (ID EG-891L01):</u> TIN conditions first time established: • Fuel oil usage shall not exceed 87.3 gallons per hour and 43,650 gallons per year. • Emissions: CO – 2.53 t/yr; PM – 0.21 t/yr; NO_x – 9.56 t/yr; SO₂ – 0.92 t/yr; VOM – 0.30 t/yr
Non-applicability (justification)	<ul style="list-style-type: none"> • 40 CFR Part 63, Subpart ZZZZ: the source is not major for HAP emissions • 40 CFR Part 64, Compliance Assurance Monitoring (CAM): the affected turbine does not use an add-on control device
Periodic Monitoring (other than basic regulatory requirements)	
Testing	<ul style="list-style-type: none"> • Testing opacity once a year (engine is used for emergency standby purposes only)
Emissions Monitoring	<ul style="list-style-type: none"> • No emission monitoring is established
Operational Monitoring	<ul style="list-style-type: none"> • No direct operational monitoring is established
Inspections	<ul style="list-style-type: none"> • No inspection requirements are established
Recordkeeping	<ul style="list-style-type: none"> • Fuel oil usage • Hours of operation • Emissions released • Records of tests
Reporting	
Prompt Reporting	<ul style="list-style-type: none"> • Excess of production and emission limits within 30 days of occurrence • See also Attachment 3 for Prompt Reporting of Deviations
Other Reporting	N/A

Other Information	
Footnotes	N/A

Table 4 (Section 7.4 of the draft permit)

Emission Unit	
Name	Storage Tanks
Description	Runway deicing fluid storage tanks are associated with runway deicing operations performed at the source
Date Constructed	1999
Emission Control Equipment	None
Applicable Rules and Requirements	
Emission Standards	N/A
Streamlining	N/A
Title I Conditions	<ul style="list-style-type: none"> • TI conditions carried over from initial CAAPP permit

Non-applicability (justification)	<ul style="list-style-type: none"> • 35 IAC 218.120: maximum true vapor pressure of deicing fluid stored in such tanks is less than 0.5 psia • 35 IAC 218.122: vapor pressure of deicing fluid stored in such tanks is less than 2.5 psia • 40 CFR Part 64, Compliance Assurance Monitoring (CAM): the affected storage tank does not use an add-on control device
Periodic Monitoring (other than basic regulatory requirements)	
Testing	N/A
Emissions Monitoring	N/A
Operational Monitoring	<ul style="list-style-type: none"> • No direct operational monitoring is established
Inspections	<ul style="list-style-type: none"> • No inspection requirements are established
Recordkeeping	<ul style="list-style-type: none"> • Deicing fluid throughput • Emissions released • True vapor pressure • Recordkeeping and reporting is sufficient because storage tanks emit negligible emissions
Reporting	
Prompt Reporting	<ul style="list-style-type: none"> • Excess of production and emission limits within 30 days of occurrence • See also Attachment 3 for Prompt Reporting of Deviations
Other Reporting	N/A
Other Information	
Footnotes	N/A

ATTACHMENT 3: Prompt Reporting of Deviations

Prompt reporting of deviations is critical in order to have timely notice of deviations and the opportunity to respond, if necessary. The effectiveness of the permit depends upon, among other important elements, timely and accurate reporting. The Illinois EPA, USEPA and the public rely on timely and accurate reports submitted by the permittee to measure compliance and to direct investigation and follow-up activities. Prompt reporting is evidence of a permittee's good faith in disclosing deviations and describing the steps taken to return to compliance and prevent similar incidents.

Any occurrence that results in an excursion from any emission limitation, operating condition, or

work practice standard as specified in this CAAPP permit is a deviation subject to prompt reporting. Additionally, any failure to comply with any permit term or condition is a deviation of that permit term or condition and must be reported to the Illinois EPA as a permit deviation. The deviation may or may not be a violation of an emission limitation or standard. A permit deviation can exist even though other indicators of compliance suggest that no emissions violation or exceedance has occurred. Reporting permit deviations does not necessarily result in enforcement action. The Illinois EPA has the discretion to take enforcement action for permit deviations that may or may not constitute an emission limitation or standard or the like, as necessary and appropriate.

Section 39.5(7)(f)(ii) of the Illinois Environmental Protection Act, which mirrors 40 CFR 70.6(a)(3)(iii)(B), requires prompt reporting of deviations from the permit requirements. The permitting authority (in this case, Illinois EPA) has the discretion to define “prompt” in relation to the degree and type of deviation likely to occur. Furthermore, Section 39.5(7)(f)(i) of the Illinois Environmental Protection Act, which mirrors 40 CFR 70.6(a)(3)(iii)(A) requires that monitoring reports must be submitted at least every 6 months. Therefore, USEPA generally considers anything less than 6 months to be “prompt” as long as the selected time frame is justified appropriately (60 Fed. Reg. 36083, 36086 (July 13, 1995)).

The USEPA has stated that, for purposes of administrative efficiency and clarity, it is acceptable to define prompt in each individual permit. *Id.* The Illinois EPA has elected to follow this approach and defines prompt reporting on a permit by permit basis. In instances where the underlying applicable requirement contains “prompt” reporting, this frequency or a shorter frequency of reporting is the required timeframe used in this permit. Where the underlying applicable requirement fails to explicitly set forth the timeframe for reporting deviations, the Illinois EPA has developed a structured manner to determine the reporting approach used in this permit.

The Illinois EPA generally uses a time frame of 30 days to define prompt reporting of most deviations. Also, for certain permit conditions in individual permits, the Illinois EPA may require an alternate timeframe that is less than 30 days if the permit requirement justifies a shorter reporting time period. Under certain circumstances, EPA may establish a deviation reporting period longer than 30 days, but, in no event exceeding 6 months. Where it has established a deviation reporting period other than 30 days in an individual permit (specifically Section 7.x.10), the Illinois EPA has explained the reason for the alternative timeframe. (See Attachment 2 of this Project Summary.)

The timing for certain deviation reporting may be different when a source or emission unit at a source warrants reporting to address operation, independent of the occurrence of any deviations. This is the case for a source that is required to perform continuous monitoring for the emission unit, for which quarterly or semi-annual “monitoring” reports are appropriate. Where appropriate, reporting of deviations has generally been combined in, or coordinated with these quarterly or semi-annual reports, so that the overall performance of the plant can be reviewed in a comprehensive fashion. This will allow a more effective and efficient review of the overall performance of the source by the Illinois EPA and other interested parties, as well as by the source itself.

At the same time, there are certain deviations for which quicker reporting is appropriate. These are deviations for which individual attention or concern may be warranted by the Illinois EPA, USEPA,

and other interested parties. Under this scenario, emphasis has been placed primarily on deviations that could represent substantial violations of applicable emission standards or lapses in control measures at the source. For these purposes, depending on the deviation, immediate notification may be required and preceded by a follow-up report submitted within 15 days, during which time the source may further assess the deviation and prepare its detailed plan of corrective action.

In determining the timeframe for prompt reporting, the Illinois EPA assesses a variety of criteria such as:

- historical ability to remain in continued compliance,
- level of public interest in a specific pollutant and/or source,
- seriousness of the deviation and potential to cause harm,
- importance of applicable requirement to achieving environmental goals,
- designation of the area (i.e., non-attainment or attainment),
- consistency among industry type and category,
- frequency of required continuous monitoring reports (i.e., quarterly),
- type of monitoring (inspection, emissions, operational, etc.), and
- air pollution control device type and operation

These prompt reporting decisions reflect the Illinois EPA's consideration of the possible nature of deviations by different emission units and the responses that might be required or taken for those different types of deviations. As a consequence, the conditions for different emission units may identify types of deviations which include but are not limited to: 1) Immediate (or very quick) notification; 2) Notification within 30 days as the standard; or 3) Notification with regular quarterly or semi-annual monitoring reports.

The Illinois EPA's decision to use the above stated prompt reporting approach for deviations as it pertains to establishing a shorter timeframe in certain circumstances reflects the criteria discussed as well as USEPA guidance on the topic.

- 40 CFR 71.6(a)(3)(iii)(B) specifies that certain potentially serious deviations must be reported within 24 or 48 hours, but provides for semi-annual reporting of other deviations. (Serious or severe consequences)
- FR Vol. 60, No. 134, July 13, 1995, pg. 36086 states that prompt should generally be defined as requiring reporting within two to ten days of the deviation, but longer time periods may be acceptable for a source with a low level of excess emissions. (intermediate consequences)
- Policy Statement typically referred to as the "Audit Policy" published by the USEPA defines prompt disclosure to be within 21 days of discovery. (Standard for most "pollutant limiting" related conditions)
- Responses to various States by USEPA regarding other States' definition of prompt.

As a result, the Illinois EPA's approach to prompt reporting for deviations as discussed herein is consistent with the requirements of 39.5(7)(f)(ii) of the Act as well as 40 CFR part 70 and the CAA. This reporting arrangement is designed so that the source will appropriately notify the Illinois EPA of those events that might warrant individual attention. The timing for these event-specific notifications is necessary and appropriate as it gives the source enough time to conduct a thorough investigation into the causes of an event, collecting any necessary data, and to develop preventative measures, to reduce the likelihood of similar events, all of which must be addressed in the notification for the

deviation.