

Statement of Basis

for the DRAFT CAAPP Permit for:

Source Name:

Natural Gas Pipeline of America

Statement of Basis No.: 197817AAA-1204
I.D. No.: 197817AAA
Permit No.: 02120051
Date Prepared: September 4, 2012

Permitting Authority:

Illinois Environmental Protection Agency
Bureau of Air, Permit Section
217/785-1705



Table of Contents

PREFACE

INTRODUCTION

CHAPTER I - LEGAL BASIS FOR THE PERMIT AND PERMIT CONDITIONS

- 1.1 Legal Basis for Program
- 1.2 Legal Basis for Issuance of CAAPP Permit
 - a. Application Status
 - b. Compliance Status
 - c. Payment of Fees
 - d. Additional Information Status
- 1.3 Legal Basis for Conditions in the CAAPP Permit
 - a. Applicable Federal Regulations
 - b. Applicable SIP Regulations
 - c. Other Applicable Requirements

CHAPTER II - FACTUAL BASIS FOR THE PERMIT AND PERMIT CONDITIONS

- 2.1 Source History
- 2.2 Source Description
- 2.3 Single Source Status
- 2.4 Ambient Air Quality Status
- 2.5 Source Status
- 2.6 Annual Emissions
- 2.7 Fee Schedule
- 2.8 SIP Permit Facts

CHAPTER III - SUPPLEMENTAL INFORMATION REGARDING THE PERMIT AND CONDITIONS

- 3.1 Environmental Justice
- 3.2 Emission Testing Results
- 3.3 Compliance Reports
- 3.4 Field Inspection Results
- 3.5 Historical Non-Compliance
- 3.6 Source Wide Justifications and Rationale
- 3.7 Emission Unit Justifications and Rationale
 - a. Turbines
 - b. Natural Gas Fired Boiler
 - c. Storage Tank
- 3.8 Insignificant Activities Discussion
- 3.9 Prompt Reporting Discussion
- 3.10 Greenhouse Gas Discussion
- 3.11 Incorporation by Reference Discussion
- 3.12 Periodic Monitoring General Discussions

CHAPTER IV - DESCRIPTION OF THE CHANGES FROM PREVIOUSLY ISSUED CAAPP PERMITS

4.1Major Changes Summary

4.2Specific Permit Condition Changes

ENDNOTES

PREFACE

Reason For This Document

This document is a requirement of the permitting authority in accordance with 502(a) of the Clean Air Act, 40 CFR 70.7(a)(5), and Section 39.5(8)(b) of the Illinois Environmental Protection Act. Section 39.5(8)(b) of the Illinois Environmental Protection Act states the following:

"The Agency shall prepare a statement that sets forth the legal and factual basis for the Draft CAAPP permit conditions, including references to the applicable statutory or regulatory provisions."

Purpose Of This Document

The purpose of this Statement of Basis is to provide discussion regarding the development of this Draft CAAPP Permit. This document would also provide the permitting authority, the public, the source, and the USEPA with the applicability and technical matters that form the basis of the Draft CAAPP Permit.

Summary Of Historical Actions Leading Up To Today's Permitting Action

Since the last Renewal CAAPP Permit issued on November 24, 2003, the source has also been issued the following: Compressor Station 113 Minor Modification to Existing Operating Permit 40 CFR 60 Subpart GG sulfur monitoring removal request.

Limitations

This Statement of Basis is not enforceable and only sets forth the legal and factual basis for the Draft CAAPP Permit Conditions (Chapters I and II). Chapter III contains supplemental material that would assist in educating interested parties about this source and the Draft CAAPP Permit. The Statement of Basis does not shield the source from enforcement actions or its responsibility to comply with existing or future applicable regulations. Nor does the Statement of Basis constitute a defense to a violation of the Federal Clean Air Act or the Illinois Environmental Protection Act including implementing regulations.

This document does not purport to establish policy or guidance.

INTRODUCTION

The Clean Air Act Permit Program (CAAPP) is the operating permit program established in Illinois for major stationary sources as required by Title V of the federal Clean Air Act and Section 39.5 of the Illinois Environmental Protection Act. The Title V Permit Program (CAAPP) is the primary mechanism to apply the various air pollution control requirements established by the Clean Air Act to major sources, defined in accordance with Title V of the Clean Air Act. The Draft CAAPP Permit contains conditions identifying the state and federal applicable requirements that apply to the source. The Draft CAAPP Permit also establishes the necessary monitoring and compliance demonstrations. The source must implement this monitoring to demonstrate that the source is operating in accordance with the applicable requirements of the permit. The Draft CAAPP Permit identifies all applicable requirements for the various emission units as well as establishes detailed provisions for testing, monitoring, recordkeeping, and reporting to demonstrate compliance with the Clean Air Act. Further explanations of the specific provisions of the Draft CAAPP Permit are contained in the following Chapters of this Statement of Basis.

The Illinois EPA has focused in on key elements of the permit that relate to the requirements of the CAAPP Program:

- Emissions of:
 - PM
 - NO_x
 - VOM
 - SO₂

- Emission units:
 - ENG-1 Through ENG-9 (Solar Saturn - T1400)
 - ENG 10 (Solar Taurus 70-T10302S)
 - 3 mmBtu/hr Natural Gas Boiler (01-BOL)
 - 270 Gallon Gasoline Storage Tank (GT1)

CHAPTER I - LEGAL BASIS FOR THE PERMIT AND PERMIT CONDITIONS

1.1 Legal Basis for Program

The Illinois EPA's state operating permit program for major sources established to meet the requirements of 40 CFR Part 70 are found at Section 39.5 of the Illinois Environmental Protection Act [415 ILCS 5/39.5]. The program is called the Clean Air Act Permitting Program (CAAPP). The underlying statutory authority is found in the Illinois Environmental Protection Act at 415 ILCS 5/39.5. The CAAPP was given final full approval by USEPA on December 4, 2001 (see 66 FR 62946).

1.2 Legal Basis for Issuance of CAAPP Permit

In accordance with Section 39.5(10)(a) of the Illinois Environmental Protection Act, the Illinois EPA may only issue a CAAPP Permit if all of the following standards for issuance have been met:

- The applicant has submitted a complete and certified application for a permit, permit modification, or permit renewal consistent with Sections 39.5(5) and (14) of the Illinois Environmental Protection Act, as applicable, and applicable regulations (Section a. below);
- The applicant has submitted with its complete application an approvable compliance plan, including a schedule for achieving compliance, consistent with Section 39.5(5) of the Illinois Environmental Protection Act and applicable regulations (Section b. below);
- The applicant has timely paid the fees required pursuant to Section 39.5(18) of the Illinois Environmental Protection Act and applicable regulations (Section c. below); and
- The applicant has provided any additional information as requested by the Illinois EPA (Section d. below).

a. Application Status

The source submitted an application for a Renewal CAAPP Permit on November 24, 2003. The source is currently operating under an application shield resultant from a timely and complete renewal application submittal. This Draft CAAPP Permit addresses application content and necessary revisions to meet the requirements for issuance of the permit.

b. Present Compliance Status

At the time of this Draft CAAPP Permit, there were no pending State or Federal enforcement actions against the source; therefore, a Compliance Schedule is not required for this source. The source submitted an approvable Compliance Plan as part of its Certified Permit Application. The source has certified compliance with all applicable rules and regulations. In addition, the draft permit requires the source to certify its compliance status on an annual basis.

c. Payment of Fees

The source is current on payment of all fees associated with operation of the emission units.

d. Additional Information

The source was not required to submit any additional application material.

1.3 Legal Basis for Conditions in the CAAPP Permit

This industrial source is subject to a variety of Federal and SIP regulations, which are the legal basis for the conditions in this permit (see Sections a. and b. below). Also, the CAAPP provides the legal basis for additional requirements such as periodic monitoring, reporting, and recordkeeping. The following list summarizes those regulations that form the legal basis for the conditions in this Draft CAAPP Permit and are provided in the permit itself as the origin and authority.

a. Applicable Federal Regulations

This source operates emission units that are subject to the following Federal regulations.

40 CFR Part 60 - Subpart GG, Standards of Performance for Stationary Gas Turbines

b. Applicable SIP Regulations

This source operates emission units that are subject to the following SIP regulations:

35 IAC Part 201 - Permits And General Provisions
35 IAC Part 212 - Visible And Particulate Matter Emissions
35 IAC Part 214 - Sulfur Limitations
35 IAC Part 217 - Nitrogen Oxides Emissions
35 IAC Part 218 - Organic Material Emis Stnds And Lmtns For The Chicago Area
35 IAC Part 244 - Episodes
35 IAC Part 254 - Annual Emissions Report

c. Other Applicable Requirements

There are no other applicable requirements for this source.

CHAPTER II - FACTUAL BASIS FOR THE PERMIT AND PERMIT CONDITIONS

2.1 Source History

There is no significant source history warranting discussion for this source.

2.2 Description of Source

SIC Code: 4922
County: Will

The source operates a natural gas pipeline compressor station. Natural gas fired compressor turbines at Station 113 are used to raise the pressure of the natural gas and move it along the pipeline, transporting natural gas from production areas to utilities and other customers.

The source contains the following processes:

<i>Emission Units</i>	<i>Description</i>
ENG-10 (Solar Taurus 70-T10302S)	Solar Taurus Turbine Equipped with Low-NO _x Combustor (ISO rated output 10,300 hp)
ENG-1 through ENG-9 (Solar Saturn - T1400)	Nine Solar Saturn Turbines (ISO Rated output 1,450 Hp Each)
01-BOL (Kewanee Boiler)	3.0 mmBtu/hr Natural Gas Boiler
GT1	270 Gallon Gasoline Storage Tank

2.3 Single Source Status

This source does not have any collocated facilities that would be considered a single source with this facility based on information found in the certified application.

2.4 Ambient Air Quality Status for the Area

The source is located in an area that is currently designated nonattainment for the National Ambient Air Quality Standards for ozone (moderate nonattainment) and attainment or unclassifiable for all other criteria pollutants (carbon monoxide, lead, nitrogen dioxide, PM_{2.5}, PM₁₀, sulfur dioxide). (See 40 CFR Part 81 - Designation of Areas for Air Quality Planning Purposes)

2.5 Source Status

The source requires a CAAPP permit because this source is considered major (based on its PTE) for the following regulated pollutants: nitrogen oxides (NO_x), carbon monoxide (CO), green house gas (GHG).

The source also requires a CAAPP Permit because the source is subject to a standard, limitation, or other requirement under Section 111 (NSPS) or Section 112 (HAPs) of the CAA for which USEPA requires a CAAPP Permit, or because the source is in a source category designated by the USEPA. Specifically, this source is subject to 40 CFR 60 Subpart GG and 40 CFR 63 Subpart DDDDD.

This source is considered a natural minor for the following regulated pollutants: PM₁₀, PM_{2.5}, volatile organic material (VOM), sulfur dioxide (SO₂) and hazardous air pollutant (HAP).

Based on available data, this source is a major source of emissions for GHG, with potential emissions of GHG that are more than 100,000 tons per year (CO₂e). Natural Gas Pipeline Company of America submitted data in its application for which the Illinois EPA estimated the PTE of GHG emissions to be 134,372.07 tons per year. The emissions consist of 134,268.34 tons of CO₂, 78.32 tons of N₂O, and 53.06 tons of methane.

This source is not currently subject to any "applicable requirements," as defined by Section 39.5(1) of the Act, for emissions of greenhouse gases (GHG) as defined by 40 CFR 86.1818-12(a), as referenced by 40 CFR 52.21(b)(49)(i). There are no GHG-related requirements under the Illinois Environmental Protection Act, Illinois' State Implementation Plan, or the Clean Air Act that apply to this facility, including terms or conditions in a Construction Permit addressing emissions of GHG or BACT for emissions of GHG from a major project at this facility under the PSD rules. In particular, the USEPA's Mandatory Reporting Rule for GHG emissions, 40 CFR Part 98, does not constitute an "applicable requirement" because it was adopted under the authority of Sections 114(a)(1) and 208 of the Clean Air Act. This permit also does not relieve the Permittee from the legal obligation to comply with the relevant provisions of the Mandatory Reporting Rule for this facility.

2.6 Annual Emissions

The following table lists annual emissions (tons) of criteria pollutants for this source, as reported in the Annual Emission Reports (AER) sent to the Illinois EPA:

<i>Pollutant</i>	<i>2011</i>	<i>2010</i>	<i>2009</i>	<i>2008</i>	<i>2007</i>
CO	56.69	23.68	43.49	4.78	22.02
NO _x	26.03	15.19	21.46	2.44	16.52
PM	0.37	0.08	0.27	0.03	0.03
SO ₂	0.19	0.04	0.14	0.01	0.01
VOM	0.74	0.64	0.70	0.81	0.01
CO _{2E}	7764.92	1262.31	4353.20	1078.00	200,408.56
HAP (total)	----	----	----	----	----

2.7 Fee Schedule

The following table lists the approved annual fee schedule (tons) submitted in the Source's permit application:

<i>Pollutant</i>	<i>Tons/Year</i>
Volatile Organic Material (VOM)	4.96
Sulfur Dioxide (SO ₂)	2.66
Particulate Matter (PM)	5.23
Nitrogen Oxides (NO _x)	183.40
HAP, not included in VOM or PM (HAP)	----
Total	196.25

2.8 SIP Permit Facts (T1 Limits)

CAAPP Permits must address all "applicable requirements," which includes the terms and conditions of preconstruction permits issued under regulations approved by USEPA in accordance with Title I of the CAA (See definition of

applicable requirements in Section 39.5(1) of the Illinois Environmental Protection Act). Preconstruction permits, commonly referred to in Illinois as Construction Permits, derive from the New Source Review ("NSR") permit programs required by Title I of the CAA. These programs include the two major NSR permit programs: (1) the Prevention of Significant Deterioration ("PSD") program¹ and (2) the nonattainment NSR program.² These programs also encompass state construction permit programs for projects that are not major.

In the CAAPP or Illinois's Title V permit program, the Illinois EPA's practice is to identify requirements that are carried over from an earlier Title I permit into a New or Renewed CAAPP Permit as "TI" conditions (i.e., Title I conditions). Title I Conditions that are revised as part of their incorporation into a CAAPP Permit are further designated as "TIR." Title I Conditions that are newly established through a CAAPP Permit are designated as "TIN". It is important that Title I Conditions be identified in a CAAPP Permit because these conditions will not expire when the CAAPP Permit expires. Because the underlying authority for Title I Conditions comes from Title I of the CAA and their initial establishment in Title I Permits, the effectiveness of T1 Conditions derives from Title I of the CAA rather than being linked to Title V of the A. For "changes" to be made to Title I Conditions, they must either cease to be applicable based on obvious circumstances, e.g., the subject emission unit is permanently shut down, or appropriate Title I procedures must be followed to change the conditions.

- Previously Incorporated Construction Permits:

<i>Permit No.</i>	<i>Date Issued</i>	<i>Subject</i>
01030010	April 17, 2002	Gas turbines upgrade and new turbine installation

- The Illinois EPA has not recently issued Construction Permits for this source.
- There are no newly issued Construction Permits for projects not yet constructed for this source.
- The Illinois EPA has not established any T1R or T1N Limits in this Draft CAAPP permit.
- There are no extraneous or obsolete T1 conditions for the source.

CHAPTER III - SUPPLEMENTAL DISCUSSIONS REGARDING THE PERMIT

The information provided in this Chapter of the Statement of Basis is being provided to assist interested parties in understanding what additional information may have been relied on to support this draft CAAPP permit.

3.1 Environmental Justice Discussions

This location has not been identified as a potential concern for Environmental Justice consideration.

3.2 Emission Testing Results

The source has performed the following emission testing:

<i>Emission Unit</i>	<i>Date</i>	<i>Pollutant</i>	<i>Results of Run #1</i>	<i>Results of Run #2</i>	<i>Results of Run #3</i>	<i>3-Run Average</i>	<i>Compliance Margin %</i>
ENG-10 (Solar Taurus 70-T10302S)	8/27/09	CO, Low Load	1.43 lb/hr	1.31 lb/hr	1.53 lb/hr	1.42 lb/hr	86.7%
ENG-10 (Solar Taurus 70-T10302S)	8/27/09	NO _x , Base Load	6.36 lb/hr	5.68 lb/hr	6.83 lb/hr	6.29 lb/hr	28.4%
ENG-10 (Solar Taurus 70-T10302S)	8/27/09	VOM, Low Load	0.11 lb/hr	0.06 lb/hr	0.12 lb/hr	0.10 lb/hr	50%

Note: These results are based on the load which would give the greatest emissions. The load is listed in the pollutant column. VOM was only measured at low load.

3.3 Compliance Reports (Annual Certifications, Semiannual Monitoring, NESHAP, etc.)

A review of the source's compliance reports demonstrates the sources ability to comply with all applicable requirements.

3.4 Field Inspection Results

A review of the source's latest field inspection report, dated January 13, 2009, demonstrates the source's ability to comply with all applicable requirements.

3.5 Historical Non-Compliance

There is no historical non-compliance for this source.

3.6 Source Wide Justifications and Rationale

Applicable Requirements Summary		
Applicable Requirement	Type	Location
Fugitive Particulate Matter (35 IAC 212.301 and 35 IAC 212.314)	Applicable Standard	See the Permit, Condition 3.1(a)

Particulate Matter Emission

- ✓ Monitoring as follows (Condition 3.1(a)(ii))
 - o If required, daily observations for a week for PM emissions.
- ✓ Recordkeeping as follows (Condition 3.1(a)(ii)):
 - o If required, records for the observations.
- ✓ Reporting as follows (Condition 3.1(a)(ii)):
 - o If required, reports for the observations.

Rationale and Justification for Periodic Monitoring

Periodic Monitoring is sufficient for these emission units because:

- The source has a substantial margin of compliance.
- Source has not exhibited a history of non-compliance.
- Monitoring is consistent with other sources in this source category.

Non-Applicability Discussion

Complex source-wide non-applicability determinations were not made for this source.

Prompt Reporting Discussion

Prompt reporting of deviations for source wide emission units has been established as 30 days. See rationale in Chapter III Section 9.

3.7 Emission Unit Justifications and Rationale

a. Turbines		
Applicable Requirements Summary		
Applicable Requirement	Type	Location
Opacity Requirement (35 IAC 212.123)	Applicable Standard	See the Permit, Condition 4.1.2(a)
PM Limitation (Construction Permit #01030010)	Applicable Limit	See the Permit, Condition 4.1.2(b)
SO ₂ Requirement (40 CFR 60.333(a) and (b))	Applicable Standard	See the Permit, Condition 4.1.2(c)
SO ₂ Requirement (35 IAC 214.301)	Applicable Standard	See the Permit, Condition 4.1.2(c)
SO ₂ Limitation (Construction Permit #01030010)	Applicable Limit	See the Permit, Condition 4.1.2(c)
VOM Requirement (35 IAC 218.143)	Applicable Standard	See the Permit, Condition 4.1.2(d)
VOM Limitation (Construction Permit #01030010)	Applicable Limit	See the Permit, Condition 4.1.2(d)
CO Limitation (Construction Permit #01030010)	Applicable Limit	See the Permit, Condition 4.1.2(e)
NO _x Requirement (40 CFR 60.322(a)(2))	Applicable Standard	See the Permit, Condition 4.1.2(f)
NO _x Requirement (35 IAC 217.386(a)(2))	Applicable Standard	See the Permit, Condition 4.1.2(f)

a. Turbines		
Applicable Requirements Summary		
Applicable Requirement	Type	Location
NO _x Requirement (35 IAC 217.388(a))	Applicable Standard	See the Permit, Condition 4.1.2(f)
NO _x Requirement (35 IAC 217.392)	Applicable Standard	See the Permit, Condition 4.1.2(f)
NO _x Limitation (Construction Permit #01030010)	Applicable Limit	See the Permit, Condition 4.1.2(f)
Operational and Production Requirement (Construction Permit #01030010)	Applicable Standard	See the Permit, Condition 4.1.2(g)(i)
Operational and Production Requirement (Construction Permit #01030010)	Applicable Limit	See the Permit, Condition 4.1.2(g)(i)
Operational and Production Requirement (Construction Permit #01030010)	Applicable Work Practice	See the Permit, Condition 4.1.2(g)(ii)
Work Practice Requirement (39.5(7) of the Act)	Applicable Work Practice	See the Permit, Condition 4.1.2(h)

Visible Emissions (i.e., Opacity)

- ✓ Monitoring as follows (Condition 4.1.2(a)(ii)(A))
 - o Annual Method 22 observations
 - o If required, Method 9 measurements
- ✓ Recordkeeping as follows (Conditions 4.1.2(a)(ii)(B) and (a)(ii)(C)):
 - o Records of each Method 22 observation
 - o If required, records of each Method 9 measurement
- ✓ Reporting as follows (Condition 4.1.5(a)):
 - o Prompt reporting within 30 days

Rationale and Justification for Periodic Monitoring

Periodic Monitoring is sufficient for these emission units because:

- There is a small likelihood of an exceedance.
- Emissions do not vary significantly under normal operation and/or vary slowly with time.
- Source has not exhibited a history of non-compliance.
- Monitoring is consistent with other sources in this source category.
- Pursuant to Construction Permit #01030010, hours of operation are limited to 8,760 hr/yr for the larger turbine and 39,420 hrs/yr total for the nine smaller turbines. The source is also required to maintain inspection, maintenance, and repair logs of the turbines. These records would help the Illinois EPA determine if the turbines are properly operated and therefore would result in minimized emissions.
- Pursuant to Construction Permit #01030010, hours of operation are limited to 8,760 hr/yr for the larger turbine and 39,420 hrs/yr total for the nine smaller turbines. The source is also required to maintain inspection, maintenance, and repair logs of the turbines. These records would help the Illinois EPA determine if the turbines are properly operated and therefore would result in minimized emissions.

Sulfur Emissions

- ✓ Monitoring as follows (Condition 4.1.2(h)(ii)(A))
 - o Monthly inspections of turbine
 - o Instrumentation to monitor turbine parameters

- ✓ Recordkeeping as follows (Conditions 4.1.2(b)(ii), 4.1.2(g)(ii)(A) and 4.1.2(h)(ii)(B)):
 - o Record of custom fuel schedule
 - o Records of inspections, maintenance, and repairs
 - o Records of operating parameters for each turbine
 - o Records of instrumentation
 - o Records of incidents of noncompliance
 - o Records of emissions

Rationale and Justification for Periodic Monitoring

Periodic Monitoring is sufficient for these emission units because:

- There is a small likelihood of an exceedance.
- Emissions do not vary significantly under normal operation and/or vary slowly with time.
- Source has not exhibited a history of non-compliance.
- Monitoring is consistent with other sources in this source category.
- Emissions are considered negligible
- Pursuant to Construction Permit #01030010, hours of operation are limited to 8,760 hr/yr for the larger turbine and 39,420 hrs/yr total for the nine smaller turbines. The source is also required to maintain inspection, maintenance, and repair logs of the turbines. These records would help the Illinois EPA determine if the turbines are properly operated and therefore would result in minimized emissions.
- Natural gas is the only fuel used.
- The likelihood of natural gas engines violating the sulfur limit is unlikely. Pipeline quality natural gas has sulfur content limited to levels that would result in SO₂ emissions less than the limit. The likelihood of natural gas turbines violating the sulfur limit is unlikely. Pursuant to 40 CFR 60.331(u) to be considered natural gas it must contain 20.0 grains or less of total sulfur per 100 standard cubic feet (680 ppmw or 338 ppmv), thus resulting in SO₂ emissions less than the 2,000 ppm limit as per 35 IAC 214.301. Furthermore, pursuant to 40 CFR 72.2 to be considered pipeline quality natural gas it must contain 0.5 grains sulfur/ 100 scf or less (less than 1.0 ppm). It should also be noted that the source is also required to maintain the type of fuel used, maintain inspection records, and maintain maintenance and repair logs of the natural gas turbines. These records would help the Illinois EPA determine if the natural gas turbines are being operated properly and therefore would result in SO₂ being minimized.

Carbon Monoxide Emissions

- ✓ Testing as follows (Condition 4.1.2(e)(ii)(B))
 - o Within 60 days after operating the substitute turbine at the greatest load at which it will normally be operated but not later than 80 days after its initial startup, the Permittee shall have

emissions tests for the turbines performed by an approved testing service in accordance with the test methods and procedures specified in 40 CFR 60.335, unless USEPA approves alternative procedures for testing.

- ✓ Monitoring as follows (Condition 4.1.2(h)(ii)(A))
 - Monthly inspections of turbine
 - Instrumentation to monitor turbine parameters
- ✓ Recordkeeping as follows (Conditions 4.1.2(g)(ii)(A) and 4.1.2(h)(ii)(B)):
 - Records of inspections, maintenance, and repairs
 - Records of operating parameters for each turbine
 - Records of instrumentation
 - Records of incidents of noncompliance
 - Records of emissions

Rationale and Justification for Periodic Monitoring

Periodic Monitoring is sufficient for these emission units because:

- Emissions do not vary significantly under normal operation and/or vary slowly with time.
- Source has not exhibited a history of non-compliance.
- Monitoring is consistent with other sources in this source category.
- CO emission testing is required for substitute turbines to insure compliance.
- Pursuant to Construction Permit #01030010, hours of operation are limited to 8,760 hrs/yr for the larger turbine and 39,420 hrs/yr total for the nine smaller turbines. The source is also required to maintain inspection, maintenance, and repair logs of the turbines. These records would help the Illinois EPA determine if the turbines are properly operated and therefore would result in minimized emissions.

Nitrogen Oxides Emissions

- ✓ Testing as follows (Conditions 4.1.2(f)(ii)(F), 4.1.2(f)(ii)(G), and 4.1.2(f)(ii)(I))
 - Within 60 days after operating the substitute turbine at the greatest load at which it will normally be operated but not later than 80 days after its initial startup, the Permittee shall have emissions tests for the turbines performed by an approved testing service in accordance with the test methods and procedures specified in 40 CFR 60.335, unless USEPA approves alternative procedures for testing
 - For the larger turbine (ENG-10), performance tests once every five years. Testing must be performed in the calendar year by May 1 or within 60 days after starting operation, whichever is later. The test shall use the applicable procedures and methods in 40 CFR 60.4400, as incorporated by reference in 35 IAC 217.104
- ✓ Monitoring as follows (Conditions 4.1.2(f)(ii)(A), 4.1.2(f)(ii)(C), 4.1.2(f)(ii)(D), and 4.1.2(h)(ii)(A))
 - Monitor the nitrogen content of the fuel combusted in the turbine. The nitrogen content of the fuel shall be determined using methods described in 40 CFR 60.335(b)(9) or an approved alternative

- o Monitor NO_x concentrations annually, once between January 1 and May 1 or within the first 876 hours of operation per calendar year, whichever is later. If annual operation is less than 876 hours per calendar year, the turbines must be monitored at least once every five years. The Permittee shall use a portable NO_x monitor utilizing method ASTM D6522-00, as incorporated by reference in 35 IAC 217.104
 - o The larger turbine (ENG-10) shall be equipped, operated and maintained with dry low-NO_x burners
 - o Monthly inspections of turbine
 - o Instrumentation to monitor turbine parameters
- ✓ Recordkeeping as follows (Conditions 4.1.2(f)(ii)(J), 4.1.2(g)(ii)(A), and 4.1.2(h)(ii)(B)):
- o Records that demonstrate compliance with the requirements of 35 IAC 217 Subpart Q for the larger turbine (ENG-10)
 - o Records of inspections, maintenance, and repairs
 - o Records of operating parameters for each turbine
 - o Records of instrumentation
 - o Records of incidents of noncompliance
 - o Records of emissions
- ✓ Reporting as follows (Condition 4.1.2(f)(ii)(H)):
- o Pursuant to 35 IAC 217.394(b)(2), if the monitoring required in Condition 4.1.2(f)(ii)(C) shows that the larger turbine (ENG-10) is not in compliance with the applicable emissions concentration, the owner or operator must report the deviation to the IEPA in writing within 30 days

Rationale and Justification for Periodic Monitoring

Periodic Monitoring is sufficient for these emission units because:

- Source has not exhibited a history of non-compliance.
- Monitoring is consistent with other sources in this source category.
- NO_x emission testing is required for substitute turbines to insure compliance.
- NO_x emission testing, performed once every five years, is required to demonstrate adherence to 35 IAC 217.394 derived from BACT and compared to initial stack test results.
- Pursuant to Construction Permit #01030010, hours of operation are limited to 8,760 hrs/yr for the larger turbine and 39,420 hrs/yr total for the nine smaller turbines. The source is also required to maintain inspection, maintenance, and repair logs of the turbines. These records would help the Illinois EPA determine if the turbines are properly operated and therefore would result in minimized emissions.

Organic Material Emission

- ✓ Testing as follows (Condition 4.1.2(d)(ii)(B)):
- o Within 60 days after operating the substitute turbine at the greatest load at which it will normally be operated but not later than 80 days after its initial startup, the Permittee shall have emissions tests for the turbines performed by an approved testing service in accordance with the test methods and procedures specified in 40 CFR 60.335, unless USEPA approves alternative

procedures for testing

- ✓ Monitoring as follows (Condition 4.1.2(h)(ii)(A))
 - o Monthly inspections of turbine
 - o Instrumentation to monitor turbine parameters

- ✓ Recordkeeping as follows (Conditions 4.1.2(d)(ii)(C), 4.1.2(g)(ii)(A), and 4.1.2(h)(ii)(B))
 - o Records of the monthly and annual aggregate VOM emissions from the turbine blowdown, using calculation from Condition 4.1.2(d)(i)(IV)
 - o Records of inspections, maintenance, and repairs
 - o Records of operating parameters for each turbine
 - o Records of instrumentation
 - o Records of incidents of noncompliance
 - o Records of emissions

Rationale and Justification for Periodic Monitoring

Periodic Monitoring is sufficient for these emission units because:

- There is a small likelihood of an exceedance.
- Emissions do not vary significantly under normal operation and/or vary slowly with time.
- Source has not exhibited a history of non-compliance.
- Monitoring is consistent with other sources in this source category.
- Emissions are considered negligible
- VOM emission testing is required for substitute turbines to insure compliance.
- Pursuant to Construction Permit #01030010, hours of operation are limited to 8,760 hrs/yr for the larger turbine and 39,420 hrs/yr total for the nine smaller turbines. The source is also required to maintain inspection, maintenance, and repair logs of the turbines. These records would help the Illinois EPA determine if the turbines are being operated properly and therefore would result in PM emissions being minimized.

Non-Applicability Discussion

Complex non-applicability determinations were not made for this emission unit. All non-applicability discussions can be found in the Draft CAAPP Permit.

Prompt Reporting Discussion

Prompt reporting of deviations has been established as 30 days. See rationale in Chapter III Section 9.

b. Natural Gas Fired Boiler		
Applicable Requirements Summary		
Applicable Requirement	Type	Location
Opacity Requirement (35 IAC 212.123)	Applicable Standard	See the Permit, Condition 4.2.2(a)
Operational and Production Requirement (39.5(7) of the Act)	Applicable Standard	See the Permit, Condition 4.2.2(c)

Visible Emissions (i.e., Opacity)

- ✓ Monitoring as follows (Condition 4.1.2(a)(ii)(A))
 - o Annual Method 22 observations
 - o If required, Method 9 measurements

- ✓ Recordkeeping as follows (Condition 4.1.2(a)(ii)(B) and (a)(ii)(C)):
 - o Records of each Method 22 observation
 - o If required, records of each Method 9 measurement

- ✓ Reporting as follows (Condition 4.1.5(a)):
 - o Prompt reporting within 30 days

Rationale and Justification for Periodic Monitoring

Periodic Monitoring is sufficient for these emission units because:

- There is a small likelihood of an exceedance.
- Emissions do not vary significantly under normal operation and/or vary slowly with time.
- Source has not exhibited a history of non-compliance.
- Monitoring is consistent with other sources in this source category.
- Emissions are considered negligible
- Pursuant to Construction Permit #01030010, hours of operation are limited to 8,760 hrs/yr for the larger turbine and 39,420 hrs/yr total for the nine smaller turbines. The source is also required to maintain inspection, maintenance, and repair logs of the turbines. These records would help the Illinois EPA determine if the turbines are properly operated and therefore would result in minimized emissions.

Non-Applicability Discussion

Complex non-applicability determinations were not made for this emission unit. All non-applicability discussions can be found in the Draft CAAPP Permit.

Prompt Reporting Discussion

Prompt reporting of deviations has been established as 30 days. See rationale in Chapter III Section 8.

c. Storage Tank		
Applicable Requirements Summary		
Applicable Requirement	Type	Location
VOM Requirement (35 IAC 218.122(b) and 35 IAC 218.583(a)(1))	Applicable Standard	See the Permit, Condition 4.3.2(a)
Work Practice Requirement (39.5(7)(a) of the Act)	Applicable Work Practice	See the Permit, Condition 4.3.2(b)

Organic Material Emission

- ✓ Recordkeeping as follows (Condition 4.3.2(a)(ii)(A)):
 - o Maintain records of the presence of the submerged loading pipe

Rationale and Justification for Periodic Monitoring

Periodic Monitoring is sufficient for this emission unit because:

- The source has a substantial margin of compliance.
- There is a small likelihood of an exceedance.
- Emissions do not vary significantly under normal operation and/or vary slowly with time.
- Source has not exhibited a history of non-compliance.
- Monitoring is consistent with other sources in this source category.

Work Practice Requirements

- ✓ Monitoring as follows (Condition 4.3.2(b)(ii)(A))
 - o Annual inspection of tank and associated equipment
- ✓ Recordkeeping as follows (Condition 4.3.2(b)(ii)(B)):
 - o Keep inspection records, maintenance records, and repair log

Rationale and Justification for Periodic Monitoring

Periodic Monitoring is sufficient for this emission unit because:

- The source has a substantial margin of compliance.
- There is a small likelihood of an exceedance.
- Emissions do not vary significantly under normal operation and/or vary slowly with time.
- Source has not exhibited a history of non-compliance.
- Monitoring is consistent with other sources in this source category.

Non-Applicability Discussion

Complex non-applicability determinations were not made for this emission unit. All non-applicability discussions can be found in the Draft CAAPP Permit.

Prompt Reporting Discussion

Prompt reporting of deviations has been established as 30 days. See rationale in Chapter III Section 8.

3.8 Insignificant Activities Discussion

There are no insignificant activities for the source subject to specific regulations which are obligated to comply with Sections 9.1(d) and Section 39.5 of the Act; Sections 165, 173, and 502 of the Clean Air Act; or any other applicable permit or registration requirements and therefore there are no periodic monitoring requirements that need to be separately addressed.

3.9 Prompt Reporting Discussion

Among other terms and conditions, CAAPP Permits contain reporting obligations to assure compliance with applicable requirements. These reporting obligations are generally four-fold. More specifically, each CAAPP Permit sets forth any reporting requirements specified by state or federal law or regulation, requires prompt reports of deviations from applicable requirements, requires

reports of deviations from required monitoring and requires a report certifying the status of compliance with terms and conditions of the CAAPP Permit over the calendar year.

The number and frequency of reporting obligations in any CAAPP Permit is source-specific. That is, the reporting obligations are directly related to factors, including the number and type of emission units and applicable requirements, the complexity of the source and the compliance status. This four-fold approach to reporting is common to virtually all CAAPP Permits as described below. Moreover, this is the approach established in the Draft CAAPP Permit for this source.

Regulatory Reports

Many state and federal environmental regulations establish reporting obligations. These obligations vary from rule-to-rule and thus from CAAPP source to CAAPP source and from CAAPP Permit to CAAPP Permit. The variation is found in the report triggering events, reporting period, reporting frequency and reporting content. Regardless, the CAAPP makes clear that all reports established under applicable regulations shall be carried forward into the CAAPP Permit as stated in Section 39.5(7)(b) of the Illinois Environmental Protection Act. Generally, where sufficiently detailed to meet the exacting standards of the CAAPP, the regulatory reporting requirements are simply restated in the CAAPP Permit. Depending on the regulatory obligations, these regulatory reports may also constitute a deviation report as described below.

The Draft CAAPP Permit for this source would embody all regulatory reporting as promulgated under federal and state regulations under the Clean Air Act and the Illinois Environmental Protection Act. Depending on the frequency of the report, the regulatory report may also satisfy the prompt reporting obligations discussed below. These reports must be certified by a responsible official.

These reports are generally found in the reporting sections for each emission unit group. The various regulatory reporting requirements are summarized in the table at the end of this Reporting Section.

Deviation Reports (Prompt Reporting)

Section 39.5(7)(f)(ii) of the Illinois Environmental Protection Act mandates that each CAAPP Permit require prompt reporting of deviations from the permit requirements.

Neither the CAAPP nor the federal rules upon which the CAAPP is based and was approved by USEPA define the term "prompt". Rather, 40 CFR Part 70.6(a)(3)(iii)(B) intended that the term have flexibility in application. The USEPA has acknowledged for purposes of administrative efficiency and clarity that the permitting authority (in this case, Illinois EPA) has the discretion to define "prompt" in relation to the degree and type of deviation likely to occur at a particular source. The Illinois EPA follows this approach and defines prompt reporting on a permit-by-permit basis. In instances where the underlying applicable requirement contains "prompt" reporting, the Illinois EPA typically incorporates the pre-established timeframe in the CAAPP permit (e.g. a NESHAP or NSPS deviation report). Where the underlying applicable requirement fails to explicitly set forth the timeframe for reporting deviations, the Illinois EPA generally uses a timeframe of 30 days to define prompt reporting of deviations.

This approach to prompt reporting of deviations as discussed herein is consistent with the requirements of Section 39.5(7)(f)(ii) of the Illinois Environmental Protection Act as well as 40 CFR Part 70 and the CAA. The reporting arrangement is designed so that the source will appropriately notify the Illinois EPA of those events that might warrant attention. The timing for these event-specific notifications is necessary and appropriate as it gives the source enough time to conduct a thorough investigation into the causes of an event, collecting any necessary data, and developing preventive measures, to reduce the likelihood of similar events, all of which must be addressed in the notification for the deviation, while at the same time affording regulatory authority and the public timely and relevant information. The approach also affords the Illinois EPA and USEPA an opportunity to direct investigation and follow-up activities, and to make compliance and enforcement decisions in a timely fashion.

The Draft CAAPP Permit for this source would require prompt reporting as required by the Illinois Environmental Protection Act in the fashion described in this subsection. In addition, pursuant to Section 39.5(7)(f)(i) of the Illinois Environmental Protection Act, this Draft CAAPP Permit would also require the source to provide a summary of all deviations with the Semi-Annual Monitoring Report. These reports must be certified by a responsible official, and are generally found in the reporting sections for each emission unit group.

Semi-Annual Monitoring Reports

Section 39.5(7)(f)(i) of the Illinois Environmental Protection Act mandates that each CAAPP Permit require a report relative to monitoring obligations as set forth in the permit. Depending upon the monitoring obligation at issue, the semi-annual monitoring report may also constitute a deviation report as previously discussed. This monitoring at issue includes instrumental and non-instrumental emissions monitoring, emissions analyses, and emissions testing established by state or federal laws or regulations or as established in the CAAPP Permit. This monitoring also includes recordkeeping. Each deviation from each monitoring requirement must be identified in the relevant semi-annual report. These reports provide a timely opportunity to assess for compliance patterns of concern. The semi-annual reports shall be submitted regardless of any deviation events. Reporting periods for semi-annual monitoring reports are January 1 through June 30 and July 1 through December 31 of each calendar year. Each semi-annual report is due within 30 days after the close of reporting period. The reports shall be certified by a responsible official. The Draft CAAPP Permit for this source would require such reports at Condition 3.5(b).

Annual Compliance Certifications

Section 39.5(7)(p)(v) of the Illinois Environmental Protection Act mandates that each CAAPP Permit require a source to submit a certification of its compliance status with each term and condition of its CAAPP Permit. The reports afford a broad assessment of a CAAPP sources compliance status. The CAAPP requires that this report be submitted, regardless of compliance status, on an annual basis. Each CAAPP Permit requires this annual certification be submitted by May 1 of the year immediately following the calendar year reporting period. The report shall be certified by a responsible official. The Draft CAAPP Permit for this source would require such a report at Condition 2.6(a).

Prompt reporting of deviations is critical in order to have timely notice of deviations and the opportunity to respond, if necessary. The effectiveness

of the permit depends upon, among other important elements, timely and accurate reporting. The Illinois EPA, USEPA, and the public rely on timely and accurate reports submitted by the source to measure compliance and to direct investigation and follow-up activities. Prompt reporting is evidence of the source's good faith in disclosing deviations and describing the steps taken to return to compliance and prevent similar incidents.

Any occurrence that results in an excursion from any emission limitation, operating condition, or work practice standard as specified in this Draft CAAPP Permit is a deviation subject to prompt reporting. Additionally, any failure to comply with any permit term or condition is a deviation of that permit term or condition and must be reported to the Illinois EPA as a permit deviation. The deviation may or may not be a violation of an emission limitation or standard. A permit deviation can exist even though other indicators of compliance suggest that no emissions violation or exceedance has occurred. Reporting permit deviations does not necessarily result in enforcement action. The Illinois EPA has the discretion to take enforcement action for permit deviations that may or may not constitute a deviation from an emission limitation or standard or the like, as necessary and appropriate.

As a result, the Illinois EPA's approach to prompt reporting of deviations as discussed herein is consistent with the requirements of Section 39.5(7)(f)(ii) of the Illinois Environmental Protection Act as well as 40 CFR Part 70 and the CAA. This reporting arrangement is designed so that the source will appropriately notify the Illinois EPA of those events that might warrant individual attention.

3.10 Greenhouse Gas Provisions

On June 3, 2010, USEPA adopted rules for the initial permitting of major sources of emissions of greenhouse gases (GHG). See, 75 FR 31514-31608. Prompted by the earlier adoption of GHG emissions standards for motor vehicles under Title II of the CAA, the USEPA's rules implement a two-phased program for permitting major sources of GHG under Title V permit programs.³ As Illinois EPA is planning to issue a permit to this source during the second phase of the rules, GHG emissions must be addressed during this CAAPP permitting action.⁴ Annual Emission Reports submitted to the Illinois EPA by this source and/or estimated GHG emissions by the Illinois EPA, which detail the source's actual annual emissions of GHG, provide the necessary data to appropriately address emissions of GHG in the Draft CAAPP Permit. The data in these reports clearly show the source is a major source for emissions of GHG.

The new federal rules also require subject Title V sources to comply with any applicable GHG-related requirements that arise from other CAA programs.⁵ However, there are currently no emission standards or other regulatory obligations relating to GHG that constitute "applicable requirements" for this source. For this reason, the Draft CAAPP Permit for this source does not contain any substantive requirements for GHG. At the federal level, the only venue that could potentially establish GHG-related requirements at this time is the PSD program. As of January 2, 2011, sources triggering PSD must evaluate GHG emissions resulting from projects that trigger the major source or major modification rules.⁶ This source has neither constructed such a project, nor received a permit authorizing such a project, since January 2, 2011, to the present, and therefore has not triggered any GHG-related requirements under the PSD program.

There are no other GHG-related requirements established under the CAA that are applicable to this source at this time. In particular, the mandatory reporting rule for GHG promulgated by USEPA in 2009 [see *generally*, 40 CFR Part 98] is not an applicable requirement and therefore would not be included in the Draft CAAPP Permit for this source. There are also no GHG-related requirements under the Illinois Environmental Protection Act or contained within Illinois' SIP that apply to the source at this time. Other state laws or regulations in Illinois relating to GHG, including efforts to reduce emissions of GHG under authority other than the Illinois Environmental Protection Act, do not constitute applicable requirements under the CAAPP.

3.11 Incorporation by Reference Discussion

Based on guidance found in White Paper 2 and past petition responses by the Administrator, it is recognized that Title V permit authorities may, within their discretion, incorporate plans by reference. As recognized in the *White Paper 2*, permit authorities can effectively streamline the contents of a Title V permit, avoiding the inevitable clutter of restated text and preventing unnecessary delays where, as here, permit issuance is subject to a decision deadline.⁷ However, it is also recognized that the benefits of incorporation of plans must be carefully balanced by a permit authority with its duty to issue permits in a way that is "clear and meaningful" to the Permittee and the public.⁸

The criteria that are mentioned in USEPA Administrator Petition Responses stress the importance of identifying, *with specificity*, the object of the incorporation.⁹ The Illinois EPA agrees that such emphasis is generally consistent with USEPA's pronouncements in previous guidance.

For each condition incorporating a plan, the Illinois EPA is also briefly describing the general manner in which the plan applies to the source. Identifying the nature of the source activity, the regulatory requirements or the nature of the equipment associated with the plan is a recommendation of the *White Paper 2*¹⁰. The Illinois EPA has stopped short of enumerating the actual contents of a plan, as restating them in the permit would plainly defeat the purpose of incorporating the document by reference and be contrary to USEPA guidance on the subject.¹¹

Plans may need to be revised from time to time, as occasionally required by circumstance or by underlying rule or permit requirement. Except where expressly precluded by the relevant rules, this Draft CAAPP Permit allows the Permittee to make future changes to a plan without undergoing formal permit revision procedures. This approach will allow flexibility to make required changes to a plan without separately applying for a revised permit and, similarly, will lessen the impacts that could result for the Illinois EPA if every change to a plan's contents required a permitting transaction.¹² Changes to the incorporated plans during the permit term are automatically incorporated into the Draft CAAPP Permit unless the Illinois EPA expresses a written objection. The exception to this practice is the PM₁₀ Contingency Measure Plan, for which a permit revision is needed for any changes to the plan.¹³

The Draft CAAPP Permit incorporates by reference the following plans: Fugitive Particulate Matter Operating Program, PM₁₀ Contingency Plan, Episode Action Plan, and Risk Management Plan.¹⁴

3.12 Periodic Monitoring General Discussions

Pursuant to Section 504(c) of the Clean Air Act, a Title V permit must set forth monitoring requirements, commonly referred to as "Periodic Monitoring," to assure compliance with the terms and conditions of the permit. A general discussion of Periodic Monitoring is provided below. The Periodic Monitoring that is proposed for specific operations and emission units and at this source is discussed in Chapter III of this Statement of Basis. Chapter III provides a narrative discussion of and justification for the elements of Periodic Monitoring that would apply to the different emission units and types of emission units at the facility.

As a general matter, the required content of a CAAPP Permit with respect to such Periodic Monitoring is addressed in Section 39.5(7) of the Illinois Environmental Protection Act.¹⁵ Section 39.5(7)(b) of the Illinois Environmental Protection Act¹⁶ provides that in a CAAPP Permit:

The Agency shall include among such conditions applicable monitoring, reporting, record keeping and compliance certification requirements, as authorized by paragraphs d, e, and f of this subsection, that the Agency deems necessary to assure compliance with the Clean Air Act, the regulations promulgated thereunder, this Act, and applicable Board regulations. When monitoring, reporting, record keeping and compliance certification requirements are specified within the Clean Air Act, regulations promulgated thereunder, this Act, or applicable regulations, such requirements shall be included within the CAAPP Permit.

Section 39.5(7)(d)(ii) of the Illinois Environmental Protection Act further provides that a CAAPP Permit shall:

Where the applicable requirement does not require periodic testing or instrumental or noninstrumental monitoring (which may consist of recordkeeping designed to serve as monitoring), require Periodic Monitoring sufficient to yield reliable data from the relevant time period that is representative of the source's compliance with the permit

...

Accordingly, the scope of the Periodic Monitoring that must be included in a CAAPP Permit is not restricted to monitoring requirements that were adopted through rulemaking or imposed through permitting. When applicable regulatory emission standards and control requirements or limits and control requirement in relevant Title 1 permits are not accompanied by compliance procedures, it is necessary for Monitoring for these standards, requirements or limits to be established in a CAAPP Permit.^{17, 18} Monitoring requirements must also be established when standards and control requirement are accompanied by compliance procedures but those procedures are not adequate to assure compliance with the applicable standards or requirements.^{19, 20} For this purpose, the requirements for Periodic Monitoring in a CAAPP Permit may include requirements for emission testing, emissions monitoring, operational monitoring, non-instrumental monitoring, and recordkeeping for each emission unit or group of similar units at a facility, as required by rule or permit, as appropriate or as needed to assure compliance with the applicable substantive requirements. Various combinations of monitoring measures will be appropriate for different emission units depending on their circumstances, including the substantive emission standards, limitations and control requirements to which they are subject.

What constitutes sufficient Periodic Monitoring for particular emission units, including the timing or frequency associated with such Monitoring requirements, must be determined by the permitting authority based on its knowledge, experience and judgment.²¹ For example, as Periodic Monitoring must collect representative data, the timing of Monitoring requirements need not match the averaging time or compliance period of the associated substantive requirements, as set by the relevant regulations and permit provisions. The timing of the various requirements making up the Periodic Monitoring for an emission unit is something that must be considered when those Monitoring requirements are being established. For this purpose, Periodic Monitoring often consists of requirements that apply on a regular basis, such as routine recordkeeping for the operation of control devices or the implementation of the control practices for an emission unit. For certain units, this regular monitoring may entail "continuous" monitoring of emissions, opacity or key operating parameters of a process or its associated control equipment, with direct measurement and automatic recording of the selected parameter(s). As it is infeasible or impractical to require emissions monitoring for most emission units, instrumental monitoring is more commonly conducted for the operating parameters of an emission unit or its associated control equipment. Monitoring for operating parameter(s) serves to confirm proper operation of equipment, consistent with operation to comply with applicable emission standards and limits. In certain cases, an applicable rule may directly specify that a particular level of an operating parameter be maintained, consistent with the manner in which a unit was being operated during emission testing. Periodic Monitoring may also consist of requirements that apply on a periodic basis, such as inspections to verify the proper functioning of an emission unit and its associated controls.

The Periodic Monitoring for an emission unit may also include measures, such as emission testing, that would only be required once or only upon specific request by the Illinois EPA. These requirements would always be accompanied by Monitoring requirements would apply on a regular basis. When emission testing or other measure is only required upon request by the Illinois EPA, it is included as part of the Periodic Monitoring for an emission unit to facilitate a response by the Illinois EPA to circumstances that were not contemplated when Monitoring was being established, such as the handling of a new material or a new mode of operation. Such Monitoring would also serve to provide further verification of compliance, along with other potentially useful information. As emission testing provides a quantitative determination of compliance, it would also provide a determination of the margin of compliance with the applicable limit(s) and serve to confirm that the Monitoring required for an emission unit on a regular basis is reliable and appropriate. Such testing might also identify specific values of operating parameters of a unit or its associated control equipment that accompany compliance and can be relied upon as part of regular Monitoring.

There are a number of considerations or factors that are or may be relevant when evaluating the need to establish new monitoring requirements as part of the Periodic Monitoring for an emission unit. These factors include: (1) The nature of the emission unit or process and its emissions; (2) The variability in the operation and the emissions of the unit or process over time; (3) The use of add-on air pollution control equipment or other practices to control emissions and comply with the applicable substantive requirement(s); (4) The nature of that control equipment or those control practices and the potential for variability in their effectiveness; (5) The nature of the applicable substantive requirement(s) for which Periodic Monitoring is needed; (6) The nature of the compliance procedures that specifically accompany the applicable

requirements; (7) The type of data that would already be available for the unit; (8) The effort needed to comply with the applicable requirements and the expected margin of compliance; (9) The likelihood of a violation of applicable requirements; (10) The nature of the Periodic Monitoring that may be readily implemented for the emission unit; (11) The extent to which such Periodic Monitoring would directly address the applicable requirements; (12) The nature of Periodic Monitoring commonly required for similar emission units at other facilities and in similar circumstances; (13) The interaction or relationship between the different measures in the Periodic Monitoring for an emission unit; and (14) The feasibility and reasonableness of requiring additional measures in the Periodic Monitoring for an emission unit in light of other relevant considerations.²²

CHAPTER IV - CHANGES FROM PREVIOUSLY ISSUED CAAPP PERMITS

4.1 Major Changes Summary

This renewal CAAPP draft is presented in a new format. The new format is the result of recommendations by the USEPA, comments made by sources, and interactions with the public.

	<i>Previous CAAPP Permit Layout</i>	<i>New CAAPP Permit Layout</i>
Section 1	Source Identification	Source Information
Section 2	List Of Abbreviations/Acronyms	General Permit Requirements
Section 3	Insignificant Activities	Source Requirements
Section 4	Significant Emission Units	Emission Unit Requirements
Section 5	Overall Source Conditions	Title I Requirements
Section 6	Emission Control Programs	Insignificant Activities
Section 7	Unit Specific Conditions	Other Requirements
Section 8	General Permit Conditions	State Only Requirements
Section 9	Standard Permit Conditions	---
Section 10	Attachments	Attachments

4.2 Specific Permit Condition Changes

Since the previously issued CAAPP Permit, the source is now subject to 35 IAC 217 Subpart Q. The source also has a 270-gallon gasoline tank, and a 3.0 mmBtu/hr boiler, which are not insignificant activities as presented in the current CAAPP application.

Endnotes

¹ The federal PSD program, 40 CFR 52.21, applies in Illinois. The Illinois EPA administers PSD permitting for major projects in Illinois pursuant to a delegation agreement with USEPA.

² Illinois has a state nonattainment NSR program, pursuant to state rules, Major Stationary Sources Construction and Modification ("MSSCM"), 35 IAC Part 203, which have been approved by USEPA as part of the State Implementation Plan for Illinois.

³ The new rules apply the first phase of permitting to sources already subject to Title V by virtue of their conventional, non-GHG pollutants. As noted above, these sources are expected to address GHG in their permitting applications and to comply with any substantive requirements for GHG that have been established through other CAA programs such as PSD. The second phase of permitting that begins July 1, 2011, essentially applies the same requirements to sources who will become subject to Title V based on their GHG emissions alone (i.e., existing or newly constructed sources with a potential to emit of equal to or greater than 100,000 tons per year of CO₂e and 100 tons per year of GHG on a mass basis).

⁴ USEPA has stated that the first phase of its new rules requires existing Title V sources to address GHG in their Title V applications by citing to any pollutants for which the Title V source is major and to all regulated air pollutants. See, PSD and Title V Permitting Guidance for Greenhouse Gases, prepared by the Office of Air Quality Planning and Standards, page 51 (November 2010).

⁵ See generally, PSD and Title V Permitting Guidance for GHG at pages 53-56.

⁶ A major source subject to PSD based on potential emissions of a non-GHG pollutant and potential emissions of GHG equal or greater than 75,000 tons per year of CO₂e is required to address GHG emissions in evaluating control options and associated monitoring, reporting, etc, for any construction of a new major source or a major modification of an existing major source.

⁷ Among other things, USEPA observed that the stream-lining benefits can consist of "reduced cost and administrative complexity, and continued compliance flexibility...". *White Paper 2*, page 41.

⁸ See, *In the Matter of Tesoro Refining and Marketing*, Petition No. IX-2004-6, Order Denying in Part and Granting in Part Petition for Objection to Permit, at page 8 (March 15, 2005); see also, *White Paper 2* at page 39 ("reference must be detailed enough that the manner in which any referenced materials applies to a facility is clear and is not reasonably subject to misinterpretation").

⁹ The Order provides that permit authorities must ensure the following: "(1) referenced documents be specifically identified; (2) descriptive information such as the title or number of the document and the date of the document be included so that there is no ambiguity as to which version of the document is being referenced; and (3) citations, cross references, and incorporations by reference are detailed enough that the manner in which any referenced material applies to a facility is clear and is not reasonably subject to

misinterpretation." See, Petition Response at page 43, citing White Paper 2 at page 37.

¹⁰ See, White Paper 2 at page 39.

¹¹ Nothing in USEPA guidance, including the White Paper 2 or previous orders responding to public petitions, supports the notion that permit authorities incorporating a document by reference must also restate contents of a given plan in the body of the Title V permit. Such an interpretation contradicts USEPA recognition that permit authorities need not restate or recite an incorporated document so long as the document is sufficiently described. White Paper 2 at page 39; see also, In the matter of Consolidated Edison Co. of New York, Inc., 74th St. Station, Petition No. II-2001-02, Order Granting in Part and Denying in Part Petition for Objection to Permit at page 16 (February 19, 2003).

¹² This approach is consistent with USEPA guidance, which has previously embraced a similar approach to certain SSM plans. See, Letter and Enclosures, dated May 20, 1999, from John Seitz, Director of Office of Air Quality Planning and Standards, to Robert Hodanbosi and Charles Lagges, STAPPA/ALAPCO, pages 9-10 of Enclosure B.

¹³ The PM₁₀ Contingency Measure Plan is not being provided the same flexibility with respect to revising the plan's contents, as the underlying SIP rule treats the contents of the plan as federally enforceable. Any future revisions to this plan during the permit term are required to undergo procedures for permit modification. See, Condition 5.3.3(d).

¹⁴ Each incorporated plan addressed by this Section of the Statement of Basis is part of the source's permit file. As such, these plans are available to any person interested in viewing the contents of a given plan may do so at the public repository during the comment period or, alternatively, may request a copy of the same from the Illinois EPA under the Freedom of Information Act. See also 71 FR 20447.

¹⁵ The provisions of the Act for Periodic Monitoring in CAAPP permits reflect parallel requirements in the federal guidelines for State Operating Permit Programs, 40 CFR 70.6(a)(3)(i)(A), (a)(3)(i)(B), and (c)(1).

¹⁶ Section 39.5(7)(p)(i) of the Act also provides that a CAAPP permit shall contain "Compliance certification, testing, monitoring, reporting and record keeping requirements sufficient to assure compliance with the terms and conditions of the permit."

¹⁷ The classic example of regulatory standards for which Periodic Monitoring requirements must be established in a CAAPP permit are state emission standards that pre-date the 1990 Clean Air Act Amendments that were adopted without any associated compliance procedures. Periodic Monitoring must also be established in a CAAPP permit when standards and limits are accompanied by compliance procedures but those procedures are determined to be inadequate to assure compliance with the applicable standards or limits.

¹⁸ Another example of emission standards for which requirements must be established as part of Periodic Monitoring is certain NSPS standards that require initial performance testing but do not require periodic testing or

other measures to address compliance with the applicable limits on a continuing basis.

¹⁹ The need to establish Monitoring requirements as part of Periodic Monitoring when existing compliance procedures are determined to be inadequate, as well as when they are absent, was confirmed by the federal appeals court in *Sierra Club v. Environmental Protection Agency*, 536 F.3d 673, 383 U.S. App. D.C. 109.

²⁰ The need to establish Monitoring requirements as part of Periodic Monitoring is also confirmed in USEPA's Petition Response. USEPA explains that "...if there is periodic monitoring in the applicable requirements, but that monitoring is not sufficient to assure compliance with permit terms and conditions, permitting authorities must supplement monitoring to assure such compliance." Petition Response, page 6.

²¹ The test for the adequacy of "Periodic Monitoring" is a context-specific determination, particularly whether the provisions in a Title V permit reasonably address compliance with relevant substantive permit conditions. 40 CFR 70.6(c)(1); see also 40 CFR 70.6(a)(3)(i)(B); see also, *In the Matter of CITGO Refinery and Chemicals Company L.P.*, Petition VI-2007-01 (May 28, 2009); see also, *In the Matter of Waste Management of LA. L.L.C. Woodside Sanitary Landfill & Recycling Center, Walker, Livingston Parish, Louisiana*, Petition VI-2009-01 (May 27, 2010); see also, *In the Matter of Wisconsin Public Service Corporation's JP Pulliam Power Plant*, Petition V-2009-01 (June 28, 2010).

²² A number of these factors are specifically listed by USEPA in its Petition Response. USEPA also observes that the specific factors that it identifies in its Petition Response with respect to Periodic Monitoring provide "...the permitting authority with a starting point for its analysis of the adequacy of the monitoring; the permitting authority also may consider other site-specific factors." Petition Response, page 7.