

217/782-2113

TITLE V - CLEAN AIR ACT PERMIT PROGRAM (CAAPP) PERMIT
and
TITLE I PERMIT¹

PERMITTEE

Soyland Power Cooperative
Attn: Randy Fisher, Superintendent Illinois Generation
Post Office Box 10
Pearl, Illinois 62361

Application No.: 01050083

I.D. No.: 171851AAA

Applicant's Designation:

Date Received: May 29, 2001

Operation of: Electric Utility

Date Issued: November 26, 2002

Expiration Date²: November 26, 2007

Source Location: 1175 Campbell Road, Alsey, Scott, Illinois 62610

Responsible Official: Randy Fisher, Superintendent Illinois Generation

This permit is hereby granted to the above-designated Permittee to OPERATE a electric power plant, pursuant to the above referenced permit application. This permit is subject to the conditions contained herein.

If you have any questions concerning this permit, please contact John Cashman at 217/782-2113.

Donald E. Sutton, P.E.
Manager, Permit Section
Division of Air Pollution Control

DES:JRC:ELK:psj

cc: Illinois EPA, FOS, Region 2
USEPA

¹ This permit may contain terms and conditions which address the applicability, and compliance if determined applicable, of Title I of the CAA and regulations promulgated thereunder, including 40 CFR 52.21 - federal PSD and 35 IAC Part 203 - Major Stationary Sources Construction and Modification. Any such terms and conditions are identified within this permit.

² Except as provided in Condition 8.7 of this permit.

TABLE OF CONTENTS

	<u>PAGE</u>
1.0 SOURCE IDENTIFICATION	4
1.1 Source	
1.2 Owner/Parent Company	
1.3 Operator	
1.4 General Source Description	
2.0 LIST OF ABBREVIATIONS/ACRONYMS USED IN THIS PERMIT	5
3.0 INSIGNIFICANT ACTIVITIES	7
3.1 Identification of Insignificant Activities	
3.2 Compliance with Applicable Requirements	
3.3 Addition of Insignificant Activities	
4.0 SIGNIFICANT EMISSION UNITS AT THIS SOURCE	9
5.0 OVERALL SOURCE CONDITIONS	10
5.1 Source Description	
5.2 Applicable Regulations	
5.3 Non-Applicability of Regulations of Concern	
5.4 Source-Wide Operational and Production Limits and Work Practices	
5.5 Source-Wide Emission Limitations	
5.6 General Recordkeeping Requirements	
5.7 General Reporting Requirements	
5.8 General Operational Flexibility/Anticipated Operating Scenarios	
5.9 General Compliance Procedures	
6.0 EMISSIONS CONTROL PROGRAMS	16
6.1 NO _x Trading Program	
7.0 UNIT SPECIFIC CONDITIONS	24
7.1 Turbines (Not Subject to NSPS - 40 CFR Subpart GG)	
8.0 GENERAL PERMIT CONDITIONS	32
8.1 Permit Shield	
8.2 Applicability of Title IV Requirements	
8.3 Emissions Trading Programs	
8.4 Operational Flexibility/Anticipated Operating Scenarios	
8.5 Testing Procedures	
8.6 Reporting Requirements	
8.7 Obligation to Comply with Title I Requirements	

9.0 STANDARD PERMIT CONDITIONS

37

- 9.1 Effect of Permit
- 9.2 General Obligations of Permittee
- 9.3 Obligation to Allow Illinois EPA Surveillance
- 9.4 Obligation to Comply with Other Requirements
- 9.5 Liability
- 9.6 Recordkeeping
- 9.7 Annual Emissions Report
- 9.8 Requirements for Compliance Certification
- 9.9 Certification
- 9.10 Defense to Enforcement Actions
- 9.11 Permanent Shutdown
- 9.12 Reopening And Reissuing Permit For Cause
- 9.13 Severability Clause
- 9.14 Permit Expiration and Renewal

10.0 ATTACHMENTS

- 10.1 Attachment 1 - Example Certification by a Responsible Official 1-1
- 10.2 Attachment 2 - Guidance on Revising This Permit 2-1
- 10.3 Attachment 3 - Form 199-CAAPP, Application For Construction Permit (For CAAPP Sources Only) 3-1
- 10.4 Attachment 4 - Guidance on Renewing This Permit 4-1

1.0 SOURCE IDENTIFICATION

1.1 Source

Alsey Station
1175 Campbell Road
Alsey, Illinois 62610
217/829-4291

I.D. No.: 171851AAA

Standard Industrial Classification: 4911, Electric Utility

1.2 Owner/Parent Company

Soyland Power Cooperative
212 Locust Street, P.O. Box 1266
Harrisburg, Pennsylvania 17108-1266

1.3 Operator

Soyland Power Cooperative, Inc.
Post Office Box 10
Pearl, Illinois 62650

Randy Fisher, Superintendent Illinois Generation
217/829-4212

1.4 General Source Description

Alsey Station is located at 1175 Campbell Road in Alsey. The source operates gas-fired turbines for the purpose of generating electricity.

2.0 LIST OF ABBREVIATIONS/ACRONYMS USED IN THIS PERMIT

ACMA	Alternative Compliance Market Account
Act	Illinois Environmental Protection Act [415 ILCS 5/1 et seq.]
AP-42	Compilation of Air Pollutant Emission Factors, Volume 1, Stationary Point and Other Sources (and Supplements A through F), USEPA, Office of Air Quality Planning and Standards, Research Triangle Park, NC 27711
ATU	Allotment Trading Unit
BAT	Best Available Technology
Btu	British thermal unit
CAA	Clean Air Act [42 U.S.C. Section 7401 et seq.]
CAAPP	Clean Air Act Permit Program
CAM	Compliance Assurance Monitoring
CFR	Code of Federal Regulations
EGU	electrical generating unit(s)
ERMS	Emissions Reduction Market System (35 IAC Part 205)
HAP	Hazardous Air Pollutant
hr	hour
IAC	Illinois Administrative Code
I.D. No.	Identification Number of Source, assigned by Illinois EPA
ILCS	Illinois Compiled Statutes
Illinois EPA	Illinois Environmental Protection Agency
kW	kilowatts
LAER	Lowest Achievable Emission Rate
lb	pound
MACT	Maximum Achievable Control Technology
mmBtu	Million British thermal units
Mg	megagram or metric ton
MW	megawatts
NESHAP	National Emission Standards for Hazardous Air Pollutants
NO _x	Nitrogen Oxides
NSPS	New Source Performance Standards
NSSA	new source set-aside
ORIS	Office of Regulatory Information System
PM	Particulate Matter
PM ₁₀	Particulate matter with an aerodynamic diameter less than or equal to a nominal 10 microns as measured by applicable test or monitoring methods
ppm	parts per million
PSD	Prevention of Significant Deterioration (40 CFR 52.21)
RMP	Risk Management Plan
SO ₂	Sulfur Dioxide
T	ton (2000 pounds)
T1	Title I - identifies Title I conditions that have been carried over from an existing permit
T1N	Title I New - identifies Title I conditions that are being established in this permit

T1R	Title I Revised - identifies Title I conditions that have been carried over from an existing permit and subsequently revised in this permit
USEPA	United States Environmental Protection Agency
VOM	Volatile Organic Material

3.0 INSIGNIFICANT ACTIVITIES

3.1 Identification of Insignificant Activities

The following activities at the source constitute insignificant activities as specified in 35 IAC 201.210:

- 3.1.1 Activities determined by the Illinois EPA to be insignificant activities, pursuant to 35 IAC 201.210(a)(1) and 201.211, as follows:

None

- 3.1.2 Activities that are insignificant activities based upon maximum emissions, pursuant to 35 IAC 201.210(a)(2) or (a)(3), as follows:

None

- 3.1.3 Activities that are insignificant activities based upon their type or character, pursuant to 35 IAC 201.210(a)(4) through (18), as follows:

Storage tanks of organic liquids with a capacity of less than 10,000 gallons and an annual throughput of less than 100,000 gallons per year, provided the storage tank is not used for the storage of gasoline or any material listed as a HAP pursuant to Section 112(b) of the CAA [35 IAC 201.210(a)(10)].

Storage tanks of any size containing virgin or re-refined distillate oil, hydrocarbon condensate from natural gas pipeline or storage systems, lubricating oil, or residual fuel oils [35 IAC 201.210(a)(11)].

Gas turbines and stationary reciprocating internal combustion engines of between 112 kW and 1,118 kW (150 and 1,500 horsepower) power output that are emergency or standby units [35 IAC 201.210(a)(16)].

- 3.1.4 Activities that are considered insignificant activities pursuant to 35 IAC 201.210(b).

3.2 Compliance with Applicable Requirements

Insignificant activities are subject to applicable requirements notwithstanding status as insignificant activities. In particular, in addition to regulations of general applicability, such as 35 IAC 212.301 and 212.123 (Condition 5.2.2), the Permittee shall comply with the following requirements, as applicable:

- 3.2.1 For each cold cleaning degreaser, the Permittee shall comply with the applicable equipment and operating requirements of 35 IAC 215.182, 218.182, or 219.182.
- 3.2.2 For each particulate matter process emission unit, the Permittee shall comply with the applicable particulate matter emission limit of 35 IAC 212.321 or 212.322. For example, the particulate matter emissions from a process emission unit shall not exceed 0.55 pounds per hour if the emission unit's process weight rate is 100 pounds per hour or less, pursuant to 35 IAC 266.110.
- 3.2.3 For each organic material emission unit that uses organic material, e.g., a mixer or printing line, the Permittee shall comply with the applicable VOM emission limit of 35 IAC 215.301, 218.301, or 219.301, which requires that organic material emissions not exceed 8.0 pounds per hour or do not qualify as photochemically reactive material as defined in 35 IAC 211.4690.

3.3 Addition of Insignificant Activities

- 3.3.1 The Permittee is not required to notify the Illinois EPA of additional insignificant activities present at the source of a type that is identified in Condition 3.1, until the renewal application for this permit is submitted, pursuant to 35 IAC 201.212(a).
- 3.3.2 The Permittee must notify the Illinois EPA of any proposed addition of a new insignificant activity of a type addressed by 35 IAC 201.210(a) and 201.211 other than those identified in Condition 3.1, pursuant to Section 39.5(12)(b) of the Act.
- 3.3.3 The Permittee is not required to notify the Illinois EPA of additional insignificant activities present at the source of a type identified in 35 IAC 201.210(b).

4.0 SIGNIFICANT EMISSION UNITS AT THIS SOURCE

Emission Unit	Description	Date Constructed	Emission Control Equipment
ACT 1	30 MW Turbine Fired by Natural Gas or Distillate Fuel Oil (450 mmBtu/Hr)	1973	None
ACT 2	30 MW Turbine Fired by Natural Gas or Distillate Fuel Oil (450 mmBtu/Hr)	1973	None
ACT 3	18 MW Turbine Fired by Natural Gas or Distillate Fuel Oil (229 mmBtu/Hr)	June 1977	Water Injection when Natural Gas Fired
ACT 4	18 MW Turbine Fired by Natural Gas or Distillate Fuel Oil (229 mmBtu/Hr)	June 1977	Water Injection when Natural Gas Fired
ACT 5	25 MW Turbine Fired by Natural Gas or Distillate Fuel Oil (306 mmBtu/Hr)	1971	Dry Low NO _x Burner

5.0 OVERALL SOURCE CONDITIONS

5.1 Source Description

5.1.1 This permit is issued based on the source requiring a CAAPP permit as a major source of NO_x emissions.

5.1.2 This permit is issued based on the source not being a major source of HAPs.

5.2 Applicable Regulations

5.2.1 Specific emission units at this source are subject to particular regulations as set forth in Section 7 (Unit-Specific Conditions) of this permit.

5.2.2 In addition, emission units at this source are subject to the following regulations of general applicability:

- a. No person shall cause or allow the emission of fugitive particulate matter from any process, including any material handling or storage activity, that is visible by an observer looking generally overhead at a point beyond the property line of the source unless the wind speed is greater than 40.2 kilometers per hour (25 miles per hour), pursuant to 35 IAC 212.301 and 212.314.

Compliance with this requirement is considered to be assured by the inherent nature of operations at this source, as demonstrated by historical operation.

- b. No person shall cause or allow the emission of smoke or other particulate matter, with an opacity greater than 30 percent, into the atmosphere from any emission unit other than those emission units subject to the requirements of 35 IAC 212.122, pursuant to 35 IAC 212.123(a), except as allowed by 35 IAC 212.123(b) and 212.124.

5.2.3 Ozone Depleting Substances

The Permittee shall comply with the standards for recycling and emissions reduction of ozone depleting substances pursuant to 40 CFR Part 82, Subpart F, except as provided for motor vehicle air conditioners in Subpart B of 40 CFR Part 82:

- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to 40 CFR 82.156.
- b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.

- c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

5.2.4 Risk Management Plan

Should this stationary source, as defined in 40 CFR Section 68.3, become subject to the Accidental Release Prevention regulations in 40 CFR Part 68, then the owner or operator shall submit [40 CFR 68.215(a)(2)(i) and (ii)]:

- a. A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR 68.10(a); or
- b. A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan (RMP), as part of the annual compliance certification required by 40 CFR Part 70 or 71.

- 5.2.5 a. Should this stationary source become subject to a regulation under 40 CFR Parts 60, 61, or 63, or 35 IAC after the date issued of this permit, then the owner or operator shall, in accordance with the applicable regulation(s), comply with the applicable requirements by the date(s) specified and shall certify compliance with the applicable requirements of such regulation(s) as part of the annual compliance certification, as required by 40 CFR Part 70 or 71.
- b. No later than upon the submittal for renewal of this permit, the owner or operator shall submit, as part of an application, the necessary information to address either the non-applicability of, or demonstrate compliance with all applicable requirements of any potentially applicable regulation which was promulgated after the date issued of this permit.
- c. This stationary source will be subject to 40 CFR Part 63 when such rule becomes final and effective. The Permittee shall comply with the applicable requirements of such regulation by the date(s) specified in such regulation and shall certify compliance with the applicable requirements of such regulation as part of the annual compliance certification required by Condition 9.8 beginning in the year that compliance is required under a final and effective rule.

5.2.6 Episode Action Plan

- a. If the source is required to have an episode action plan pursuant to 35 IAC 244.142, the Permittee shall maintain at the source and have on file with the Illinois EPA a written episode action plan (plan) for reducing the levels of emissions during yellow alerts, red alerts, and emergencies, consistent with safe operating procedures. The plan shall contain the information specified in 35 IAC 244.144.
- b. The Permittee shall immediately implement the appropriate steps described in this plan should an air pollution alert or emergency be declared.
- c. If a change occurs at the source which requires a revision of the plan (e.g., operational change, change in the source contact person), a copy of the revised plan shall be submitted to the Illinois EPA for review within 30 days of the change. Such plans shall be further revised if disapproved by the Illinois EPA.
- d. For sources required to have a plan pursuant to 35 IAC 244.142, a copy of the original plan and any subsequent revisions shall be sent to:
 - i. Illinois EPA, Compliance Section; and
 - ii. For sources located in Cook County and outside of the city of Chicago: Cook County Department of Environmental Control; or
 - iii. For sources located within the city of Chicago: Chicago Department of Environmental Control.

5.2.7 CAM Plan

This stationary source has a pollutant-specific emissions unit that is subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources. As a result of this application either not having been submitted or deemed complete by April 20, 1998, the source is required to comply with the requirements of 40 CFR Part 64 for large pollutant-specific emissions units in the initial application and CAAPP permit. The source must submit a CAM plan for all other affected pollutant-specific emissions units upon application for renewal of the initial CAAPP permit, or upon a significant modification to the CAAPP permit for the construction or modification of a large pollutant-specific emissions unit which has the potential post-control device emissions of the applicable regulated air pollutant that equals or exceeds major source threshold levels.

5.3 Non-Applicability of Regulations of Concern

None

5.4 Source-Wide Operational and Production Limits and Work Practices

In addition to the source-wide requirements in the Standard Permit Conditions in Section 9, the Permittee shall fulfill the following source-wide operational and production limitations and/or work practice requirements:

None

5.5 Source-Wide Emission Limitations

5.5.1 Permitted Emissions for Fees

The annual emissions from the source, not considering insignificant activities as addressed by Section 3.0 of this permit, shall not exceed the following limitations. The overall source emissions shall be determined by adding emissions from all emission units. Compliance with these limits shall be determined on a calendar year basis. These limitations (Condition 5.5.1) are set for the purpose of establishing fees and are not federally enforceable.

Permitted Emissions of Regulated Pollutants

Pollutant	Tons/Year
Volatile Organic Material (VOM)	13.0
Sulfur Dioxide (SO ₂)	18.0
Particulate Matter (PM)	11.0
Nitrogen Oxides (NO _x)	249.0
HAP, not included in VOM or PM	---
Total	282.0

5.5.2 Emissions of Hazardous Air Pollutants

This permit is issued based on the emissions of HAPs as listed in Section 112(b) of the CAA not being equal to or exceeding 10 tons per year of a single HAP or 25 tons per year of any combination of such HAPs, so that this source is considered a minor source for HAPs.

5.5.3 Other Source-Wide Emission Limitations

Other source-wide emission limitations are not set for this source pursuant to either the federal rules for Prevention of Significant Deterioration (PSD), 40 CFR 52.21, Illinois EPA rules for Major Stationary Sources Construction and Modification, 35 IAC Part 203, or Section 502(b)(10) of the CAA. However, there may be unit specific emission limitations set forth in Section 7 of this permit pursuant to these rules.

5.6 General Recordkeeping Requirements

5.6.1 Emission Records

The Permittee shall maintain records of the following items for the source to demonstrate compliance with Condition 5.5.1, pursuant to Section 39.5(7)(b) of the Act:

Total annual emissions on a calendar year basis for the emission units covered by Section 7 (Unit Specific Conditions) of this permit.

5.6.2 Records for Operating Scenarios

N/A

5.6.3 Retention and Availability of Records

- a. All records and logs required by this permit shall be retained for at least five years from the date of entry (unless a longer retention period is specified by the particular recordkeeping provision herein), shall be kept at a location at the source that is readily accessible to the Illinois EPA or USEPA, and shall be made available for inspection and copying by the Illinois EPA or USEPA upon request.
- b. The Permittee shall retrieve and print, on paper during normal source office hours, any records retained in an electronic format (e.g., computer) in response to an Illinois EPA or USEPA request for records during the course of a source inspection.

5.7 General Reporting Requirements

5.7.1 General Source-Wide Reporting Requirements

The Permittee shall promptly notify the Illinois EPA, Compliance Section of deviations of the source with the permit requirements as follows, pursuant to Section 39.5(7)(f)(ii) of the Act. Reports shall describe the probable cause of such deviations, and any corrective actions or preventive measures taken.

5.7.2 Annual Emissions Report

The annual emissions report required pursuant to Condition 9.7 shall contain emissions information for the previous calendar year.

5.8 General Operational Flexibility/Anticipated Operating Scenarios

N/A

5.9 General Compliance Procedures

5.9.1 General Procedures for Calculating Emissions

Compliance with the source-wide emission limits specified in Condition 5.5 shall be based on the recordkeeping and reporting requirements of Conditions 5.6 and 5.7, and Compliance Procedures in Section 7 (Unit Specific Conditions) of this permit.

6.0 EMISSIONS CONTROL PROGRAMS

6.1 NO_x Trading Program

6.1.1 Description of NO_x Trading Program

The NO_x Trading Program is a regional "cap and trade" market system for large sources of NO_x emissions in the eastern United States, including Illinois. It is designed to reduce and maintain NO_x emissions from the emission units covered by the program within a budget to help contribute to attainment and maintenance of the ozone ambient air quality standard in the multi-state region covered by the program, as required by Section 126 of the CAA. The NO_x Trading Program applies in addition to other applicable requirements for NO_x emissions and in no way relaxes these other requirements.

Electrical generating units (EGU) that are subject to the NO_x Trading Program are referred to as "budget EGU." Sources that have one or more EGU or other units subject to the NO_x Trading Program are referred to as budget sources.

The NO_x Trading Program controls NO_x emissions from budget EGU and other budget units during a seasonal control period from May 1 through September 30 of each year, when weather conditions are conducive to formation of ozone in the ambient air. (In 2004, the first year that the NO_x Trading Program is in effect, the control period will be May 31 through September 30.) By November 30 of each year, the allowance transfer deadline, each budget source must hold "NO_x allowances" for the actual NO_x emissions of its budget units during the preceding control period. The USEPA will then retire NO_x allowances in the source's accounts in amounts equivalent to its seasonal emissions. If a source does not have sufficient allowances in its accounts, USEPA would subtract allowances from the source's future allocation for the next control period and impose other penalties as appropriate. Stringent monitoring procedures developed by USEPA apply to budget units to assure that actual emissions of NO_x emissions are accurately determined.

The number of NO_x allowances available for budget sources is set by the overall budget for NO_x emissions established by USEPA. This budget requires a substantial reduction in NO_x emissions from historical levels as necessary to meet air quality goals. In Illinois, existing budget sources initially receive their allocation or share of the NO_x allowances budgeted for EGU in an amount determined by rule [35 IAC Part 217, Appendix F]. Between 2007 and 2011, the allocation mechanism for existing EGU gradually shifts to one based on the actual operation of EGU in preceding control periods. New budget EGU, for which

limited operating data may be available, may obtain NO_x allowances from the new source set-aside (NSSA), a portion of the overall budget reserved for new EGU.

In addition to directly receiving or purchasing NO_x allowances as described above, budget sources may transfer NO_x allowances from one of their units to another. They may also purchase allowances in the marketplace from other sources that are willing to sell some of the allowances that they have received. Each budget source must designate an account representative to handle all its allowance transactions. The USEPA, in a central national system, will maintain allowance accounts and record transfer of allowances among accounts.

The ability of sources to transfer allowances will serve to minimize the costs of reducing NO_x emissions from budget units to comply with the overall NO_x budget. In particular, the NO_x emissions of budget units that may be most economically controlled will be targeted by sources for further control of emissions. This will result in a surplus of NO_x allowances from those units that can be transferred to other units at which it is more difficult to control NO_x emissions. Experience with reduction of sulfur dioxide emissions under the federal Acid Rain program has shown that this type of trading program not only achieves regional emission reductions in a more cost-effective manner but also results in greater overall reductions than application of traditional emission standards to individual emission units.

The USEPA developed the plan for the NO_x Trading Program with assistance from affected states. Illinois' rules for the NO_x Trading Program for EGU are located at 35 IAC Part 217, Subpart W, and have been approved by the USEPA. These rules provide for interstate trading of NO_x allowances, as mandated by Section 9.9 of the Act. Accordingly, these rules refer to and rely upon federal rules at 40 CFR Part 96, which have been developed by USEPA for certain aspects of the NO_x Trading Program, and which an individual state must follow to allow for interstate trading of allowances.

Note: This narrative description of the NO_x Trading Program is for informational purposes only and is not enforceable.

6.1.2 Applicability

- a. The following emission units at this source are budget EGU for purposes of the NO_x Trading Program. Accordingly, this source is a budget source and the Permittee is the owner or operator of a budget source and budget EGU. In this section of this permit, these emission units are addressed as budget EGU.

Three Turbines ACT 1, ACT 2, ACT 5

- b. This permit does not provide "low-emitter status" for the above emission units pursuant to 35 IAC 217.754(c).

6.1.3 General Provisions of the NO_x Trading Program

- a. This source and the budget EGU at this source shall comply with all applicable requirements of Illinois' NO_x Trading Program, i.e., 35 IAC Part 217, Subpart W, and 40 CFR Part 96 (excluding 40 CFR 96.4(b) and 96.55(c), and excluding 40 CFR 96, Subparts C, E and I), pursuant to 35 IAC 217.756(a) and 217.756(f)(2).
- b. Any provision of the NO_x Trading Program that applies to a budget source (including any provision applicable to the account representative of a budget source) shall also apply to the owner and operator of such budget sources and to the owner and operator of each budget EGU at the source, pursuant to 35 IAC 217.756(f)(3).
- c. Any provision of the NO_x Trading Program that applies to a budget EGU (including any provision applicable to the account representative of a budget EGU) shall also apply to the owner and operator of such budget EGU. Except with regard to requirements applicable to budget EGUs with a common stack under 40 CFR 96, Subpart H, the owner and operator and the account representative of one budget EGU shall not be liable for any violation by any other budget EGU of which they are not an owner or operator or the account representative, pursuant to 35 IAC 217.756(f)(4).

6.1.4 Requirements for NO_x Allowances

- a. Beginning in 2004, by November 30 of each year, the allowance transfer deadline, the account representative of each budget EGU at this source shall hold allowances available for compliance deduction under 40 CFR 96.54 in the budget EGU's compliance account or the source's overdraft account in an amount that shall not be less than the budget EGU's total tons of NO_x emissions for the preceding control period, rounded to the nearest whole ton, as determined in accordance with 40 CFR 96, Subpart H, plus any number necessary to account for actual utilization (e.g., for testing, start-up, malfunction, and shut down) under 40 CFR 96.42(e) for the control period, pursuant to 35 IAC 217.756(d)(1). For purposes of this requirement, an allowance may not be utilized for a control period in a year prior to the year for which the allowance is allocated, pursuant to 35 IAC 217.756(d)(5).

- b. The account representative of a budget EGU that has excess emissions in any control period, i.e., NO_x emissions in excess of the number of NO_x allowances held as provided above, shall surrender allowances as required for deduction under 40 CFR 96.54(d)(1), pursuant to 35 IAC 201.756(f)(5). In addition, the owner or operator of a budget EGU that has excess emissions shall pay any fine, penalty, or assessment, or comply with any other remedy imposed under 40 CFR 96.54(d)(3) and the Act, pursuant to 35 IAC 217.756(f)(6). Each ton of NO_x emitted in excess of the number of NO_x allowances held as provided above for each budget EGU for each control period shall constitute a separate violation of 35 IAC Part 217 and the Act, pursuant to 35 IAC 217.756(d)(2).
- c. An allowance allocated by the Illinois EPA or USEPA under the NO_x Trading Program is a limited authorization to emit one ton of NO_x in accordance with the NO_x Trading Program. As explained by 35 IAC 217.756(d)(6), no provisions of the NO_x Trading Program, the budget permit application, the budget permit, or a retired unit exemption under 40 CFR 96.5 and no provision of law shall be construed to limit the authority of the United States or the State of Illinois to terminate or limit this authorization. As further explained by 35 IAC 217.756(d)(7), an allowance allocated by the Illinois EPA or USEPA under the NO_x Trading Program does not constitute a property right. As provided by 35 IAC 217.756(d)(4), allowances shall be held in, deducted from, or transferred among allowances accounts in accordance with 35 IAC Part 217, Subpart W, and 40 CFR 96, Subparts F and G.

6.1.5 Monitoring Requirements for Budget EGU

- a. The Permittee shall comply with the monitoring requirements of 40 CFR Part 96, Subpart H, for each budget EGU and the compliance of each budget EGU with the emission limitation under Condition 6.1.4(a) shall be determined by the emission measurements recorded and reported in accordance with 40 CFR 96, Subpart H, pursuant to 35 IAC 217.756(c)(1), (c)(2) and (d)(3).
- b. The account representative for the source and each budget EGU at the source shall comply with those sections of the monitoring requirements of 40 CFR 96, Subpart H, applicable to an account representative, pursuant to 35 IAC 217.756(c)(1) and (d)(3).

Note: Pursuant to 40 CFR 96.70(b), new budget EGU that commence operation before January 1, 2003 are to begin

complying with applicable monitoring requirements of 40 CFR Part 96 at least one year in advance of the start of the first control period governed by the NO_x Trading Program.

6.1.6 Recordkeeping Requirements for Budget EGU

Unless otherwise provided below, the Permittee shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This 5-year period may be extended for cause at any time prior to the end of the 5 years, in writing by the Illinois EPA or the USEPA.

- a. The account certificate of representation of the account representative for the source and each budget EGU at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with 40 CFR 96.13, as provided by 35 IAC 217.756(e)(1)(A). These certificates and documents must be retained on site at the source for at least 5-years after they are superseded because of the submission of a new account certificate of representation changing the account representative.
- b. All emissions monitoring information, in accordance with 40 CFR 96, Subpart H, (provided that to the extent that 40 CFR 96, Subpart H, provides for a 3-year period for retaining records, the 3-year period shall apply), pursuant to 35 IAC 217.756(e)(1)(B).
- c. Copies of all reports, compliance certifications, and other submissions and all records made or required under the NO_x Trading Program or documents necessary to demonstrate compliance with requirements of the NO_x Trading Program, pursuant to 35 IAC 217.756(e)(1)(C).
- d. Copies of all documents used to complete a budget permit application and any other submission under the NO_x Trading Program, pursuant to 35 IAC 217.756(e)(1)(D).

6.1.7 Reporting Requirements for Budget EGU

- a. The account representative for this source and each budget EGU at this source shall submit to the Illinois EPA and USEPA the reports and compliance certifications required under the NO_x Trading Program, including those under 40 CFR 96, Subparts D and H, and 35 IAC 217.774, pursuant to 35 IAC 217.756(e)(2).

- b. Notwithstanding the provisions in Conditions 9.8 and 9.9 of this CAAPP permit, these submittals need only be signed by the designated representative, who may serve in place of the responsible official for this purpose, as provided by Section 39.5(1) of the Act, and submittals to the Illinois EPA need only be made to the Illinois EPA, Air Compliance Section.

6.1.8 Allocation of NO_x Allowances to Budget EGU

- a. For 2004, 2005 and 2006, the budget EGU identified in Condition 6.1.2(a) will not be entitled to direct allocations of NO_x allowances because these EGU will be considered "new" budget EGU, as defined in 35 IAC 217.768(a)(1).
- b.
 - i. Beginning in 2007, these budget EGU will cease to be "new" budget EGU and the source will be entitled to an allocation of NO_x allowances for these budget EGU as provided in 35 IAC 217.764. For example, for 2007, the allocation of NO_x allowances will be governed by 35 IAC 217.764(b)(2) and (b)(4).
 - ii. In accordance with 35 IAC 217.762, the theoretical number of NO_x allowances for these budget EGU, calculated as the product of the applicable NO_x emissions rate and heat input as follows, shall be the basis for determining the allocation of NO_x allowances to these EGU. For this purpose, this calculation shall be performed separately for heat input from natural gas and oil, if any, into each budget unit:
 - A. As provided by 35 IAC 217.762(a)(2), the applicable NO_x emission rates for these EGU are 0.15 lb/mmBtu for natural gas and 0.15 lb/mmBtu for oil. For natural gas, this is the permitted emission rate for these EGU as contained in Construction Permit 98120050, pursuant to which the EGU were constructed. The permitted emission rate for natural gas is the applicable rate because it is between 0.15 lb/mmBtu and 0.055 lb/mmBtu, as provided by 35 IAC 217.762(a)(2).
 - B. The applicable heat inputs (mmBtu/control period) for natural gas and oil shall be the average of the two highest heat inputs from the control periods four to six years prior to the year for which the allocation is being made, as provided by 35 IAC 217.762(b)(1).

6.1.9 Eligibility for NO_x Allowances from the New Source Set-Aside (NSSA)

- a. In 2004, 2005 and 2006, the budget EGU identified in Condition 6.1.2(a) will qualify as "new" budget EGU that commenced commercial operation prior to January 1, 2004. As such, the Permittee may be entitled to obtain NO_x allowances from the NSSA for these EGU without charge, as provided by 35 IAC 217.768.
- b. For the purpose of any such request for NO_x allowances, the NO_x emission rate shall be the permitted emission rate of these EGU as specified in Condition 6.1.8(b)(ii) and the projected heat input shall not exceed the average of the EGU's two highest seasonal heat inputs for the control periods one to three years prior to the allocation year, pursuant to 35 IAC 217.768(e).

6.1.10 Eligibility for Early Reduction Credits (ERC)

The Permittee is not eligible to request NO_x allowances for the budget EGU identified in Condition 6.1.2(a) for any early reductions in NO_x emissions prior to the 2004 control period, as provided by 35 IAC 217.770, because these EGU are not equipped with continuous emission monitoring systems for NO_x.

6.1.11 Budget Permit Required by the NO_x Trading Program

- a. For this source, this segment of the CAAPP Permit, i.e., Section 6.1, is the Budget Permit required by the NO_x Trading Program and is intended to contain federally enforceable conditions addressing all applicable NO_x Trading Program requirements. This Budget Permit shall be treated as a complete and segregable portion of the source's entire CAAPP permit, as provided by 35 IAC 217.758(a)(2).
- b. The Permittee and any other owner or operator of this source and each budget EGU at the source shall operate the budget EGU in compliance with this Budget Permit, pursuant to 35 IAC 217.756(b)(2).
- c. No provision of this Budget Permit or the associated application shall be construed as exempting or excluding the Permittee, or other owner or operator and, to the extent applicable, the account representative of a budget source or budget EGU from compliance with any other regulation or requirement promulgated under the CAA, the Act, the approved State Implementation Plan, or other federally enforceable permit, pursuant to 35 IAC 217.756(g).

- d. Upon recordation by USEPA under 40 CFR 96, Subpart F or G, or 35 IAC 217.782, every allocation, transfer, or deduction of an allowance to or from the budget units' compliance accounts or to or from the overdraft account for the budget source is deemed to amend automatically, and become part of, this budget permit, pursuant to 35 IAC 217.756(d)(8). This automatic amendment of this budget permit shall be deemed an operation of law and will not require any further review.
- e. No revision of this Budget Permit shall excuse any violation of the requirements of the NO_x Trading Program that occurs prior to the date that the revisions to this permit takes effect, pursuant to 35 IAC 217.756(f)(1).
- f. The Permittee, or other owner or operator of the source, shall reapply for a Budget Permit for the source as required by 35 IAC Part 217, Subpart W and Section 39.5 of the Act. For purposes of the NO_x Trading Program, the application shall contain the information specified by 35 IAC 217.758(b)(2).

7.0 UNIT SPECIFIC CONDITIONS

7.1 Turbines (Not Subject to NSPS - 40 CFR 60 Subpart GG)

7.1.1 Description

The turbines are process emission units used to generate electricity. The turbines are powered by natural gas or distillate fuel oil.

7.1.2 List of Emission Units and Air Pollution Control Equipment

Emission Unit	Description	Emission Control Equipment
ACT 1	30 MW Turbine Fired by Natural Gas or Distillate Fuel Oil (450 mmBtu/Hr)	None
ACT 2	30 MW Turbine Fired by Natural Gas or Distillate Fuel Oil (450 mmBtu/Hr)	None
ACT 3	18 MW Turbine Fired by Natural Gas or Distillate Fuel Oil (229 mmBtu/Hr)	Water Injection when Natural Gas Fired
ACT 4	18 MW Turbine Fired by Natural Gas or Distillate Fuel Oil (229 mmBtu/Hr)	Water Injection when Natural Gas Fired
ACT 5	25 MW Turbine Fired by Natural Gas or Distillate Fuel Oil (306 mmBtu/Hr)	Dry Low NO _x Burner

7.1.3 Applicability Provisions and Applicable Regulations

- a. The "affected turbines" for the purpose of these unit-specific conditions, are the turbines described in Conditions 7.1.1 and 7.1.2.
- b. Each affected turbine is subject to the emission limits identified in Condition 5.2.2.
- c. No person shall cause or allow the emission of sulfur dioxide into the atmosphere from any process emission source to excess 2000 ppm [35 IAC 214.301].
- d. i. A. No owner or operator shall cause or allow the emissions of NO_x into the atmosphere from affected turbines ACT 1, ACT 2, and ACT 5 to exceed 0.25 lbs/mmBtu of actual heat input during each ozone control period from May 1 through September 30, based on a ozone control period average, for that unit [35 IAC 217.706(a)].
 - B. Notwithstanding the above emission limitation of 35 IAC 217.706(a), the affected turbines ACT 1, ACT 2, and ACT 5 subject to a more stringent NO_x emission

limitation pursuant to any State or federal statute, including the Act, the Clean Air Act, or any regulations promulgated thereunder, shall comply with both the requirements of 35 IAC 217 Subpart V and that more stringent emission limitation [35 IAC 217.706(b)].

- ii. A. Notwithstanding 35 IAC 217.706(a) above, the Permittee may elect to demonstrate compliance with 35 IAC 217 Subpart V by averaging for the ozone control period the NO_x emission rates [35 IAC 217.708(a)].
- B. The average NO_x emission rate for all EGUs being averaged pursuant to 35 IAC 217 Subpart V must not exceed 0.25 lbs/mmBtu and shall be determined as follows [35 IAC 217.708(b)]:

$$ER_{avg} = \frac{\sum (HI_i \times ER_i)}{\sum HI_i}$$

Where:

\sum = Summation of i=1 to n

ER_{avg} = Average emission rate in lb/mmBtu of all EGUs in averaging demonstration

HI_i = Heat input for the ozone control period of EGU i, in mmBtu, as specified in the NO_x averaging demonstration

ER_i = Actual NO_x emission rate of EGU i, in lbs/mmBtu, as specified in the NO_x averaging demonstration

n = Number of EGUs that are averaging

- C. An EGU may be included in only one NO_x averaging demonstration during an ozone control period [35 IAC 217.708(d)].
- D. Compliance by averaging for each ozone control period must be demonstrated by November 30 following each ozone control period [35 IAC 217.708(e)].
- E. If averaging is used to demonstrate compliance with 35 IAC 217 Subpart V, the effect of a failure to demonstrate such compliance shall be that the compliance status of each EGU shall be determined

pursuant to 35 IAC 217.706(a) as if the NO_x emission rates of such EGUs were not averaged [35 IAC 217.708(f)].

- F. The owner or operator of any EGU that elects to participate in an averaging demonstration to demonstrate compliance with this 35 IAC 217 Subpart V cannot average with any other EGU for which the owner or operator of such EGU does not maintain the required records, data, and reports, or does not submit copies of such records, data, or reports to the Illinois EPA upon request [35 IAC 217.708(g)].

7.1.4 Non-Applicability of Regulations of Concern

- a. This permit is issued based on the affected turbines not being subject to the New Source Performance Standards (NSPS) for Stationary Gas Turbines, 40 CFR Part 60, Subpart GG, because the affected turbines commenced construction, modification, or reconstruction prior to October 3, 1977.
- b. This permit is issued based on the affected turbines not being subject to the requirements of 35 IAC 212.321 or 212.322, because due to the unique nature of these units, a process weight rate can not be set so that such rules can not reasonably be applied.
- c. The affected turbines (ACT 3 and ACT 4) are not subject to the requirements of the NO_x Compliance Programs of 35 IAC Part 217 because each affected turbine has nameplate capacities less than 25 MWe.
- d. This permit is issued based on the affected turbines not being subject to the requirements of the Acid Rain Program because the turbines are simple cycle turbines and originally commenced operation before November 15, 1990 [40 CFR 72.6 (b)(1)].

7.1.5 Operational and Production Limits and Work Practices

- a.
 - i. Natural gas or distillate fuel oil shall be the only fuels fired in the affected turbines.
 - ii. Distillate fuel oil with a sulfur content greater than 0.3 weight percent shall not be fired in the affected turbines.
- b.
 - i. Affected turbine ACT 5 shall be equipped, operated, and maintained with a dry low NO_x burner to control NO_x emissions.

- ii. Affected turbines ACT 3 and ACT 4 shall be equipped, operated, and maintained with water injection to control NO_x emissions when firing natural gas.
 - iii. The affected turbines shall be equipped, operated, and maintained with a system to measure and record their fuel consumption.
- c. Combined operation of the affected turbines shall not exceed a fuel heat input of 1,131,818 mmBtu per year. Compliance with the annual limitation shall be determined from a running total of 12 months of data. This limit reflects the affected turbines operating for about 772 hours/year with distillate oil being used 10 percent of the time. The above limitations were established in Permit 98120050 [T1].

7.1.6 Emission Limitations

In addition to Condition 5.2.2 and the source wide emission limitations in Condition 5.5, the affected turbines are subject to the following:

- a. Hourly emissions from affected turbines ACT 1 and ACT 2 shall not exceed the following limits:

<u>Pollutant</u>	<u>Natural Gas Fired (Lb/Hour)</u>	<u>Distillate Fuel Oil Fired (Lb/Hour)</u>
NO _x	143.0	234.0
CO	3.0	4.0
SO ₂	0.5	113.6
VOM	9.0	9.0
PM	7.2	14.3

- b. Hourly emissions from affected turbines ACT 3 and ACT 4 shall not exceed the following limits, except when ice fog is deemed a traffic hazard by the Permittee:

<u>Pollutant</u>	<u>Natural Gas Fired (Lb/Hour)</u>	<u>Distillate Fuel Oil Fired (Lb/Hour)</u>
NO _x	74.0	182.0
CO	3.0	2.0
SO ₂	0.5	100.0
VOM	4.8	3.4
PM	4.4	7.6

- c. Hourly emissions from affected turbine ACT 5 shall not exceed the following limits:

<u>Pollutant</u>	<u>Natural Gas Fired (Lb/Hour)</u>	<u>Distillate Fuel Oil Fired (Lb/Hour)</u>
NO _x	115.0	172.0
CO	33.7	14.5
SO ₂	0.2	105.2
VOM	7.4	5.1
PM	5.9	11.4

- d. Annual emissions from the affected turbines shall not exceed the following limits:

<u>Pollutant</u>	<u>(Ton/Year)</u>
NO _x	249.0
CO	58.0
SO ₂	18.0
VOM	13.0
PM	11.0

- e. Compliance with annual limits shall be determined on a monthly basis from the sum of the data for the current month plus the preceding 11 months (running 12 month total) [T1].

The above limitations were established in Permits 98120050 and 02070011, pursuant to 40 CFR 52.21, Prevention of Significant Deterioration (PSD). These limits ensure that the construction and/or modification addressed in the aforementioned permit does not constitute a new major source or major modification pursuant to Title I of the CAA, specifically the federal rules for Prevention of Significant Deterioration (PSD), 40 CFR 52.21 [T1].

7.1.7 Testing Requirements

None

7.1.8 Monitoring Requirements

- a. i. The owner or operator of an affected turbine subject to 35 IAC 217 Subpart V (Condition 7.1.3(d)) shall install, calibrate, maintain and operate continuous emissions monitoring systems (CEMS) for NO_x that meet the requirements of 40 CFR 75, Subpart B [35 IAC 217.710(a)].

- ii. Notwithstanding 35 IAC 217.710(a) above, the owner or operator of a gas-fired peaking unit or oil-fired peaking unit as defined in 40 CFR 72.2 may determine NO_x emissions in accordance with the emissions estimation protocol of 40 CFR 75, Subpart E [35 IAC 217.710(b)].
- iii. Notwithstanding 35 IAC 217.710(a) above, the owner or operator of a combustion turbine that operates less than 350 hour per ozone control period may determine the heat input and NO_x emissions of the turbine as follows [35 IAC 217.710(c)]:
 - A. Heat input shall be determined from the metered fuel usage to the turbine or the calculated heat input determined as the product of the turbine's maximum hourly heat input and hours of operation as recorded by operating instrumentation on the turbine [35 IAC 217.710(c)(1)].
 - B. NO_x emissions shall be determined as the product of the heat input, as determined above, and the appropriate default NO_x emission factors below [35 IAC 217.710(c)(2)]:
 - 0.7 lbs/mmBtu - Natural gas
 - 1.2 lbs/mmBtu - Fuel oil

7.1.9 Recordkeeping Requirements

In addition to the records required by Condition 5.6, the Permittee shall maintain records of the following items for the affected turbines to demonstrate compliance with 5.5.1 and 7.1.6, pursuant to Section 39.5(7)(b) of the Act:

- a. The owner or operator of an affected turbine subject to the requirements of 35 IAC 217 Subpart V (Condition 7.1.3(d)) shall:
 - i. Comply with the recordkeeping and reporting requirements of 40 CFR 75 applicable to NO_x emissions during the ozone control period, including, but not limited to, 40 CFR 75.54(b) and (d) [35 IAC 217.712(a)].
 - ii. Notwithstanding 35 IAC 217.712(a) above, the owner or operator of a combustion turbine for which heat input and NO_x emissions are determined pursuant to 35 IAC 217.710(c) (Condition 7.1.8(a)(iii)) shall comply with the following recordkeeping and reporting requirements [35 IAC 217.712(b)]:

- A. Maintain records of the heat input and NO_x emissions of the turbine as determined in accordance with 35 IAC 217.710(c), and records of metered fuel use or operating hours used to determine heat input [35 IAC 217.712(b)(1)].
- b. A maintenance and repair log for each affected turbine, listing each activity performed with date.
- c. The sulfur content of the fuel fired in the affected turbine.
- d. Fuel consumption for the affected turbines, scf/month and scf/year.
- e. Heat content of the fuel being fired in the affected turbines.
- f.
 - i. Emissions of each pollutant from each affected turbine with supporting calculations including documentation on the validity of the emission factors used, ton/month and ton/yr.
 - ii. Total emissions of each pollutant from the affected turbines with supporting calculations including documentation on the validity of the emission factors used, ton/month and ton/yr.
- g. The Permittee shall maintain the following if any day in which emission and/or opacity exceeded an applicable standard or limit.

7.1.10 Reporting Requirements

- a. The Permittee shall promptly notify the Illinois EPA, Compliance Section, of deviations of the affected turbines with the permit requirements as follows, pursuant to Section 39.5(7)(f)(ii) of the Act. Reports shall describe the probable cause of such deviations, and any corrective actions or preventive measures taken:
 - i. Emissions from or operation of an affected turbine in excess of the limits specified in Conditions 7.1.3, 7.1.5, and 7.1.6 within 30 days of such occurrence.
- b.
 - i. Annually report the heat input and NO_x emissions of the turbines as determined in accordance with 35 IAC 217.710(c) (Condition 7.1.8(a)(iii)), for each ozone control period, by November 30 of each year [35 IAC 217.712(b)(2)].

- ii. Pursuant to 35 IAC 217.712(c) and (d), no later than November 30 of each year, the Permittee shall submit a report to the Illinois EPA that demonstrates that the affected turbines ACT 1, ACT 2, and ACT 5 have complied with Condition 7.1.3(d). These reports shall be accompanied by a certification statement signed by a responsible official for the Permittee as specified by 35 IAC 217.712(c). If demonstrating compliance through 35 IAC 217.708 (Condition 7.1.3(d)(ii)), the reports shall demonstrate the following [35 IAC 217.712(e)]:
 - A. For all EGUs participating in the averaging demonstration, the averaged ozone control period NO_x emission rate pursuant to the equation in 35 IAC 217.708(b) (Condition 7.1.3(d)(ii)) [35 IAC 217.712(e)(1)].
 - B. The average ozone control period NO_x emission rate of each EGU participating in the averaging demonstration [35 IAC 217.712(e)(2)].
 - C. The information required to determine the averaged NO_x emission rate pursuant to 35 IAC 217.708(b) (Condition 7.1.3(d)(ii)) [35 IAC 217.712(e)(3)].

7.1.11 Operational Flexibility/Anticipated Operating Scenarios

N/A

7.1.12 Compliance Procedures

- a. Compliance with Condition 7.1.3(c) is demonstrated by proper operating conditions of the affected turbines.
- b. Compliance with Condition 7.1.3(d) shall be demonstrated by the monitoring requirements of 7.1.8, the records required in Condition 7.1.9, and the reporting requirements of 7.1.10.
- c. Compliance with the emission limits in Conditions 5.5 and 7.1.6 shall be determined by using published emission factors, Illinois EPA approved stack test data, Illinois EPA approved measured emission factors, or approved manufacturer's data and the recordkeeping requirements in Condition 7.1.9.

8.0 GENERAL PERMIT CONDITIONS

8.1 Permit Shield

Pursuant to Section 39.5(7)(j) of the Act, the Permittee has requested and has been granted a permit shield. This permit shield provides that compliance with the conditions of this permit shall be deemed compliance with applicable requirements which were applicable as of the date the proposed permit for this source was issued, provided that either the applicable requirements are specifically identified within this permit, or the Illinois EPA, in acting on this permit application, has determined that other requirements specifically identified are not applicable to this source and this determination (or a concise summary thereof) is included in this permit.

This permit shield does not extend to applicable requirements which are promulgated after October 10, 2002 (the date of issuance of the draft permit) unless this permit has been modified to reflect such new requirements.

8.2 Applicability of Title IV Requirements (Acid Deposition Control)

This source is not an affected source under Title IV of the CAA and is not subject to requirements pursuant to Title IV of the CAA.

8.3 Emissions Trading Programs

No permit revision shall be required for increases in emissions allowed under any USEPA approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for elsewhere in this permit and that are authorized by the applicable requirement [Section 39.5(7)(o)(vii) of the Act].

As of the date of issuance of this permit, there are no such economic incentive, marketable permit or emission trading programs that have been approved by USEPA.

8.4 Operational Flexibility/Anticipated Operating Scenarios

8.4.1 Changes Specifically Addressed by Permit

Physical or operational changes specifically addressed by the Conditions of this permit that have been identified as not requiring Illinois EPA notification may be implemented without prior notice to the Illinois EPA.

8.4.2 Changes Requiring Prior Notification

The Permittee is authorized to make physical or operational changes that contravene express permit terms without applying for or obtaining an amendment to this permit, provided that [Section 39.5(12)(a)(i) of the Act]:

- a. The changes do not violate applicable requirements;
- b. The changes do not contravene federally enforceable permit terms or conditions that are monitoring (including test methods), recordkeeping, reporting, or compliance certification requirements;
- c. The changes do not constitute a modification under Title I of the CAA;
- d. Emissions will not exceed the emissions allowed under this permit following implementation of the physical or operational change; and
- e. The Permittee provides written notice to the Illinois EPA, Division of Air Pollution Control, Permit Section, at least 7 days before commencement of the change. This notice shall:
 - i. Describe the physical or operational change;
 - ii. Identify the schedule for implementing the physical or operational change;
 - iii. Provide a statement of whether or not any New Source Performance Standard (NSPS) is applicable to the physical or operational change and the reason why the NSPS does or does not apply;
 - iv. Provide emission calculations which demonstrate that the physical or operational change will not result in a modification; and
 - v. Provide a certification that the physical or operational change will not result in emissions greater than authorized under the Conditions of this permit.

8.5 Testing Procedures

Tests conducted to measure composition of materials, efficiency of pollution control devices, emissions from process or control equipment, or other parameters shall be conducted using standard test methods. Documentation of the test date, conditions, methodologies, calculations, and test results shall be retained pursuant to the recordkeeping procedures of this permit. Reports of any tests conducted as required by this permit or as the result of a request by the Illinois EPA shall be submitted as specified in Condition 8.6.

8.6 Reporting Requirements

8.6.1 Monitoring Reports

If monitoring is required by any applicable requirements or conditions of this permit, a report summarizing the required monitoring results, as specified in the conditions of this permit, shall be submitted to the Air Compliance Section of the Illinois EPA every six months as follows [Section 39.5(7)(f) of the Act]:

<u>Monitoring Period</u>	<u>Report Due Date</u>
January - June	September 1
July - December	March 1

All instances of deviations from permit requirements must be clearly identified in such reports. All such reports shall be certified in accordance with Condition 9.9.

8.6.2 Test Notifications

Unless otherwise specified elsewhere in this permit, a written test plan for any test required by this permit shall be submitted to the Illinois EPA for review at least 60 days prior to the testing pursuant to Section 39.5(7)(a) of the Act. The notification shall include at a minimum:

- a. The name and identification of the affected unit(s);
- b. The person(s) who will be performing sampling and analysis and their experience with similar tests;
- c. The specific conditions under which testing will be performed, including a discussion of why these conditions will be representative of maximum emissions and the means by which the operating parameters for the source and any control equipment will be determined;
- d. The specific determination of emissions and operation which are intended to be made, including sampling and monitoring locations;
- e. The test method(s) which will be used, with the specific analysis method, if the method can be used with different analysis methods;
- f. Any minor changes in standard methodology proposed to accommodate the specific circumstances of testing, with justification; and

- g. Any proposed use of an alternative test method, with detailed justification.

8.6.3 Test Reports

Unless otherwise specified elsewhere in this permit, the results of any test required by this permit shall be submitted to the Illinois EPA within 60 days of completion of the testing. The test report shall include at a minimum [Section 39.5(7)(e)(i) of the Act]:

- a. The name and identification of the affected unit(s);
- b. The date and time of the sampling or measurements;
- c. The date any analyses were performed;
- d. The name of the company that performed the tests and/or analyses;
- e. The test and analytical methodologies used;
- f. The results of the tests including raw data, and/or analyses including sample calculations;
- g. The operating conditions at the time of the sampling or measurements; and
- h. The name of any relevant observers present including the testing company's representatives, any Illinois EPA or USEPA representatives, and the representatives of the source.

8.6.4 Reporting Addresses

- a. The following addresses should be utilized for the submittal of reports, notifications, and renewals:
 - i. Illinois EPA - Air Compliance Section

Illinois Environmental Protection Agency
Bureau of Air
Compliance Section (#40)
P.O. Box 19276
Springfield, Illinois 62794-9276
 - ii. Illinois EPA - Air Regional Field Office

Illinois Environmental Protection Agency
Division of Air Pollution Control
5415 North University
Peoria, Illinois 61614

iii. Illinois EPA - Air Permit Section (MC 11)

Illinois Environmental Protection Agency
Division of Air Pollution Control
Permit Section
P.O. Box 19506
Springfield, Illinois 62794-9506

iv. USEPA Region 5 - Air Branch

USEPA (AE - 17J)
Air & Radiation Division
77 West Jackson Boulevard
Chicago, Illinois 60604

- b. Unless otherwise specified in the particular provision of this permit, reports shall be sent to the Illinois EPA - Air Compliance Section with a copy sent to the Illinois EPA - Air Regional Field Office.

8.7 Obligation to Comply with Title I Requirements

Any term, condition, or requirement identified in this permit by T1, T1R, or T1N is established or revised pursuant to 35 IAC Part 203 or 40 CFR 52.21 ("Title I provisions") and incorporated into this permit pursuant to both Section 39.5 and Title I provisions. Notwithstanding the expiration date on the first page of this permit, the Title I conditions remain in effect pursuant to Title I provisions until the Illinois EPA deletes or revises them in accordance with Title I procedures.

9.0 STANDARD PERMIT CONDITIONS

9.1 Effect of Permit

9.1.1 The issuance of this permit does not release the Permittee from compliance with State and Federal regulations which are part of the Illinois State Implementation Plan, as well as with other applicable statutes and regulations of the United States or the State of Illinois or applicable ordinances, except as specifically stated in this permit and as allowed by law and rule [Section 39.5(7)(j)(iv) of the Act].

9.1.2 In particular, this permit does not alter or affect the following:

- a. The provisions of Section 303 (emergency powers) of the CAA, including USEPA's authority under that Section;
- b. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
- c. The applicable requirements of the acid rain program consistent with Section 408(a) of the CAA; and
- d. The ability of USEPA to obtain information from a source pursuant to Section 114 (inspections, monitoring, and entry) of the CAA.

9.1.3 Notwithstanding the conditions of this permit specifying compliance practices for applicable requirements, any person (including the Permittee) may also use other credible evidence to establish compliance or noncompliance with applicable requirements.

9.2 General Obligations of Permittee

9.2.1 Duty to Comply

The Permittee must comply with all terms and conditions of this permit. Any permit noncompliance constitutes a violation of the CAA and the Act, and is grounds for any or all of the following: enforcement action, permit termination, revocation and reissuance, modification, or denial of a permit renewal application [Section 39.5(7)(o)(i) of the Act].

The Permittee shall meet applicable requirements that become effective during the permit term in a timely manner unless an alternate schedule for compliance with the applicable requirement is established.

9.2.2 Duty to Maintain Equipment

The Permittee shall maintain all equipment covered under this permit in such a manner that the performance or operation of such equipment shall not cause a violation of applicable requirements.

9.2.3 Duty to Cease Operation

No person shall cause, threaten or allow the continued operation of any emission unit during malfunction or breakdown of the emission unit or related air pollution control equipment if such operation would cause a violation of an applicable emission standard, regulatory requirement, ambient air quality standard or permit limitation unless such malfunction or breakdown is allowed by a permit condition [Section 39.5(6)(c) of the Act].

9.2.4 Disposal Operations

The source shall be operated in such a manner that the disposal of air contaminants collected by the equipment operations, or activities shall not cause a violation of the Act or regulations promulgated thereunder.

9.2.5 Duty to Pay Fees

The Permittee must pay fees to the Illinois EPA consistent with the fee schedule approved pursuant to Section 39.5(18) of the Act, and submit any information relevant thereto [Section 39.5(7)(o)(vi) of the Act]. The check should be payable to "Treasurer, State of Illinois" and sent to: Fiscal Services Section, Illinois Environmental Protection Agency, P.O. Box 19276, Springfield, Illinois 62794-9276.

9.3 Obligation to Allow Illinois EPA Surveillance

Upon presentation of proper credentials and other documents, the Permittee shall allow the Illinois EPA, or an authorized representative to perform the following [Section 39.5(7)(a) and (p)(ii) of the Act and 415 ILCS 5/4]:

- a. Enter upon the Permittee's premises where an actual or potential emission unit is located; where any regulated equipment, operation, or activity is located or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;

- c. Inspect during hours of operation any sources, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- d. Sample or monitor any substances or parameters at any location:
 - i. At reasonable times, for the purposes of assuring permit compliance; or
 - ii. As otherwise authorized by the CAA, or the Act.
- e. Obtain and remove samples of any discharge or emission of pollutants authorized by this permit; and
- f. Enter and utilize any photographic, recording, testing, monitoring, or other equipment for the purposes of preserving, testing, monitoring, or recording any activity, discharge or emission at the source authorized by this permit.

9.4 Obligation to Comply With Other Requirements

The issuance of this permit does not release the Permittee from applicable State and Federal laws and regulations, and applicable local ordinances addressing subjects other than air pollution control.

9.5 Liability

9.5.1 Title

This permit shall not be considered as in any manner affecting the title of the premises upon which the permitted source is located.

9.5.2 Liability of Permittee

This permit does not release the Permittee from any liability for damage to person or property caused by or resulting from the construction, maintenance, or operation of the sources.

9.5.3 Structural Stability

This permit does not take into consideration or attest to the structural stability of any unit or part of the source.

9.5.4 Illinois EPA Liability

This permit in no manner implies or suggests that the Illinois EPA (or its officers, agents or employees)

assumes any liability, directly or indirectly, for any loss due to damage, installation, maintenance, or operation of the source.

9.5.5 Property Rights

This permit does not convey any property rights of any sort, or any exclusive privilege [Section 39.5(7)(o)(iv) of the Act].

9.6 Recordkeeping

9.6.1 Control Equipment Maintenance Records

A maintenance record shall be kept on the premises for each item of air pollution control equipment. As a minimum, this record shall show the dates of performance and nature of preventative maintenance activities.

9.6.2 Records of Changes in Operation

A record shall be kept describing changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under this permit, and the emissions resulting from those changes [Section 39.5(12)(b)(iv) of the Act].

9.6.3 Retention of Records

- a. Records of all monitoring data and support information shall be retained for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records, original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit [Section 39.5(7)(e)(ii) of the Act].
- b. Other records required by this permit shall be retained for a period of at least 5 years from the date of entry unless a longer period is specified by a particular permit provision.

9.7 Annual Emissions Report

The Permittee shall submit an annual emissions report to the Illinois EPA, Compliance Section no later than May 1 of the following year, as required by 35 IAC Part 254.

9.8 Requirements for Compliance Certification

Pursuant to Section 39.5(7)(p)(v) of the Act, the Permittee shall submit annual compliance certifications. The compliance certifications shall be submitted no later than May 1 or more frequently as specified in the applicable requirements or by permit condition. The compliance certifications shall be submitted to the Air Compliance Section, Air Regional Field Office, and USEPA Region 5 - Air Branch. The addresses for the submittal of the compliance certifications are provided in Condition 8.6.4 of this permit.

- a. The certification shall include the identification of each term or condition of this permit that is the basis of the certification; the compliance status; whether compliance was continuous or intermittent; the method(s) used for determining the compliance status of the source, both currently and over the reporting period consistent with the conditions of this permit.
- b. All compliance certifications shall be submitted to USEPA Region 5 in Chicago as well as to the Illinois EPA.
- c. All compliance reports required to be submitted shall include a certification in accordance with Condition 9.9.

9.9 Certification

Any document (including reports) required to be submitted by this permit shall contain a certification by a responsible official of the Permittee that meets the requirements of Section 39.5(5) of the Act [Section 39.5(7)(p)(i) of the Act]. An example Certification by a Responsible Official is included as an attachment to this permit.

9.10 Defense to Enforcement Actions

9.10.1 Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit [Section 39.5(7)(o)(ii) of the Act].

9.10.2 Emergency Provision

- a. An emergency shall be an affirmative defense to an action brought for noncompliance with the technology-based emission limitations under this permit if the following conditions are met through properly signed, contemporaneous operating logs, or other relevant evidence:

- i. An emergency occurred as provided in Section 39.5(7)(k) of the Act and the Permittee can identify the cause(s) of the emergency. Normally, an act of God such as lightning or flood is considered an emergency;
 - ii. The permitted source was at the time being properly operated;
 - iii. The Permittee submitted notice of the emergency to the Illinois EPA within two working days of the time when emission limitations were exceeded due to the emergency. This notice must contain a detailed description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - iv. During the period of the emergency the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission limitations, standards, or regulations in this permit.
- b. This provision is in addition to any emergency or upset provision contained in any applicable requirement. This provision does not relieve a Permittee of any reporting obligations under existing federal or state laws or regulations.

9.11 Permanent Shutdown

This permit only covers emission units and control equipment while physically present at the indicated source location(s). Unless this permit specifically provides for equipment relocation, this permit is void for the operation or activity of any item of equipment on the date it is removed from the permitted location(s) or permanently shut down. This permit expires if all equipment is removed from the permitted location(s), notwithstanding the expiration date specified on this permit.

9.12 Reopening and Reissuing Permit for Cause

9.12.1 Permit Actions

This permit may be modified, reopened, and reissued, for cause pursuant to Section 39.5(15) of the Act. The filing of a request by the Permittee for a permit modification, revocation, and reissuance, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition [Section 39.5(7)(o)(iii) of the Act].

9.12.2 Reopening and Revision

This permit must be reopened and revised if any of the following occur [Section 39.5(15)(a) of the Act]:

- a. Additional requirements become applicable to the equipment covered by this permit and three or more years remain before expiration of this permit;
- b. Additional requirements become applicable to an affected source for acid deposition under the acid rain program;
- c. The Illinois EPA or USEPA determines that this permit contains a material mistake or inaccurate statement when establishing the emission standards or limitations, or other terms or conditions of this permit; and
- d. The Illinois EPA or USEPA determines that this permit must be revised to ensure compliance with the applicable requirements of the Act.

9.12.3 Inaccurate Application

The Illinois EPA has issued this permit based upon the information submitted by the Permittee in the permit application. Any misinformation, false statement or misrepresentation in the application shall be grounds for revocation under Section 39.5(15)(b) of the Act.

9.12.4 Duty to Provide Information

The Permittee shall furnish to the Illinois EPA, within a reasonable time specified by the Illinois EPA any information that the Illinois EPA may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. Upon request, the Permittee shall also furnish to the Illinois EPA copies of records required to be kept by this permit, or for information claimed to be confidential, the Permittee may furnish such records directly to USEPA along with a claim of confidentiality [Section 39.5(7)(o)(v) of the Act].

9.13 Severability Clause

The provisions of this permit are severable, and should any one or more be determined to be illegal or unenforceable, the validity of the other provisions shall not be affected. The rights and obligations of the Permittee shall be construed and enforced as if this permit did not contain the particular provisions held to be invalid and the applicable requirements underlying these provisions shall remain in force [Section 39.5(7)(i) of the Act].

9.14 Permit Expiration and Renewal

The right to operate terminates on the expiration date unless the Permittee has submitted a timely and complete renewal application. For a renewal to be timely it must be submitted no later than 9 and no sooner than 12 months prior to expiration. The equipment may continue to operate during the renewal period until final action is taken by the Illinois EPA, in accordance with the original permit conditions [Section 39.5(5)(1), (n), and (o) of the Act].

10.0 ATTACHMENTS

10.1 Attachment 1 - Example Certification by a Responsible Official

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Signature: _____

Name: _____

Official Title: _____

Telephone No.: _____

Date Signed: _____

10.2 Attachment 2 - Guidance on Revising This Permit

The Permittee must submit an application to the Illinois EPA using the appropriate revision classification in accordance with Sections 39.5(13) and (14) of the Act and 35 IAC 270.302. Specifically, there are currently three classifications for revisions to a CAAPP permit. These are:

1. Administrative Permit Amendment;
2. Minor Permit Modification; and
3. Significant Permit Modification.

The Permittee must determine, request, and submit the necessary information to allow the Illinois EPA to use the appropriate procedure to revise the CAAPP permit. A brief explanation of each of these classifications follows.

1. Administrative Permit Amendment
 - Corrects typographical errors;
 - Identifies a change in the name, address, or phone number of any person identified in the permit, or provides a similar minor administrative change at the source;
 - Requires more frequent monitoring or reporting by the Permittee;
 - Allows for a change in ownership or operational control of the source where no other change in the permit is necessary, provided that a written agreement containing a specific date for transfer of permit responsibility, coverage, and liability between the current and new Permittees has been submitted to the Illinois EPA. This shall be handled by completing form 272-CAAPP, REQUEST FOR OWNERSHIP CHANGE FOR CAAPP PERMIT; or
 - Incorporates into the CAAPP permit a construction permit, provided the conditions of the construction permit meet the requirements for the issuance of CAAPP permits.
2. Minor Permit Modification
 - Do not violate any applicable requirement;
 - Do not involve significant changes to existing monitoring, reporting, or recordkeeping requirements in the permit;

- Do not require a case-by-case determination of an emission limitation or other standard, or a source-specific determination of ambient impacts, or a visibility or increment analysis;
- Do not seek to establish or change a permit term or condition for which there is no corresponding underlying requirement and which avoids an applicable requirement to which the source would otherwise be subject. Such terms and conditions include:
 - A federally enforceable emissions cap assumed to avoid classification as a modification under any provision of Title I of the CAA; and
 - An alternative emissions limit approved pursuant to regulations promulgated under Section 112(i)(5) of the CAA.
- Are not modifications under any provision of Title I of the CAA;
- Are not required to be processed as a significant permit modification; and
- Modifications involving the use of economic incentives, marketable permits, emissions trading, and other similar approaches.

An application for a minor permit modification shall include the following:

- A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
- The source's suggested draft permit/conditions;
- Certification by a responsible official that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used; and
- Information as contained on form 271-CAAPP, MINOR PERMIT MODIFICATION FOR CAAPP PERMIT for the Illinois EPA to use to notify USEPA and affected States.

3. Significant Permit Modification

- Applications that do not qualify as either minor permit modifications or as administrative permit amendments;

- Applications requesting a significant change in existing monitoring permit terms or conditions;
- Applications requesting a relaxation of reporting or recordkeeping requirements; and
- Cases in which, in the judgment of the Illinois EPA, action on an application for modification would require decisions to be made on technically complex issues.

An application for a significant permit modification shall include the following:

- A detailed description of the proposed change(s), including all physical changes to equipment, changes in the method of operation, changes in emissions of each pollutant, and any new applicable requirements which will apply as a result of the proposed change. Note that the Permittee need only submit revised forms for equipment and operations that will be modified.

The Illinois EPA requires the information on the following appropriate forms to be submitted in accordance with the proper classification:

- Form 273-CAAPP, REQUEST FOR ADMINISTRATIVE PERMIT AMENDMENT FOR CAAPP PERMIT; or
- Form 271-CAAPP, MINOR PERMIT MODIFICATION FOR CAAPP PERMIT; or
- Form 200-CAAPP, APPLICATION FOR CAAPP PERMIT (for significant modification).

Application forms can be obtained from the Illinois EPA website at <http://www.epa.state.il.us/air/forms>.

Note that the request to revise the permit must be certified for truth, accuracy, and completeness by a responsible official.

Note that failure to submit the required information may require the Illinois EPA to deny the application. The Illinois EPA reserves the right to require that additional information be submitted as needed to evaluate or take final action on applications pursuant to Section 39.5(5)(g) of the Act and 35 IAC 270.305.



Illinois Environmental Protection Agency
Division Of Air Pollution Control -- Permit Section
P.O. Box 19506
Springfield, Illinois 62794-9506

Application For Construction Permit (For CAAPP Sources Only)	For Illinois EPA use only
	I.D. number:
	Permit number:
	Date received:

This form is to be used by CAAPP sources to supply information necessary to obtain a construction permit. Please attach other necessary information and completed CAAPP forms regarding this construction/modification project.

Source Information		
1. Source name:		
2. Source street address:		
3. City:	4. Zip code:	
5. Is the source located within city limits? <input type="checkbox"/> Yes <input type="checkbox"/> No		
6. Township name:	7. County:	8. I.D. number:

Owner Information		
9. Name:		
10. Address:		
11. City:	12. State:	13. Zip code:

Operator Information (if different from owner)		
14. Name		
15. Address:		
16. City:	17. State:	18. Zip code:

Applicant Information	
19. Who is the applicant? <input type="checkbox"/> Owner <input type="checkbox"/> Operator	20. All correspondence to: (check one) <input type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Source
21. Attention name and/or title for written correspondence:	
22. Technical contact person for application:	23. Contact person's telephone number:

This Agency is authorized to require and you must disclose this information under 415 ILCS 5/39. Failure to do so could result in the application being denied and penalties under 415 ILCS 5 et seq. It is not necessary to use this form in providing this information. This form has been approved by the forms management center.

Summary Of Application Contents

24.	Does the application address whether the proposed project would constitute a new major source or major modification under each of the following programs: a) Non-attainment New Source Review – 35 IAC Part 203; b) Prevention of Significant Deterioration (PSD) – 40 CFR 52.21; c) Hazardous Air Pollutants: Regulations Governing Constructed or Reconstructed Major Sources – 40 CFR Part 63?	<input type="checkbox"/> Yes <input type="checkbox"/> No
25.	Does the application identify and address all applicable emissions standards, including those found in the following: a) Board Emission Standards – 35 IAC Chapter I, Subtitle B; b) Federal New Source Performance Standards – 40 CFR Part 60; c) Federal Standards for Hazardous Air Pollutants – 40 CFR Parts 61 and 63?	<input type="checkbox"/> Yes <input type="checkbox"/> No
26.	Does the application include a process flow diagram(s) showing all emission units and control equipment, and their relationship, for which a permit is being sought?	<input type="checkbox"/> Yes <input type="checkbox"/> No
27.	Does the application include a complete process description for the emission units and control equipment for which a permit is being sought?	<input type="checkbox"/> Yes <input type="checkbox"/> No
28.	Does the application include the information as contained in completed CAAPP forms for all appropriate emission units and air pollution control equipment, listing all applicable requirements and proposed exemptions from otherwise applicable requirements, and identifying and describing any outstanding legal actions by either the USEPA or the Illinois EPA? Note: The use of "APC" application forms is not appropriate for applications for CAAPP sources. CAAPP forms should be used to supply information.	<input type="checkbox"/> Yes <input type="checkbox"/> No
29.	If the application contains TRADE SECRET information, has such information been properly marked and claimed, and have two separate copies of the application suitable for public inspection and notice been submitted, in accordance with applicable rules and regulations?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Applicable, No TRADE SECRET information in this application

Note 1: Answering "No" to any of the above may result in the application being deemed incomplete.

Signature Block

This certification must be signed by a responsible official. Applications without a signed certification will be returned as incomplete.	
30.	I certify under penalty of law that, based on information and belief formed after reasonable inquiry, the statements and information contained in this application are true, accurate and complete. Authorized Signature: BY: _____ <div style="display: flex; justify-content: space-between; margin-top: 10px;"> <div style="width: 45%; text-align: center;"> _____ <small>AUTHORIZED SIGNATURE</small> </div> <div style="width: 45%; text-align: center;"> _____ <small>TITLE OF SIGNATORY</small> </div> </div> <div style="display: flex; justify-content: space-between; margin-top: 10px;"> <div style="width: 45%; text-align: center;"> _____ <small>TYPED OR PRINTED NAME OF SIGNATORY</small> </div> <div style="width: 45%; text-align: center;"> _____ / _____ / _____ <small>DATE</small> </div> </div>

Note 2: An operating permit for the construction/modification permitted in a construction permit must be obtained by applying for the appropriate revision to the source's CAAPP permit, if necessary

10.4 Attachment 4 - Guidance on Renewing This Permit

Timeliness - Pursuant to Section 39.5(5)(n) of the Act and 35 IAC 270.301(d), a source must submit to the Illinois EPA a complete CAAPP application for the renewal of a CAAPP permit not later than 9 months before the date of permit expiration of the existing CAAPP permit in order for the submittal to be deemed timely. Note that the Illinois EPA typically sends out renewal notices approximately 18 months prior to the expiration of the CAAPP permit.

The CAAPP application must provide all of the following information in order for the renewal CAAPP application to be deemed complete by the Illinois EPA:

1. A completed form 200-CAAPP, APPLICATION FOR CAAPP PERMIT.
2. A completed compliance certification for the source. For this purpose, the Illinois EPA will accept a copy of the most recent form 401-CAAPP, ANNUAL COMPLIANCE CERTIFICATION submitted to the Illinois EPA.
3. If this is the first time this permit is being renewed and this source has not yet addressed CAM, the application should contain the information on form 464-CAAPP, COMPLIANCE ASSURANCE MONITORING (CAM) PLAN.
4. Information addressing any outstanding transfer agreement pursuant to the ERMS.
5.
 - a. If operations of an emission unit or group of emission units remain unchanged and are accurately depicted in previous submittals, the application may contain a letter signed by a responsible official that requests incorporation by reference of existing information previously submitted and on file with the Illinois EPA. The boxes should be marked yes on form 200-CAAPP, APPLICATION FOR CAAPP PERMIT, as existing information is being incorporated by reference.
 - b. If portions of current operations are not as described in previous submittals, then in addition to the information above for operations that remain unchanged, the application must contain the necessary information on all changes, e.g., discussion of changes, new or revised CAAPP forms, and a revised fee form 292-CAAPP, FEE DETERMINATION FOR CAAPP PERMIT, if necessary.

The Illinois EPA will review all applications for completeness and timeliness. If the renewal application is deemed both timely and complete, the source shall continue to operate in accordance

with the terms and conditions of its CAAPP permit until final action is taken on the renewal application.

Notwithstanding the completeness determination, the Illinois EPA may request additional information necessary to evaluate or take final action on the CAAPP renewal application. If such additional information affects your allowable emission limits, a revised form 292-CAAPP, FEE DETERMINATION FOR CAAPP PERMIT must be submitted with the requested information. The failure to submit to the Illinois EPA the requested information within the time frame specified by the Illinois EPA, may force the Illinois EPA to deny your CAAPP renewal application pursuant to Section 39.5 of the Act.

Application forms may be obtained from the Illinois EPA website at <http://www.epa.state.il.us/air/forms.html>.

If you have any questions regarding this matter, please contact a permit analyst at 217/782-2113.

Mail renewal applications to:

Illinois Environmental Protection Agency
Division of Air Pollution Control
Permit Section (MC 11)
P.O. Box 19506
Springfield, Illinois 62794-9506

JRC:ELK:psj