

3745-18-49

Lake county emission limits.

(F) The "Painesville Municipal Electric Plant" (OEPA premise

number 0243110008) or any subsequent owner or operator of the "Painesville Municipal Electric Plant, 325 Richmond Street, Painesville, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler numbers 3, 4 and 5 (OEPA source numbers B001, B003, and B004) to exceed a maximum of 5.7 pounds of sulfur dioxide per MM Btu actual heat input from each boiler and shall operate said boilers such that their combined average operating rate shall not exceed five hundred ninety three MM Btu per hour for any calendar day.

Effective: May 11, 1987  
Promulgated under: Chapter 119  
Rule amplifies: Section 3704.03  
Prior effective date: 12/28/79, 11/1/84