

(B) The "Dayton Power and Light Company, J. M. Stuart Electric Generating Station" (OEPA premise number 0701000007) or any subsequent owner or operator of the "Dayton Power and Light Company, J. M. Stuart Electric Generating Station," Aberdeen, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:

- (1) Auxiliary boiler and diesel unit numbers 1 through 4 (OEPA source numbers B005 through B009); a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each unit.
- (2) Boiler numbers 1 through 4 (OEPA source numbers B001 through B004); a maximum of 3.16 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.

Effective: May 11, 1987
Promulgated under: Chapter 119
Rule amplifies: R.C. Section 3704.03
Prior effective date: 12/28/79