

3745-18-12

Auglaize County emission limits.

- (A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified below, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "St. Marys Municipal Light and Power" (OEPA premise number 0306010010) or any subsequent owner or operator of the "St. Marys Municipal Light and Power" facility located at 101 East Spring Street, St. Marys, Ohio shall not cause or permit the emission of sulfur dioxide from boiler ~~number numbers~~ 6 and 5 (OEPA source ~~number numbers~~ B001 and B002) to exceed a maximum of ~~6.5~~ 5.9 pounds of sulfur dioxide per MM Btu actual heat input.
- (C) The "Goodyear Tire & Rubber Company" (OEPA premise number 0306010138) or any subsequent owner or operator of the "Goodyear Tire & Rubber Company" facility located on South Wayne Street, St. Marys, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:
- (1) Boiler numbers 3, 5, and 6 (OEPA source numbers B003, B005, and B007); a maximum of 4.2 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
 - (2) Boiler numbers 1, 2, and 4 (OEPA source numbers B001, B002, and B004); a maximum of 0.0 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.

Effective: 01/23/2006
R.C. 119.032 review dates: 10/28/2005 and 01/23/2011

CERTIFIED ELECTRONICALLY

Certification

01/13/2006

Date

Promulgated Under: 119.03
Statutory Authority: 3704.03(E)
Rule Amplifies: 3704.03(A) and 3704.03(E)
Prior Effective Dates: 12/28/79