

3745-18-91

Wayne County emission limits.

- (A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified below, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 7.2 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "Apple Creek State Institute" (OEPA premise number 0285000028) or any subsequent owner or operator of the "Apple Creek State Institute" facility located in Apple Creek, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 3, 4, 5, and 2 (OEPA source numbers B001 through B004) to exceed a maximum of 6.3 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
- (C) The "~~Orrville Milk Company~~NPC Incorporated" (OEPA premise number 0285010092) or any subsequent owner or operator of the "~~Orrville Milk Company~~NPC Incorporated" facility located at 429 Westwood Avenue, Orrville, Ohio shall not cause or permit the emission of sulfur dioxide from boiler number FF-16 (OEPA source number B001) to exceed a maximum of 1.6 pounds of sulfur dioxide per MM Btu actual heat input.
- (D) The "Koppers Company, Incorporated" (OEPA premise number 0285010156) or any subsequent owner or operator of the "Koppers Company, Incorporated" facility located on Orr Street Extension, Orrville, Ohio shall not cause or permit the emission of sulfur dioxide from boiler number 1 (OEPA source number B003) to exceed a maximum of 6.3 pounds of sulfur dioxide per MM Btu actual heat input.
- (E) The "Orrville Municipal Utility" (OEPA premise number 0285010188) or any subsequent owner or operator of the "Orrville Municipal Utility" facility located at 1115 Perry Street, Orrville, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 10 through 13 (OEPA source numbers B001 through B004) to exceed a maximum of 7.0 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
- (F) The "Morton Salt Company, Division of Morton-Norwich Products, Incorporated" (OEPA premise number 0285020059) or any subsequent owner or operator of the "Morton Salt Company, Division of Morton-Norwich Products Incorporated," facility located at 151 South Industrial Street, Rittman, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 and 2 (OEPA source numbers B001 and B003) to exceed a maximum of 7.0 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
- (G) The "~~Packaging Corporation of America~~Caraustar Industries, Inc." (OEPA premise number 0285020076) or any subsequent owner or operator of the "~~the Packaging~~

~~Corporation of America~~ Caraustar Industries, Inc. facility located on Industrial Street, Rittman, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:

- (1) Boiler numbers 1 through 3 (OEPA source numbers B001 through B003); a maximum of 7.0 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
 - (2) Boiler number 4 (OEPA source number B004); a maximum of 1.2 pounds of sulfur dioxide per MM Btu actual heat input.
- (H) The "College of Wooster" (OEPA premise number 0285030180) or any subsequent owner or operator of the "College of Wooster" facility located on East University Street, Wooster, Ohio shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 3 (OEPA source numbers B001 through B003) to exceed a maximum of 5.4 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.

Effective: 01/23/2006

R.C. 119.032 review dates: 10/28/2005 and 01/23/2011

CERTIFIED ELECTRONICALLY

Certification

01/13/2006

Date

Promulgated Under: 119.03
Statutory Authority: 3704.03(E)
Rule Amplifies: 3704.03(A) and 3704.03(E)
Prior Effective Dates: 12/28/79