

3745-18-70      **Perry county emission limits.**

No owner or operator of any coal-fired steam generating unit shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

Effective: 02/17/2011

R.C. 119.032 review dates: 11/30/2010 and 11/30/2015

CERTIFIED ELECTRONICALLY  
Certification

02/07/2011  
Date

Promulgated Under: 119.03  
Statutory Authority: 3704.03(E)  
Rule Amplifies: 3704.03(A), 3704.03(E)  
Prior Effective Dates: 12/28/79