

- (B) The "Libbey-Owens-Ford Company Plant Numbers 4 and 8" (OEPA premise number 0387000040) or any subsequent owner or operator of the "Libbey-Owens-Ford Company Plant Numbers 4 and 8, 1769 East Broadway, Toledo, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler numbers 2 through 5 (OEPA source numbers B001 through B003) to exceed a maximum of 1.1 pounds of sulfur dioxide per MM Btu actual heat input from each boiler
- (C) The "Libbey-Owens-Ford Company Plant Number 6" (OEPA premise number 0387010012) or any subsequent owner or operator of the "Libbey-Owens-Ford Company Plant Number 6, 140 Dixie Highway, Rossford, Ohio" shall not cause or permit the emission of sulfur dioxide from boilers "D" through "F" (OEPA source numbers B002 through B004) to exceed a maximum of 1.1 pounds of sulfur dioxide per MM Btu actual heat input from each boiler

Effective: November 1, 1984
Promulgated under: Chapter 119
Rule amplifies: Section 3704.03
Prior effective date: December 28, 1979