

Morgan county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) The "Ohio Power Company, Muskingum River Plant" (OEPA premise number 0684000000) or any subsequent owner or operator of the "Ohio Power Company, Muskingum River Plant" facility located in Beverly, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:
 - (1) Boiler numbers 1 through 5 (OEPA source numbers B002 through B006); a maximum of 8.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler prior to July 1, 1989;
 - (2) Boiler numbers 1 through 5 (OEPA source numbers B002 through B006); a maximum of 7.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler on and after July 1, 1989;
 - (3) Unit 5 auxiliary boiler (OEPA source number B001); a maximum of 1.2 pounds of sulfur dioxide per MM Btu actual heat input.

Effective: 02/17/2011

R.C. 119.032 review dates: 11/30/2010 and 11/30/2015

CERTIFIED ELECTRONICALLY
Certification

02/07/2011
Date

Promulgated Under: 119.03
Statutory Authority: 3704.03(E)
Rule Amplifies: 3704.03(A), 3704.03(E)
Prior Effective Dates: 12/28/79, 4/21/82, 10/1/82