

Chapter NR 428

CONTROL OF NITROGEN COMPOUND EMISSIONS

NR 428.01 Applicability; purpose.
 NR 428.02 Definitions.
 NR 428.03 General limitations.

Subchapter I — NO_x Emissions Performance Program General Provisions
 NR 428.04 Requirements and performance standards for new or modified sources.

NR 428.05 Requirements and performance standards for existing sources.

Subchapter II — NO_x Emissions Performance Program Compliance Provisions

NR 428.06 Determination of compliance.

Subchapter III — NO_x Emissions Performance Program Monitoring And Reporting Provisions

NR 428.07 General requirements.

NR 428.08 Specific provisions for monitoring NO_x and heat input for the purpose of calculating NO_x mass emissions.

NR 428.09 Quarterly reports.

NR 428.10 Petitions.

NR 428.11 Additional requirements to provide heat input data.

Note: Corrections made under s. 13.93(2m)(b)7., Stats., Register, December, 1996, No. 492. Corrections in NR 428.04 to 428.08 made under s. 13.93(2m)(b)7., Stats., Register, January, 2001, No. 541.

NR 428.02 Definitions. The definitions contained in ch. NR 400 apply to the terms used in this chapter. In addition, the following definitions apply to the terms used in this chapter:

(1) "Biologically derived gaseous fuel" means a gaseous fuel resulting from biological processing of a carbon-based feedstock.

(1m) "Capacity factor" means one of the following:

(a) The ratio of a unit's actual electric output (expressed in MWe-hr) to the unit's nameplate capacity times the unit's potential hours of operation. The potential hours of operation on an annual basis are 8,760 hours, and on an ozone season basis are 3,672 hours.

(b) The ratio of a unit's heat input (in million Btu or equivalent units of measure) to the unit's maximum design heat input (in million Btu per hour or equivalent units of measure) times the unit's potential hours of operation.