

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

PART 2. AIR USE APPROVAL

R 336.1280 Permit system exemptions; cooling and ventilating equipment.

Rule 280. The permit system does not apply to any of the following:

- (a) Cold storage refrigeration equipment.
- (b) Comfort air conditioning or comfort ventilating systems not designed or used to remove air contaminants generated by, or released from, specific units of equipment.
- (c) Natural draft hoods or natural draft ventilation not designed or used to remove air contaminants generated by, or released from, specific units of equipment.
- (d) Water-cooling towers and water-cooling ponds not used for evaporative cooling of process water or not used for evaporative cooling of water from barometric jets or from barometric condensers.

History: 1979 ACS 1, Eff. Jan. 19, 1980.