

Clark county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified below shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 3.6 pounds of sulfur dioxide per MM Btu actual heat input.

- (B) [Reserved]

- (C) The "Ohio Edison Company, Mad River Plant" (OEPA premise number 0812790035) or any subsequent owner or operator of the "Ohio Edison Company, Mad River Plant" facility located on West Main Street, Springfield, Ohio shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:
 - (1) Boiler numbers 1 through 4 (OEPA source numbers B001 through B004); a maximum of 4.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.

 - (2) Combustion turbine numbers A and B (OEPA source numbers B005 and B006); a maximum of 1.0 pounds of sulfur dioxide per MM Btu actual heat input.

Effective: 02/17/2011

R.C. 119.032 review dates: 11/30/2010 and 11/30/2015

CERTIFIED ELECTRONICALLY
Certification

02/07/2011
Date

Promulgated Under: 119.03
Statutory Authority: 3704.03(E)
Rule Amplifies: 3704.03(A), 3704.03(E)
Prior Effective Dates: 12/28/79, 1/23/06