

SECTION 2. 326 IAC 7-4-3 IS AMENDED TO READ AS FOLLOWS:

326 IAC 7-4-3 Vigo County sulfur dioxide emission limitations

Authority: IC 13-14-8; IC 13-17-3-4
Affected: IC 13-12; IC 13-14-4-3; IC 13-16-1

Sec. 3. The following sources and facilities located in Vigo County shall comply with the sulfur dioxide emission limitations in pounds per million Btu, unless otherwise specified, and other requirements:

<u>Source</u>	<u>Facility Description</u>	<u>Emission Limitations</u>
(1) Alcan Rolled Products Co.	Sol Oil Boiler	0.51
	Foil Mill Boiler	0.51
	Oil Farm Boiler	0.51
	#2 Melter	1.60
	#3 Melter	1.60
	#4 Melter	1.60
	#5 Melter	1.60
	#6 Melter	1.60
	#7 Melter	1.60
	#53 Annealing Furnaces	1.60
	(2) Bemis	Boiler
(3) CBS	#1 WH CB200-200	0.51
	#2 WH CB200-200	0.51
	#1 HC CB293-100	0.51
	#2 HC CB M & W 4000	0.51
	#3 HC CB M & W 4000	0.51
	#1 BP Springfield	0.51
(4) CF Industries	Process Murray Boiler 1	0.52
	Process Murray Boilers 2 and 3	0.52
	#1 Kewanee Boiler	0.36
(5) Digital Audio Disc	#2 Kewanee Boiler	0.36
	Boiler	2.62
(6) Doxsee Foods Corp.	Boiler 1A Ladd	6.00
(7) General Housewares	Boiler 2A Combustion Eng.	6.00
	#5 Enamel Furnace Radiant Tube	0.51
	#6 Enamel Furnace Muffle	0.51
	Murray Iron Works Boiler A	0.51
(8) Hercules, Inc.	Murray Iron Works Boiler B	0.51
	Clayton Boiler (Standby)	0.51
	Nebraska Boiler	0.51
	#2 Voight Boiler	5.64
(9) Indiana State University	#3 Voight Boiler	5.64
	#5 B & W Boiler	5.64
	#4 Murray Boiler	0.37
	No. 1 Riley Boiler	4.74
(10) J.I. Case	No. 2 Riley Boiler	4.74
	Boiler 8	3.01
(11) Pfizer	Boiler 5	2.12
	Boiler 6	2.12
	Boiler 7	2.12
	Animal Health Boiler	1.55

Final Rules

Boiler load on Boiler 5; Boiler 6; or Boiler 7 is restricted to 55.84 million Btu per hour if Boiler 8 is also in operation. Pfizer shall maintain records which contain the actual boiler heat input, based on the average fuel heat content and on the quantity of fuel burned hourly; for any hour in which Boiler 5; Boiler 6; or Boiler 7 is in simultaneous operation with Boiler 8. The records shall be made available to the department or the Vigo County Air Pollution Control Department upon request.

(12) Pillsbury (Terre Haute)	Boiler B	0.36
	Boiler C	2.62
	Boiler D	0.36
(13) Pitman-Moore	#9, #10, and #15 Boilers	4.58
	#16 Boiler	0.36
	East Plant Boiler	0.36
(14) Public Service Indiana Wabash River	Boilers 1, 2, 3, 4, 5, and 6	4.04
(15) Rose-Hulman	#1 Voight Boiler	2.26
	#2 Cleaver Brooks Boiler	0.51
	#4 Cleaver Brooks Boiler	0.51
(16) St. Mary's Sisters of Providence	#2 Voight Boiler	3.84
	#3 B & N Boiler	3.84
	#5 B & N Boiler	3.84
	#7 Voight Boiler	3.84
	#8 Voight Boiler	3.84
(17) Snacktime Company	#1 Boiler	0.52
	#12 Boiler	0.52
	#2, #3, #4, and #6	0.52
	Fryer Oil Heaters	
(18) Terre Haute Coke and Carbon	2 CB Boilers	1.79
	2 Standby Boilers	4.55
	No. 1 CB Underfire Stack	0.63
	No. 2 CB Underfire Stack	0.63
(19) Terre Haute Regional Hospital	#1 Boiler	0.45
	(New) #2 Boiler	0.45
(20) Union Hospital Energy Co.	2 Keeler Boilers	0.36
	3 Cleaver Brooks Boilers	0.36
(21) U.S. Penitentiary	#1, #2, and #3 Boilers	0.51
	2 Honor Farm Boilers	0.51
(22) Wabash Fibre Box	Cleaver Brooks Boiler	2.36
(23) Wabash Products Co.	Boiler	natural gas only
(24) Western Tar	Tar Division, Boiler A	0.36
	Tar Division, Boiler B	0.36
	Wood Division, Boiler A	0.36
	Wood Division, Boiler B	0.36
	Tar Division, Process Still	0.36
(25) Weston Paper	B-1 and B-4 Boilers	4.09
	B-5 Warehouse Boiler	2.62

(Air Pollution Control Board; 326 IAC 7-4-3; filed Aug 28, 1990, 4:50 p.m.: 14 IR 70; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477; filed Aug 31, 2004, 2:30 p.m.: 28 IR 117)

LSA Document #03-195(F)

Proposed Rule Published: April 1, 2004; 27 IR 2317

Hearing Held: June 2, 2004

Approved by Attorney General: August 13, 2004

Approved by Governor: August 30, 2004

Filed with Secretary of State: August 31, 2004, 2:30 p.m.

IC 4-22-7-5(c) notice from Secretary of State regarding documents incorporated by reference: None received by Publisher