

**Montgomery county emission limits.**

- (A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 1.5 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) [Reserved]
- (C) [Reserved]
- (D) [Reserved]
- (E) [Reserved]
- (F) [Reserved]
- (G) The "Delphi AHG Home Ave." (OEPA premise number 0857040931) or any subsequent owner or operator of the "Inland Division, General Motors Corporation Delphi AHG Home Ave., 2727 Inland Avenue, Dayton, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler numbers 4 through 6 (OEPA source numbers B001 through B003) to exceed a maximum of 1.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
- (H) [Reserved]
- (I) The "DP&L Tait Generating Station" (OEPA premise number 0857042072) or any subsequent owner or operator of the "DP&L Tait Generating Station, 2101 Arbor Blvd., Dayton, Ohio" shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:
  - (1) Boiler numbers 7-1, 7-2, 8-1, and 8-2 (OEPA source numbers B001, B002, B005, and B004); a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
  - (2) Boiler numbers 4 and 5 (OEPA source numbers B003 and B006); a maximum of 1.8 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
  - (3) Diesel IC units 1 through 4 (OEPA source numbers B507 through B510); a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each unit.
- (J) The "Harrison Radiator Division, General Motors Corporation" (OEPA premise number 0857100030) or any subsequent owner or operator of the "Harrison Radiator Division, General Motors Corporation, Dayton, Ohio" shall not cause or permit the

emission of sulfur dioxide from boiler numbers 1 through 8 (OEPA source numbers B001 through B008) to exceed a maximum of 1.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.

- (K) The "Appleton Papers, Inc." (OEPA premise number 0857190001) or any subsequent owner or operator of the "Appleton Papers, Inc., West Carrollton, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler numbers 2 and 4 (OEPA source numbers B002 and B003) to exceed a maximum of 1.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
- (L) [Reserved]
- (M) The "Dayton Power and Light Company, O.H. Hutchings Station" (OEPA premise number 0857780013) or any subsequent owner or operator of the "Dayton Power and Light Company, O.H. Hutchings Station, 9200 Chautauqua Road, Miamisburg, Ohio" shall not cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:
- (1) Boiler numbers 1 through 6 (OEPA source numbers B001 through B006); a maximum of 1.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
  - (2) Turbine number 7 (OEPA source number B007); a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input.
- (N) The "Dayton Power and Light Company, Yankee Substation" (OEPA premise number 0857810015) or any subsequent owner or operator of the "Dayton Power and Light Company, Yankee Substation, 9955 Yankee Road, Dayton, Ohio" shall not cause or permit the emission of sulfur dioxide from turbine numbers 1 through 7 (OEPA source numbers B001 through B007) to exceed a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each turbine.
- (O) The "Delphi AHG" (OEPA premise number 0857040018) or any subsequent owner or operator of the "Delphi AHG, 3100 Needmore Road, Dayton, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 4 (OEPA source numbers B001 through B004) to exceed a maximum of 1.3 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
- (P) The "Delphi AHG" (OEPA premise number 0857170125) or any subsequent owner or operator of the "Delphi AHG, North Dixie Highway, Vandalia, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler numbers 1 through 4 (OEPA source numbers B001 through B004) to exceed a maximum of 1.6 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
- (Q) The "Delphi AHG" (OEPA premise number 0857080148) or any subsequent owner or operator of the "Delphi AHG, 2000 Forrer Boulevard, Dayton, Ohio" shall not

cause or permit the emission of sulfur dioxide from the following sources to exceed the amounts indicated:

- (1) Boiler numbers 1 and 2 (OEPA source numbers B001 and B002); a maximum of 0.5 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.
- (2) Boiler numbers 3 and 4 (OEPA source numbers B003 and B004); a maximum of 1.2 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.

(R) [Reserved]

(S) [Reserved]

(T) The "Tate & Lyle, Incorporated" (OEPA premise number 0857041333) or any subsequent owner or operator of the "Tate & Lyle, Incorporated, 5600 Brentlinger Drive, Dayton, Ohio" shall not cause or permit the emission of sulfur dioxide from unit numbers 1 and 2 (OEPA source numbers B001 and B002) to exceed a maximum of 0.8 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.

Effective: 02/17/2011

R.C. 119.032 review dates: 11/30/2010 and 11/30/2015

CERTIFIED ELECTRONICALLY  
Certification

02/07/2011  
Date

Promulgated Under: 119.03  
Statutory Authority: 3704.03(E)  
Rule Amplifies: 3704.03(A), 3704.03(E)  
Prior Effective Dates: 12/28/79, 11/1/84, 1/23/06