



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 5
77 WEST JACKSON BOULEVARD
CHICAGO, IL 60604-3590

NOV 26 2012

REPLY TO THE ATTENTION OF:

Phil Kairis
Vice President
NRG Backup Generation Services
17685 Juniper Path, Suite 301
Lakeville, Minnesota 55044

Dear Mr. Kairis:

Please find enclosed with this letter copies of the final Modification of Air Quality Construction Permit, permit number PSD-PI-2704900084-2012-02, final Air Pollution Control Title V Permit to Operate, permit number V-PI-2704900084-2012-10, and associated statements of basis for Treasure Island Resort and Casino located in Red Wing, Minnesota. The Modification of Air Quality Construction Permit authorizes a reduction nitrogen oxide testing frequency from every 3 to 5 years. The Title V Permit to Operate authorizes NRG Backup Generation Services to operate four diesel-fired reciprocating internal combustion engines for Treasure Island Resort and Casino.

Our office received one comment regarding the draft permits during the public comment period which ended on October 19, 2012. Please also find enclosed a copy of our response to the comment.

These permits should be posted at the facility and distributed to staff members responsible for ensuring compliance with the conditions and limitations established in these permits. If you have any questions regarding this permit, please contact Michael Langman, of my staff, at (312) 886-6867.

Sincerely,

A handwritten signature in black ink, appearing to be "S Hedman".

Susan Hedman
Regional Administrator

Enclosures