



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 6

1445 ROSS AVENUE, SUITE 1200

DALLAS, TEXAS 75202-2733

August 1, 2011

CERTIFIED MAIL - RETURN RECEIPT REQUESTED: 7011 0110 0001 3590 6889

The Honorable Jack Torres
Mayor of Bernalillo
P.O. Box 638
Bernalillo, NM 87004

Re: Administrative Order Docket Number: CWA-06-2011-1778
Notice of Proposed Assessment of Class I Civil Penalty
Docket Number: CWA-06-2011-1822
NPDES Permit Number: NM0023485

Dear Mayor Torres:

Enclosed is an Administrative Order (AO) issued to the Town of Bernalillo for violation of Section 301(a) of the Clean Water Act. The violation was identified during our review of the permit file for your Bernalillo waste water treatment plant. The violation alleged was for exceedance of permitted effluent limitations. The AO requires certification of compliance with applicable effluent limitations within thirty (30) days of its receipt. The AO also contains other compliance deadlines.

Also enclosed for your review is a proposed Consent Agreement and Final Order (CAFO) that specifies a proposed settlement agreement between the Environmental Protection Agency (EPA) and the Town of Bernalillo, that will resolve the violation alleged. If you wish to enter into this settlement agreement, please sign, date, and return the CAFO, with original signature, to the attention of Mr. Efren Ordoñez (6RC-EW) at the address above.

If you agree to settle this matter by signing and returning the CAFO, EPA will solicit public comments, which may impact the settlement. After the consideration of public comments, EPA will sign and issue the CAFO which is effective upon filing with the Regional Hearing Clerk. Please do not send payment of the penalty until you receive the CAFO signed by EPA. By signing the CAFO and agreeing to settle the case, you waive your right to a hearing on, and to a judicial appeal of, the agreed civil penalty of \$7,800.00 specified in the CAFO.

Re: Administrative Order
Town of Bernalillo

2

The EPA is committed to ensuring compliance with the requirements of the National Pollutant Discharge Elimination System program, and my staff will assist you in any way possible. If you have any questions, or wish to discuss the possibility of a settlement of this matter, please contact Mr. Robert Houston, of my staff, at (214) 665-8565.

Sincerely,



John Blevins
Director
Compliance Assurance and
Enforcement Division

Enclosure

cc: w/CAFO - Regional Hearing Clerk

Mr. James Bearzi, Bureau Chief
Surface Water Quality Bureau
New Mexico Environment Department
P.O. Box 5469
Santa Fe, NM 87502-5469

Mr. Steve Paul
Chief Plant Operator
Town of Bernalillo WWTP
585 Calle Chaparral Rd.
Bernalillo, NM 87004

Mr. Frank Chavez
Environmental Director
c/o Pueblo of Sandia
481 Sandia Loop
Bernalillo, NM 87004



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 6
1445 ROSS AVENUE, SUITE 1200
DALLAS, TEXAS 75202-2733

August 1, 2011

Mr. James Bearzi, Bureau Chief
Surface Water Quality Bureau
New Mexico Environment Department
P.O. Box 5469
Santa Fe, NM 87502-5469


Re: Notice of Proposed Administrative Penalty Assessment
Docket Number: CWA-06-2011-1822
NPDES Permit Number: NM0023485

Dear Mr. Bearzi:

Enclosed is a copy of the Consent Agreement and Final Order (CAFO), which contains all elements of an administrative complaint, that the Environmental Protection Agency (EPA) is proposing to the Town of Bernalillo (Respondent), pursuant to Section 309(g) of the Clean Water Act (CWA), 33 U.S.C. § 1319(g). EPA is proposing to administratively assess a Class I civil penalty of \$7,800.00 against the Respondent for violation of the CWA. Because the violation has occurred in the State of New Mexico, I am offering you an opportunity to confer with us regarding the proposed penalty assessment.

You may request a conference within two weeks of receipt of this letter. The conference may be in person or by telephone and may cover any matters relevant to the proposed penalty assessment. If you wish to request a conference or if you have any comments or questions regarding the matter, please contact Robert Houston, of my staff, at (214) 665-8565.

Sincerely,


John Blevins
Director
Compliance Assurance and
Enforcement Division

Enclosure



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 6 • 1445 Ross Avenue, Suite 1200 • Dallas, TX 75202-2733
FINDINGS OF VIOLATIONS and ORDER FOR COMPLIANCE
Docket Number: CWA-06-2011-1778, NPDES Permit No.: NM0023485

Statutory Authority

The following findings are made, and Order issued, under the authority vested in the Administrator of the United States Environmental Protection Agency ("EPA"), by Section 309(a) of the Clean Water Act (the "Act"), 33 U.S.C. § 1319(a). The Administrator of EPA has delegated the authority to issue this Order to the Regional Administrator of EPA Region 6, who delegated this authority to the Director of the Compliance Assurance and Enforcement Division.

Findings

1. The Town of Bernalillo ("Respondent") is a "person," as that term is defined at Section 502(5) of the Act, 33 U.S.C. § 1362(5), and 40 C.F.R. § 122.2.
2. At all times relevant to this Order ("all relevant times"), the Respondent owned or operated a waste water treatment plant located at 585 Calle Chaparral, in Bernalillo, Sandoval County, New Mexico ("facility"), and was, therefore, an "owner or operator" within the meaning of 40 C.F.R. § 122.2.
3. At all relevant times, the facility was a "point source" of a "discharge" of "pollutants" with its wastewater to the receiving waters of the Rio Grande in Segment 20.6.4.106 of the Rio Grande Basin, which is considered a "water of the United States" within the meaning of Section 502 of the Act, 33 U.S.C. § 1362, and 40 C.F.R. § 122.2.
4. Because the Respondent owned or operated a facility that acted as a point source of discharges of pollutants to waters of the United States, the Respondent and the facility were subject to the Act and the National Pollutant Discharge Elimination System ("NPDES") program.
5. Under Section 301 of the Act, 33 U.S.C. § 1311, it is unlawful for any person to discharge any pollutant from a point source to waters of the United States, except with the authorization of, and in compliance with, an NPDES permit issued pursuant to Section 402 of the Act, 33 U.S.C. § 1342.
6. Section 402(a) of the Act, 33 U.S.C. § 1342(a), provides that the Administrator of EPA may issue permits under the NPDES program for the discharge of pollutants from point sources to waters of the United States. Any such discharge is subject to the specific terms and conditions prescribed in the applicable permit.
7. The Respondent applied for and was issued NPDES Permit Number NM0023485 ("permit") under Section 402 of the Act, 33 U.S.C. § 1342, which became effective on February 1, 2004, and was re-issued on November 1, 2010. At all relevant times, the Respondent was authorized to discharge pollutants from the facility to waters of the United States only in compliance with the specific terms and conditions of the permit.
8. Part I.A of the permit places certain limitations on the quality and quantity of effluent discharged by the Respondent. The relevant discharge limitations are listed in Attachment A, which is incorporated by reference, for the permit that was issued on February 1, 2004, and expired five (5) years after the issuance date. The current discharge limitations are also listed in Attachment B, which is incorporated by reference, for the current permit that was issued on November 1, 2010.
9. Parts III.C and III.D of the permit require the Respondent to sample and test its effluent and monitor its compliance with permit conditions according to specific procedures, in order to determine the facility's compliance or noncompliance with the permit and applicable regulations. Parts III.C and III.D also require the Respondent to file with EPA certified DMRs of the results of monitoring, and Noncompliance Reports when appropriate.
10. Certified Discharge Monitoring Reports ("DMRs") filed by the Respondent with EPA in compliance with the permit show discharges of pollutants from the facility that exceed the permitted effluent limitations established in Part I.A of the permit. The discharge of pollutants that exceeded the current permit limitations are specified in Attachment C.
11. Each instance in which the Respondent discharged pollutants to waters of the United States in amounts exceeding the effluent limitations contained in the permit was a violation of the permit and Section 301 of the Act, 33 U.S.C. § 1311.

ORDER

Based on the foregoing Findings and pursuant to the authority of Section 309 of the Act, EPA hereby orders the Respondent to take the following actions:

- A. Within thirty (30) days of the effective date of this Order, the Respondent shall certify compliance with permit effluent limitations for Total Ammonia.

B. Within thirty (30) days of the effective date of this Order, the Respondent shall also provide the EPA with a list of all mechanical and operational deficiencies and a narrative describing the specific actions taken to correct the violations for Total Ammonia cited in Attachment C.

C. In the event that it will take the Respondent longer than thirty (30) days to provide an explanation as to why compliance is not possible, a listing of all non-compliance-related deficiencies and a schedule for repair/correction for each deficiency shall be submitted to the EPA for review and approval.

D. Any approved compliance schedule will be incorporated and reissued in a future enforcement action.

E. To ask questions or comment on this matter, please contact Mr. Robert Houston, of my staff, at (214) 665-8565.

F. Any information or correspondence submitted by the Respondent to EPA under this Order shall be addressed to the following:

Ms. Sonia Hall
Water Enforcement Branch (6EN-WC)
EPA, Region 6
1445 Ross Ave., Suite 1200
Dallas, TX 75202-2733

GENERAL PROVISIONS


Issuance of this Order shall not be deemed an election by EPA to forego any administrative or judicial, civil or criminal action to seek penalties, fines, or any other relief appropriate under the Act for the violations cited herein, or other violations that become known. EPA reserves the right to seek any remedy available under the law that it deems appropriate. Failure to comply with this Order or the Act can result in further administrative action, or a civil judicial action initiated by the United States Department of Justice.

This Order does not constitute a waiver or modification of the terms or conditions of the Respondent's NPDES permit, which remain in full force and effect. Compliance with the terms and conditions of this Order does not relieve the Respondent of its obligation to comply with any applicable federal, state, or local law or regulation.

The effective date of this Order is the date it is received by the Respondent.

AUG 01 2011

Date


John Blevins
Director
Compliance Assurance and
Enforcement Division


DRAFT CAFO Concurrence

Town of Bernalillo

Docket Number: CWA-06-2011-1822

Permit Number: NM0023485

Signature: _____

A handwritten signature in black ink, consisting of several overlapping loops and a long horizontal stroke extending to the right.

Date: _____

8-7-11

UNITED STATES
ENVIRONMENTAL PROTECTION AGENCY
REGION 6

In the Matter of

Town of Bernalillo,
a New Mexico Municipality,

Respondent

Permit No. NM0023485

§
§
§
§
§
§
§
§
§
§
§

Docket No. CWA-06-2011-1822

CONSENT AGREEMENT AND FINAL ORDER

I. PRELIMINARY STATEMENT

1. This Consent Agreement and Final Order (“CAFO”) is issued under the authority vested in the United States Environmental Protection Agency (“EPA”) pursuant to Section 309(g) of the Clean Water Act (“the Act”), 33 U.S.C. § 1319(g). This CAFO is issued to simultaneously commence and conclude this proceeding to assess a civil penalty in accordance with 40 C.F.R. §§ 22.13(b) and 22.18(b)(2) and (3), as described in the “Consolidated Rules of Practice Governing the Administrative Assessment of Civil Penalties and the Revocation/Termination or Suspension of Permits.”

2. The EPA and Respondent (“Parties”) agree that settlement of the relevant matters without litigation will save time and resources, that it is in the public’s interest, and that the entry of this CAFO is the most appropriate means of resolving such matters. Compliance with all the terms and conditions of this CAFO resolves only those violations specified in this CAFO.

3. Respondent admits the jurisdictional allegations herein; however, Respondent neither admits nor denies the specific Findings of Fact and Conclusions of Law contained in this CAFO. This CAFO states a claim(s) upon which relief may be granted.

4. Respondent expressly waives any right to contest the factual allegations or conclusions of law contained in this CAFO, and waives its right to appeal the Final Order set forth herein.

5. Before the taking of any testimony, and without adjudication of any issue of law or fact, the parties agree to the terms of this CAFO and to its issuance. Respondent consents to the assessment and payment of a civil penalty in the amount and by the method stated below.

II. FINDINGS OF FACT AND CONCLUSIONS OF LAW

6. Town of Bernalillo (herein "Respondent") is a municipality, chartered under the laws of the State of New Mexico, and as such, Respondent is a "person," as that term is defined at Section 502(5) of the Act, 33 U.S.C. § 1362(5), and 40 C.F.R. § 122.2.

7. At all times relevant to the violations alleged herein ("all relevant times"), Respondent owned or operated a municipal wastewater treatment plant located at 585 Calle Chaparral, in Bernalillo, Sandoval County, New Mexico ("facility"), and was therefore an "owner or operator" within the meaning of 40 C.F.R. § 122.2.

8. During the relevant time period, the facility was a "point source" of a "discharge" of "pollutants" with its waste water discharges to the receiving waters of the Rio Grande in Segment 20.6.4.106 of the Rio Grande Basin which is a "water of the United States" within the meaning of 40 C.F.R. § 122.2.

9. Because Respondent owned or operated a facility that acted as a point source of discharges of pollutants to waters of the United States, Respondent and the facility were subject to the Act and the National Pollutant Discharge Elimination System ("NPDES") program.

10. Under Section 301 of the Act, 33 U.S.C. § 1311, it is unlawful for any person to discharge any pollutant from a point source to waters of the United States, except with the authorization of, and in compliance with, an NPDES permit issued pursuant to Section 402 of the Act, 33 U.S.C. § 1342.

11. Section 402(a) of the Act, 33 U.S.C. § 1342(a), provides that the Administrator of EPA may issue permits under the NPDES program for the discharge of pollutants from point sources to waters of the United States. Any such discharge is subject to the specific terms and conditions prescribed in the applicable permit.

12. Respondent applied for and was issued NPDES Permit No. NM0023485 (herein "the NPDES Permit") under Section 402 of the Act, 33 U.S.C. § 1342, which became effective on February 1, 2004, and expired on January 9, 2009. At all relevant times, Respondent was authorized to discharge pollutants from the facility to waters of the United States but only in compliance with the specific effluent limits specified in Part I.A of the NPDES Permit.

13. Part I.A of the permit places certain limitations on the quality and quantity of effluent discharge by Respondent. The relevant discharge limitations are specified below:

<u>Effluent Characteristics</u>	<u>Discharge Limitations</u>		
	30-Day Avg.	30-Day Avg.	Daily Max.
Ammonia, Total	2.0 lbs./day	0.30 mg/L	0.71 mg/L
Arsenic, Total	0.00012 lbs./day	0.0175 ug/L	N/A

14. Respondent applied for and was re-issued NPDES permit coverage under the permit described above, and was assigned NPDES Permit No. NM0023485, effective on November 1, 2010. Beginning on the effective date, Respondent was authorized to discharge pollutants to waters of the United States, but only in compliance with specific effluent limitation terms specified in Part I.A of the NPDES Permit.

15. Part I.A. of the re-issued NPDES Permit places certain limitations on the quality and quantity of effluent discharge by Respondent. The relevant discharge limitations are specified below:

Effluent Characteristics	Discharge Limitations				
	30-Day Avg.	30-Day Avg.	Daily Max.		
Ammonia, Total	2.14 mg/L		3.21 mg/L		N/A
Arsenic, Total	Report		Report		N/A

16. Parts III.C and III.D of the NPDES Permit require the Respondent to sample and test its effluent and monitor its compliance with permit conditions according to specific procedures, in order to determine the facility's compliance or noncompliance with the permit and applicable regulations. They also require Respondent to file with EPA certified Discharge Monitoring Reports ("DMRs") of the results of monitoring, and Noncompliance Reports when appropriate.

17. Certified DMRs filed by Respondent with EPA in compliance with the permit show discharges of pollutants from the facility that exceed the permitted effluent limitations established in Part I.A of the NPDES Permit, as specified below:

Date	Outfall	Parameter	Violation	Permit Limit
September 30, 2010	001 A	Ammonia, Total 30 Day Average	10.93 lbs./day	2 lbs./day
September 30, 2010	001 A	Ammonia, Total 30 Day Average	2 mg/L	0.30 mg/L
September 30, 2010	001 A	Ammonia, Total 7 Day Average	5.70 mg/L	0.71 mg/L
May 31, 2010	001 A	Ammonia, Total 30 Day Average	7.02 lbs./day	2 lbs./day
May 31, 2010	001 A	Ammonia, Total 30 Day Average	1.4 mg/L	0.30 mg/L
May 31, 2010	001 A	Ammonia, Total 7 Day Average	3.1 mg/L	0.71 mg/L
March 31, 2010	001 A	Arsenic, Total 30 Day Average	0.06 lbs./day	0.00012 lbs./day
March 31, 2010	001 A	Arsenic, Total 30 Day Average	11.5 ug/L	0.0175 ug/L
March 31, 2010	001 A	Arsenic, Total Daily Maximum	11.5 ug/L	0.0417 ug/L
January 31, 2010	001 A	Ammonia, Total 30 Day Average	3.48 lbs./day	2 lbs./day
January 31, 2010	001 A	Ammonia, Total 30 Day Average	0.7 mg/L	0.30 mg/L
January 31, 2010	001 A	Ammonia, Total 7 Day Average	0.9 mg/L	0.71 mg/L
January 31, 2010	001 A	Arsenic, Total 30 Day Average	0.06 lbs./day	0.00012 lbs./day
January 31, 2010	001 A	Arsenic, Total 30 Day Average	11.23 ug/L	0.0175 ug/L
January 31, 2010	001 A	Arsenic, Total Daily Maximum	11.23 ug/L	0.0417 ug/L
November 30, 2009	001 A	Ammonia, Total 30 Day Average	3.1 lbs./day	2 lbs./day
November 30, 2009	001 A	Ammonia, Total 30 Day Average	0.6 mg/L	0.30 mg/L
November 30, 2009	001 A	Ammonia, Total 7 Day Average	0.96 mg/L	0.71 mg/L
October 31, 2009	001 A	Ammonia, Total 30 Day Average	3.1 lbs./day	2 lbs./day

Date	Outfall	Parameter	Violation	Permit Limit
October 31, 2009	001 A	Ammonia, Total 30 Day Average	0.6 mg/L	0.30 mg/L
October 31, 2009	001 A	Ammonia, Total 7 Day Average	0.96 mg/L	0.71 mg/L
September 30, 2009	001 A	Arsenic, Total 30 Day Average	0.7 lbs./day	0.00012 lbs./day
September 30, 2009	001 A	Arsenic, Total 30 Day Average	11.54 ug/L	0.0175 ug/L
September 30, 2009	001 A	Arsenic, Total Daily Maximum	11.54 ug/L	0.0417 ug/L
August 31, 2009	001 A	Ammonia, Total 30 Day Average	6.56 lbs./day	2 lbs./day
August 31, 2009	001 A	Ammonia, Total 30 Day Average	1.2 mg/L	0.30 mg/L
August 31, 2009	001 A	Ammonia, Total 7 Day Average	1.6 mg/L	0.71 mg/L
July 31, 2009	001 A	Ammonia, Total 30 Day Average	49.78 lbs./day	2 lbs./day
July 31, 2009	001 A	Ammonia, Total 30 Day Average	8.7 mg/L	0.30 mg/L
July 31, 2009	001 A	Ammonia, Total 7 Day Average	16 mg/L	0.71 mg/L
July 31, 2009	001 A	Arsenic, Total 30 Day Average	0.07 lbs./day	0.00012 lbs./day
July 31, 2009	001 A	Arsenic, Total 30 Day Average	13.28 ug/L	0.0175 ug/L
July 31, 2009	001 A	Arsenic, Total Daily Maximum	13.28 ug/L	0.0417 ug/L
June 30, 2009	001 A	Ammonia, Total 30 Day Average	3.7 lbs./day	2 lbs./day
June 30, 2009	001 A	Ammonia, Total 30 Day Average	0.7 mg/L	0.30 mg/L
June 30, 2009	001 A	Ammonia, Total 7 Day Average	0.9 mg/L	0.71 mg/L
June 30, 2009	001 A	Arsenic, Total 30 Day Average	0.07 lbs./day	0.00012 lbs./day
June 30, 2009	001 A	Arsenic, Total 30 Day Average	13.3 ug/L	0.0175 ug/L
June 30, 2009	001 A	Arsenic, Total Daily Maximum	13.3 ug/L	0.0417 ug/L

Date	Outfall	Parameter	Violation	Permit Limit
May 31, 2009	001 A	Ammonia, Total 30 Day Average	5.8 lbs./day	2 lbs./day
May 31, 2009	001 A	Ammonia, Total 30 Day Average	1 mg/L	0.30 mg/L
May 31, 2009	001 A	Ammonia, Total 7 Day Average	1.6 mg/L	0.71 mg/L
January 31, 2009	001 A	Ammonia, Total 30 Day Average	22.87 lbs./day	2 lbs./day
January 31, 2009	001 A	Ammonia, Total 30 Day Average	2.6 mg/L	0.30 mg/L
January 31, 2009	001 A	Ammonia, Total 7 Day Average	7.3 mg/L	0.71 mg/L
December 31, 2008	001 A	Arsenic, Total 30 Day Average	0.11 lbs./day	0.00012 lbs./day
December 31, 2008	001 A	Arsenic, Total 30 Day Average	11.78 ug/L	0.0175 ug/L
December 31, 2008	001 A	Arsenic, Total Daily Maximum	11.78 ug/L	0.0417 ug/L

18. Each instance in which Respondent discharged pollutants to waters of the United States in amounts exceeding the effluent limitations contained in the NPDES Permit was a violation of the NPDES Permit and Section 301 of the Act, 33 U.S.C. § 1311.

19. The State of New Mexico was notified and given an opportunity to consult with EPA regarding the proposed assessment of an administrative penalty against Respondent.

20. EPA notified the public of the proposed CAFO and afforded the public forty (40) days to comment on the proposed penalty. At the expiration of the notice period, EPA had received no comments from the public.

III. TERMS OF SETTLEMENT

A. PENALTY PROVISIONS

21. Based on the foregoing Findings of Fact and Conclusions of Law, EPA Region 6, considering the relevant criteria pursuant to Section 309(g)(3) of the Act, 33 U.S.C. § 1319(g)(3), and acting pursuant to the authority of Section 309(g) of the Act, 33 U.S.C. § 1319(g), hereby orders that Respondent shall pay to the United States a civil penalty in the amount of seven thousand eight hundred dollars (\$7,800.00) to settle the violations specified in this CAFO.

22. Payment shall be made by one of the following methods within thirty (30) days of the effective date of this CAFO.

- a. By mailing a bank check, cashier's check or certified check, payable to "Treasurer of the United States," to:
U.S. Environmental Protection Agency
Fines and Penalties
Cincinnati Finance Center
P.O. Box 979077
St. Louis, MO 63197-9000
- b. By wire transfer to:
Federal Reserve Bank of New York
ABA: 021030004
Account: 68010727
SWIFT address: FRNYUS33
33 Liberty Street
New York, NY 10045
Field Tag 4200 of the Fedwire message should read:
"D68010727 Environmental Protection Agency"
- c. By overnight mail (Express, FedEx, DHL, etc.) to:
U.S. Bank
Government Lockbox 979077
U.S. EPA Fines & Penalties
1005 Convention Plaza
Mail Station SL-MO-C2-GL
St. Louis, MO 63101
Phone: 314-418-1028

- d. By credit card payments to <https://www.pay.gov>
(enter sfo 1.1 in the search field)

“In the Matter of Town of Bernalillo, Docket No. CWA-06-2011-1822” should be clearly marked on the check, or other payment method, to ensure credit for payment.

23. Respondent shall send simultaneous notices of payment, including a copy of the check, or other payment method, to each of the following:

- (1) Regional Hearing Clerk (6RC-D)
U.S. EPA, Region 6
1445 Ross Avenue, Suite 1200
Dallas, TX 75202-2733
- (2) Chief, NPDES Compliance Monitoring (6EN-WC)
U.S. EPA, Region 6
1445 Ross Avenue, Suite 1200
Dallas, TX 75202-2733
- (3) Chief, Water Enforcement Legal Branch (6RC-EW)
U.S. EPA, Region 6
1445 Ross Avenue, Suite 1200
Dallas, TX 75202-2733

Respondent's adherence to these procedures will ensure proper credit when payment is received by EPA.

24. Respondent agrees not to claim or attempt to claim a federal income tax deduction or credit covering all or any part of the civil penalty paid to the United States Treasurer.

25. Pursuant to 31 U.S.C. § 3717 and 40 C.F.R. § 13.11, unless otherwise prohibited by law, EPA will assess interest and late payment penalties on outstanding debts owed to the United States and a charge to cover the costs of processing and handling a delinquent claim. Interest on the civil penalty assessed in this CAFO will begin to accrue thirty (30) days after the effective date of the CAFO and will be recovered by EPA on any amount of the civil penalty that

is not paid by the respective due date. Interest will be assessed at the rate of the United States Treasury tax and loan rate in accordance with 40 C.F.R. § 13.11(a). Moreover, the costs of the Agency's administrative handling of overdue debts will be charged and assessed monthly throughout the period the debt is overdue. See 40 C.F.R. § 13.11(b).

26. EPA will also assess a fifteen dollar (\$15.00) administrative handling charge for administrative costs on unpaid penalties for the first thirty (30)-day period after the payment is due and an additional fifteen dollars (\$15.00) for each subsequent thirty (30)-day period that the penalty remains unpaid. In addition, a penalty charge of up to six percent (6%) per year will be assessed monthly on any portion of the debt which remains delinquent more than ninety (90) days. See 40 C.F.R. § 13.11(c). Should a penalty charge on the debt be required, it shall accrue from the first day payment is delinquent. See 31 C.F.R. § 901.9(d). Other penalties for failure to make a payment may also apply.

27. Pursuant to Section 309(g)(9) of the Act, 33 U.S.C. § 1319(g)(9), any person who fails to pay, on a timely basis, a civil penalty ordered or assessed under this section shall be required to pay, in addition to such penalty and interest, the United States enforcement expenses, including but not limited to, attorneys' fees and costs incurred by the United States for collection proceedings, and a quarterly non-payment penalty for each quarter during which such failure to pay persists. Such non-payment penalty shall be twenty percent (20%) of the aggregate amount of such person's outstanding penalties and non-payment penalties accrued as of the beginning of each quarter. In such a collection action, the validity, amount, and appropriateness of the penalty assessed by this CAFO, and the terms of this CAFO shall not be subject to review.

B. GENERAL PROVISIONS

28. To execute this Agreement, Respondent shall forward this copy of the CAFO, with original signature, to:

Mr. Efren Ordoñez (6RC-EW)
Water Enforcement Legal Section
U.S. EPA, Region 6
1445 Ross Avenue, Suite 1200
Dallas, TX 75202-2733

29. Issuance of this CAFO does not relieve Respondent from responsibility to comply with all requirements of the Act and the requirements of any permits issued thereunder, as described in Section 309(g)(7) of the Act, 33 U.S.C. § 1319(g)(7), nor does it constitute a waiver by EPA of its right to enforce compliance with the requirements of Respondent's permits or other requirements of the Act by actions pursuant to Section 309 of the Act, 33 U.S.C. § 1319.

30. In any action to enforce this CAFO, Respondent shall not assert as a defense any act or failure to act by any of its officers, directors, employees, agents, servants, contractors, subcontractors, successors or assigns.

31. Each party agrees to bear its own costs and attorneys' fees in this matter, except to the extent that Respondent may be responsible for reasonable costs and expenses of enforcement and collection proceedings for failure to comply with the terms of this CAFO. Furthermore, Respondent specifically waives its right to seek reimbursement of its costs and attorneys' fees under the Equal Access to Justice Act (5 U.S.C. § 504), as amended by the Small Business Regulatory Enforcement Fairness Act (P.L.104-121), and any regulations promulgated pursuant to those Acts.

32. Each undersigned representative of the parties to this agreement certifies that he or she is fully authorized by the party represented to enter into the terms and conditions of this agreement and to execute and legally bind that party to it.

In recognition and acceptance of the foregoing:

For Town of Bernalillo

Date:

John Blevins
Director
Compliance Assurance and
Enforcement Division

Date

FINAL ORDER

Pursuant to the Consolidated Rules of Practice Governing the Administrative Assessment of Civil Penalties, 40 C.F.R. Part 22, the foregoing Consent Agreement is hereby ratified.

This Final Order shall not in any case affect the right of EPA or the United States to pursue appropriate injunctive or other equitable relief or criminal sanctions for any violations of law.

This Final Order shall resolve only those causes of action alleged in the CAFO. Nothing in this Final Order shall be construed to waive, extinguish or otherwise affect Respondent's (or its officers', agents', servants', employees', successors', or assigns') obligation to comply with all applicable federal, state, and local statutes and regulations, including the regulations that were the subject of this action. The Respondent is ordered to comply with the terms of settlement and the civil penalty payment instructions as set forth in the Consent Agreement.

Pursuant to 40 C.F.R. § 22.31(b), this Final Order shall become effective upon filing with the Regional Hearing Clerk.

Issuance Date: _____

Regional Judicial Officer
U.S. EPA, Region 6

CERTIFICATE OF SERVICE

I hereby certify that on the _____ day of _____, 2011, the original of the foregoing Consent Agreement and Final Order was hand-delivered to the Regional Hearing Clerk, U.S. EPA, Region 6 (6RC-D), 1445 Ross Avenue, Suite 1200, Dallas, Texas 75202-2733, and that a true and correct copy was placed in the United States mail, by certified mail, return receipt requested, addressed to the following:

Copy by certified mail,
return receipt requested:

The Honorable Jack Torres
Mayor of Bernalillo
P.O. Box 638
Bernalillo, NM 87004

Copy:

Mr. James Bearzi
Bureau Chief
Surface Water Quality Bureau
New Mexico Environment Department
P.O. Box 5469
Santa Fe, NM 87502-5469

Mr. Frank Chavez
Environmental Director
c/o Pueblo of Sandia
481 Sandia Loop
Bernalillo, NM 87004

Mr. Steve Paul
Chief Plant Operator
Town of Bernalillo WWTP
585 Calle Chaparral Rd.
Bernalillo, NM 87004

Copy hand-delivered: Mr. Efren Ordoñez (6RC-EW)

Dated: _____