

(3) Emergency heating equipment, using coal or wood for fuel, with a rated capacity less than 50,000 BTU per hour.

(4) Exhaust systems for controlling steam and heat that do not contain combustion products.

R307-401-11. Replacement-in-Kind Equipment.

(1) Applicability. Existing process equipment or pollution control equipment that is covered by an existing approval order or State Implementation Plan requirement may be replaced using the procedures in (2) below if:

(a) the potential to emit of the process equipment is the same or lower;

(b) the number of emission points or emitting units is the same or lower;

(c) no additional types of air contaminants are emitted as a result of the replacement;

(d) the process equipment or pollution control equipment is identical to or functionally equivalent to the replaced equipment;

(e) the replacement does not change the basic design parameters of the process unit or pollution control equipment;

(f) the replaced process equipment or pollution control equipment is permanently removed from the stationary source, otherwise permanently disabled, or permanently barred from operation;

(g) the replaced process equipment or pollution control equipment does not trigger New Source Performance Standards or National Emissions Standards for Hazardous Air Pollutants under 42 U.S.C. 7411 or 7412; and

(h) the replacement of the control apparatus or process equipment does not violate any other provision of Title R307.

(2) Replacement-in-Kind Procedures.

(a) In lieu of filing a notice of intent under R307-401-5, the owner or operator of a stationary source shall submit a written notification to the executive secretary before replacing the equipment. The notification shall contain a description of the replacement-in-kind equipment, including the control capability of any control apparatus and a demonstration that the conditions of (1) above are met.

(b) If the replacement-in-kind meets the conditions of (1) above, the executive secretary will update the source's approval order and notify the owner or operator. Public review under R307-401-7 is not required for the update to the approval order.

(3) If the replaced process equipment or pollution control equipment is brought back into operation, it shall constitute a new emissions unit.

R307-401-12. Reduction in Air Contaminants.

(1) Applicability. The owner or operator of a stationary source of air contaminants that reduces or eliminates

air contaminants is exempt from the approval order requirements of R307-401-5 through 8 if:

(a) the project does not increase the potential to emit of any air contaminant or cause emissions of any new air contaminant, and

(b) the executive secretary is notified of the change and the reduction of air contaminants is made enforceable through an approval order in accordance with (2) below.

(2) Notification. The owner or operator shall submit a written description of the project to the executive secretary no later than 60 days after the changes are made. The executive secretary will update the source's approval order or issue a new approval order to include the project and to make the emission reductions enforceable. Public review under R307-401-7 is not required for the update to the approval order.

R307-401-13. Plantwide Applicability Limits.

A plantwide applicability limit under R307-405-21 does not exempt a stationary source from the requirements of R307-401.

R307-401-14. Used Oil Fuel Burned for Energy Recovery.

(1) Definitions.

"Boiler" means boiler as defined in R315-1-1 that incorporates by reference the term "boiler" in 40 CFR 260.10, 2000 ed., as amended by 67 FR 2962, January 22, 2002.

"Used Oil" is defined as any oil that has been refined from crude oil, used, and, as a result of such use contaminated by physical or chemical impurities.

(2) Boilers burning used oil for energy recovery are exempted from the requirement to obtain an approval order in R307-401-5 through 8 if the following requirements are met:

(a) the heat input design is less than one million BTU/hr;

(b) contamination levels of all used oil to be burned do not exceed any of the following values:

(i) arsenic - 5 ppm by weight,

(ii) cadmium - 2 ppm by weight,

(iii) chromium - 10 ppm by weight,

(iv) lead - 100 ppm by weight,

(v) total halogens - 1,000 ppm by weight,

(vi) Sulfur - 0.50% by weight; and

(c) the flash point of all used oil to be burned is at least 100 degrees Fahrenheit.

(3) Testing. The owner or operator shall test each load of used oil received or generated as directed by the executive secretary to ensure it meets these requirements. Testing may be performed by the owner/operator or documented by test reports from the used fuel oil vendor. The flash point shall be measured using the appropriate ASTM method as required by the executive secretary. Records for used oil consumption and test reports are to be kept for all periods when fuel-burning equipment is in operation. The records shall be kept on site and made available to the executive secretary or