



JUN 26 2013

Gerardo C. Rios, Chief
Permits Office
Air Division
U.S. EPA - Region IX
75 Hawthorne St
San Francisco, CA 94105

**Re: Final - Authority to Construct / Certificate of Conformity (Minor Mod)
Project # S-1130353**

Dear Mr. Rios:

The Air Pollution Control Officer has issued an Authority to Construct (S-33-130-7) with a Certificate of Conformity to Alon Bakersfield Refining. Alon Bakersfield Refining has requested to designate the low-use engine an emergency only engine.

Enclosed are copies of the Authority to Construct. The application and proposal were sent to US EPA Region IX on June 7, 2013. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,



David Warner
Director of Permit Services

Enclosures
ktr

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



JUN 26 2013

Ms. Helen Ordway
Alon Bakersfield Refining
6451 Rosedale Highway
Bakersfield, CA 93308

**Re: Final - Authority to Construct / Certificate of Conformity (Minor Mod)
Project # S-1130353**

Dear Ms. Ordway:

The Air Pollution Control Officer has issued an Authority to Construct (S-33-130-7) with a Certificate of Conformity to Alon Bakersfield Refining. Alon Bakersfield Refining has requested to designate the low-use engine an emergency only engine.

Enclosed is the Authority to Construct and invoice. The application and proposal were sent to US EPA Region IX on June 7, 2013. No comments were received following the District's preliminary decision on this project.

Prior to operating with modifications authorized by the Authority to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,



David Warner
Director of Permit Services

Enclosures
ktr

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



AUTHORITY TO CONSTRUCT

PERMIT NO: S-33-130-7

ISSUANCE DATE: 06/25/2013

LEGAL OWNER OR OPERATOR: ALON BAKERSFIELD REFINING
MAILING ADDRESS: 6451 ROSEDALE HWY
BAKERSFIELD, CA 93308

LOCATION: 6451 ROSEDALE HWY (AREA 1 & 2)
BAKERSFIELD, CA 93308

SECTION: 28 **TOWNSHIP:** 29S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 415 HP DIESEL-FIRED "LOW-USE" I.C. ENGINE #86-C36-G POWERING AN AIR COMPRESSOR:
CONVERT FROM LOW-USE TO EMERGENCY STANDBY SERVICE

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rules 2201 and 4201] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following: NOx (as NO2): 600 ppmv @ 15% O2 or 20% reduction of uncontrolled NOx emissions, or CO: 2000 ppmv @ 15% O2. [District Rule 2520, 9.3.2 and 4701] Federally Enforceable Through Title V Permit
5. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [District Rules 4701 and 4702, CCR §93115.6(b)(3), and 40 CFR 63.6640 (f)(ii)] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

S-33-130-7: Jun 25 2013 11:45AM - RICKARDK : Joint Inspection NOT Required

6. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rule 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
7. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 40 CFR 63.6625 (f), and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, Kern County Rule 407, 40 CFR 63.6604, and 17 CCR 93115] Federally Enforceable Through Title V Permit
9. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
10. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
11. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
12. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
13. The permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63.6625(h)] Federally Enforceable Through Title V Permit
14. The engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR 63.6603/63.6640] Federally Enforceable Through Title V Permit
15. The permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63.6603/63.6640] Federally Enforceable Through Title V Permit
17. The engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63.6603/63.6640] Federally Enforceable Through Title V Permit
18. The permittee shall maintain monthly records of all performance tests, opacity and visible emissions observations and required maintenance performed on the air pollution control and monitoring equipment. [District Rule 1070 and 40 CFR 63.6655(a)(3)/§63.10(b)(2)(viii) and §63.6655(a)(4)] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

19. The permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [District Rule 1070 and 40 63.6655(a)(2) and (a)(5)] Federally Enforceable Through Title V Permit
20. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
21. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
22. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 4702, 40 CFR 63.6660, and 17 CCR 93115] Federally Enforceable Through Title V Permit